

OUVEA, New Caledonia

WMO: 915790

Lat: 20.639S

Lon: 166.571E

Elev: 9

StdP: 101.22

Time Zone: 11.00 (E11)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	15.1	10.5	7.9	18.7	11.5	8.5	19.4	9.8	21.6	9.2	21.8	0.6	190	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.1	31.0	25.9	30.5	25.6	29.9	25.2	27.1	29.7	26.6	29.2	26.2	28.7	4.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.7	28.6	25.8	21.1	28.2	25.4	20.6	27.9	85.5	29.9	83.3	29.2	81.5	28.8	31.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	8.6	8.1	10.7	32.1	1.4	0.7	9.7	32.6	8.8	33.1	8.0	33.5	7.0	34.0
			10.1	27.9	1.2	1.1	9.3	28.7	8.6	29.4	7.9	30.0	7.1	30.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.4	26.9	27.3	26.9	25.8	24.1	22.6	21.5	21.5	22.4	23.6	24.8	26.1	(6)
	DBStd	2.47	1.08	1.01	0.99	1.21	1.48	1.55	1.69	1.81	1.59	1.31	1.22	1.06	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	3	0	0	0	0	0	0	1	2	0	0	0	0	(9)
	CDD10.0	5271	523	485	523	476	436	378	356	357	372	421	445	500	(10)
	CDD18.3	2233	264	252	265	226	177	129	98	101	123	162	195	242	(11)
	CDH23.3	15380	2562	2592	2523	1759	848	343	161	198	396	747	1219	2033	(12)
	CDH26.7	2864	649	705	566	261	43	6	1	2	16	45	159	413	(13)
(14) Wind	WSAvg	4.6	4.5	4.4	4.5	4.9	4.5	4.6	4.3	4.3	4.4	4.9	4.9	4.7	(14)
(15) Precipitation	PrecAvg	1152	150	134	174	90	78	97	91	62	42	62	86	86	(15)
	PrecMax	2156	635	499	634	313	231	228	299	258	197	237	289	235	(16)
	PrecMin	665	32	27	22	1	4	1	2	1	0	4	0	1	(17)
	PrecStd	411	134	115	132	80	68	59	81	56	45	56	74	64	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.6	32.1	31.3	30.5	28.6	27.5	26.5	26.8	28.4	28.5	29.7	31.2	(19)
		MCWB	25.8	26.6	26.4	26.1	24.1	23.5	22.1	22.3	23.0	22.8	24.2	25.3	(20)
	2%	DB	30.7	31.1	30.5	29.5	27.8	26.5	25.5	25.9	26.9	27.7	28.9	30.2	(21)
		MCWB	25.5	26.1	25.9	25.2	23.5	22.6	21.1	21.7	21.9	22.3	23.6	24.8	(22)
	5%	DB	30.1	30.5	29.9	28.8	27.1	25.8	24.8	25.1	26.1	27.1	28.2	29.4	(23)
		MCWB	25.1	25.7	25.5	24.5	22.9	21.8	20.4	20.8	20.9	21.9	22.9	24.3	(24)
	10%	DB	29.5	29.9	29.3	28.2	26.5	25.2	24.3	24.4	25.5	26.6	27.6	28.8	(25)
		MCWB	24.8	25.4	25.0	24.1	22.5	21.4	20.0	20.1	20.4	21.5	22.5	23.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.8	27.5	27.0	25.3	24.9	23.7	24.0	24.4	24.5	25.7	26.4	(27)
		MCDB	29.9	30.7	30.0	29.5	27.1	26.6	24.9	25.3	26.5	27.0	28.4	29.4	(28)
	2%	WB	26.7	27.1	26.7	26.2	24.7	24.0	22.8	22.9	23.4	23.6	24.8	25.8	(29)
		MCDB	29.4	29.8	29.4	28.4	26.4	25.4	24.4	24.7	25.5	26.3	27.3	28.8	(30)
	5%	WB	26.2	26.6	26.3	25.6	24.2	23.4	22.1	22.2	22.6	23.1	24.1	25.3	(31)
		MCDB	28.8	29.2	28.7	27.7	25.9	24.8	23.8	24.1	24.7	25.8	27.0	28.2	(32)
	10%	WB	25.7	26.2	25.9	25.0	23.6	22.6	21.3	21.4	21.8	22.5	23.6	24.9	(33)
		MCDB	28.3	28.7	28.2	27.1	25.6	24.3	23.3	23.6	24.3	25.4	26.5	27.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.1	4.8	4.7	4.9	5.1	5.8	5.9	6.1	5.9	5.6	5.3	(35)
		MCDBR	6.1	6.0	5.8	5.5	5.5	6.0	6.7	6.6	7.1	6.9	6.4	6.3	(36)
	5% WB	MCWBR	2.9	2.7	2.9	2.8	3.0	3.5	3.8	3.7	3.8	3.3	2.9	2.7	(37)
		MCWBR	5.3	5.3	5.3	5.2	4.7	4.8	5.0	5.5	6.0	6.1	5.6	5.6	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.389	0.386	0.384	0.378	0.363	0.356	0.339	0.344	0.358	0.372	0.373	0.379	(40)
		taud	2.590	2.607	2.623	2.616	2.622	2.629	2.651	2.636	2.572	2.553	2.581	2.595	(41)
	Ebn at Noon	Ebn at Noon	956	947	924	891	867	854	883	911	935	949	965	966	(42)
		Edh at Noon	106	102	97	91	84	80	81	88	100	107	106	105	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.74	6.40	5.47	4.68	3.88	3.56	3.86	4.62	5.70	6.42	6.71	6.98	(44)
	RadStd	RadStd	0.53	0.54	0.39	0.42	0.32	0.25	0.27	0.29	0.40	0.38	0.39	0.48	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page