

NOUMEA, New Caledonia

WMO: 915920

Lat: 22.2761S

Lon: 166.4528E

Elev: 71

StdP: 100.47

Time Zone: 11.00 (E11)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.2	16.8	9.7	7.5	19.4	10.5	7.9	19.6	11.2	20.3	10.4	20.7	3.1	40	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.0	31.7	25.0	30.8	24.8	30.0	24.5	26.2	29.7	25.7	29.1	25.3	28.5	5.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.5	28.2	24.8	20.0	27.7	24.4	19.5	27.4	82.2	29.8	80.1	29.2	78.3	28.7	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	10.4	9.6	15.1	33.9	0.6	0.9	14.7	34.5	14.4	35.0	14.0	35.5	13.6	36.2
			12.3	27.0	0.8	0.7	11.7	27.5	11.2	27.9	10.8	28.3	10.2	28.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.5	26.2	26.7	26.0	24.6	22.8	21.4	20.3	20.2	21.4	22.7	23.9	25.6
	DBStd	2.67	1.46	1.45	1.46	1.47	1.37	1.39	1.29	1.39	1.46	1.56	1.51	1.64
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDD10.0	4916	503	467	496	438	396	343	321	317	341	393	417	483
	CDD18.3	1876	245	234	237	188	138	93	63	59	91	135	167	225
	CDH23.3	10839	2049	2124	1858	1019	343	123	51	56	176	479	833	1727
(13)	CDH26.7	2088	464	523	358	124	16	4	2	2	11	56	119	409
(14)	Wind	WSAvg	5.3	5.9	5.5	5.7	5.3	4.8	4.7	4.7	4.8	5.4	5.8	5.5
(15) Precipitation	PrecAvg	1036	104	124	151	115	94	105	74	69	40	46	49	69
	PrecMax	1610	372	406	395	278	242	392	229	227	138	208	194	290
	PrecMin	678	18	15	8	7	12	12	20	10	1	0	1	5
	PrecStd	207	77	74	95	76	52	66	44	37	34	46	39	57
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	33.0	32.2	30.6	28.3	27.3	26.3	26.5	28.0	30.0	31.2	32.7
		MCWB	25.3	25.3	25.8	24.8	22.9	21.9	20.7	20.5	21.3	22.8	23.0	24.2
	2%	DB	31.2	31.6	30.7	29.1	26.8	25.8	24.6	24.9	26.4	28.2	29.2	31.2
		MCWB	24.9	25.5	25.4	24.3	22.4	21.0	19.5	20.0	20.8	21.9	22.7	24.2
	5%	DB	30.1	30.5	29.6	28.1	25.9	24.7	23.6	23.7	25.2	26.9	28.0	30.0
		MCWB	24.7	25.2	25.1	23.8	21.7	20.4	18.8	19.1	20.1	21.3	22.4	23.9
	10%	DB	29.0	29.5	28.6	27.1	25.1	23.8	22.6	22.8	24.2	25.8	26.9	28.9
		MCWB	24.1	24.8	24.6	23.1	21.1	19.8	18.3	18.4	19.5	20.7	21.7	23.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.9	26.7	25.7	24.1	23.1	22.0	21.9	23.1	23.7	24.5	25.6
		MCDB	30.4	30.8	30.3	29.1	26.6	25.6	24.6	24.7	26.4	27.9	28.8	30.0
	2%	WB	26.0	26.2	26.1	24.9	23.3	22.2	20.9	21.0	21.8	22.8	23.7	25.0
		MCDB	29.3	29.8	29.4	28.1	25.5	24.4	23.3	23.4	24.8	26.6	27.5	29.4
	5%	WB	25.4	25.7	25.6	24.3	22.7	21.5	20.0	20.2	21.0	22.1	23.1	24.5
		MCDB	28.5	29.1	28.6	27.0	24.8	23.7	22.4	22.7	24.0	26.0	26.7	28.6
	10%	WB	24.9	25.3	25.1	23.7	22.1	20.7	19.3	19.4	20.3	21.4	22.4	24.0
		MCDB	27.8	28.4	27.9	26.3	24.3	23.1	21.7	22.0	23.2	25.0	25.9	27.8
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.0	4.6	4.4	4.5	4.5	4.7	5.0	5.4	5.5	5.5	5.6
		MCDBR	6.3	6.4	5.8	5.5	5.2	5.5	5.8	5.9	6.5	7.0	7.0	7.2
		MCWBR	2.7	2.7	2.6	2.6	2.7	2.9	2.9	3.1	3.3	3.2	3.3	3.0
	5% WB	MCDBR	5.4	5.5	5.2	4.9	4.5	4.7	4.8	5.1	5.6	6.3	6.2	6.3
		MCWBR	2.7	2.7	2.6	2.6	2.7	2.8	3.0	3.1	3.1	3.1	3.1	3.1
(40) Clear-Sky Solar Irradiance	taub		0.378	0.377	0.375	0.361	0.345	0.340	0.322	0.324	0.343	0.355	0.360	0.367
	taud		2.597	2.615	2.625	2.647	2.650	2.647	2.676	2.678	2.582	2.570	2.577	2.608
	Ebn at Noon		966	954	931	904	880	865	896	928	947	964	977	978
	Edh at Noon		105	101	96	87	80	77	77	83	99	105	106	104
(44) All-Sky Solar Radiation	RadAvg		6.61	6.23	5.33	4.51	3.70	3.34	3.67	4.43	5.65	6.40	6.73	6.90
	RadStd		0.49	0.45	0.40	0.38	0.27	0.23	0.24	0.32	0.31	0.30	0.45	0.48

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page