

ILE MATTHEW, New Caledonia

WMO: 915980

Lat: 22.346S

Lon: 171.358E

Elev: 92

StdP: 14.65

Time Zone: 11.00 (E11)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	63.2	64.2	49.2	51.9	68.0	50.6	54.8	68.2	31.6	69.0	30.1	68.7	15.7	140	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	3.7	85.1	78.2	83.8	77.5	82.8	76.8	79.8	83.5	78.9	82.7	78.2	81.9	7.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.5	148.6	82.5	77.6	144.1	81.7	77.0	141.1	81.2	43.4	83.9	42.5	82.9	41.8	82.1	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.5	28.9	27.1		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.1	77.6	78.5	79.1	77.5	74.0	71.7	70.0	69.4	70.3	71.3	73.8	76.2
	DBStd	4.43	3.16	4.20	2.72	2.40	1.95	2.64	2.45	2.84	2.99	2.77	2.54	2.92
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	6	0	1	0	0	0	1	1	3	0	0	0	0
	CDD50	8790	856	798	901	825	745	650	621	600	610	660	713	811
	CDD65	3323	391	379	436	375	280	201	157	139	160	196	263	346
	CDH74	16543	2962	3405	3811	2491	617	198	52	48	140	225	652	1942
	CDH80	1436	213	469	485	139	6	0	0	0	1	2	13	108
(14) Wind	WSAvg	13.9	12.0	12.6	13.9	13.3	16.0	16.1	14.8	13.1	12.7	14.1	14.1	14.5
(15) Precipitation	PrecAvg	48.4	5.6	5.0	7.0	5.0	4.4	4.3	3.2	2.2	2.7	2.6	2.5	3.8
	PrecMax	75.7	14.8	14.0	19.6	14.7	11.9	7.8	8.2	4.8	8.1	6.4	6.5	13.2
	PrecMin	28.6	0.4	0.7	1.7	1.0	0.2	1.0	0.4	0.2	0.5	0.4	0.3	0.3
	PrecStd	13.1	3.7	3.6	3.5	3.4	3.0	2.1	1.9	1.1	2.0	1.5	1.8	3.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.5	86.8	86.8	84.5	80.7	78.3	76.5	77.1	79.7	79.8	81.5	84.3
		MCWB	78.2	78.2	79.5	78.7	71.8	72.1	70.6	71.3	74.1	71.1	74.3	76.5
	2%	DB	83.1	85.2	85.0	82.7	78.8	77.1	75.4	75.4	77.2	78.0	80.0	82.6
		MCWB	76.7	77.6	78.9	77.6	71.9	71.0	69.8	69.9	71.8	70.1	73.5	75.8
	5%	DB	82.0	83.9	83.7	81.6	77.8	76.1	74.5	74.1	75.7	76.4	78.5	81.2
		MCWB	76.1	77.2	78.0	76.6	71.1	70.1	68.9	68.8	71.0	69.5	73.0	75.2
	10%	DB	81.1	82.6	82.6	80.5	76.7	75.2	73.5	73.0	74.4	75.0	77.2	80.0
		MCWB	75.6	76.5	77.3	75.6	70.2	69.3	67.9	67.7	69.7	68.7	71.2	74.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	79.9	81.0	80.5	74.7	73.4	73.5	72.6	75.4	73.1	77.1	78.4
		MCDB	83.1	84.5	84.8	83.7	77.0	76.1	75.1	75.6	79.1	77.1	79.4	81.4
	2%	WB	78.8	79.0	80.2	78.9	73.7	72.2	71.8	71.6	73.8	72.4	75.8	77.4
		MCDB	82.1	83.5	83.8	82.4	76.6	75.2	74.5	74.7	76.8	76.3	78.8	80.5
	5%	WB	78.0	78.3	79.2	77.5	72.7	71.0	70.3	70.6	72.5	71.5	74.3	76.8
		MCDB	81.5	82.6	82.9	81.1	76.3	74.3	73.5	73.8	75.4	75.4	77.9	80.0
	10%	WB	77.3	77.8	78.2	76.4	71.3	69.9	68.8	69.5	71.4	70.7	72.5	76.1
		MCDB	80.8	81.9	81.9	80.0	75.7	73.3	72.5	72.8	74.4	75.1	76.5	79.4
(35) Mean Daily Temperature Range	5% DB	MDBR	3.8	4.2	3.7	3.7	3.3	3.2	3.4	3.3	3.6	3.6	3.7	4.1
		MCDBR	5.0	5.8	5.2	4.8	4.5	4.4	4.5	4.7	5.3	5.8	5.4	5.7
	5% WB	MCWBR	2.9	2.7	2.9	2.7	3.7	4.2	4.7	3.8	3.5	3.3	3.6	3.2
		MCWBR	5.0	5.4	5.5	4.6	4.4	4.5	5.0	5.1	5.3	5.3	5.3	5.1
(40) Clear-Sky Solar Irradiance	taub	taub	0.381	0.376	0.379	0.367	0.359	0.349	0.331	0.329	0.353	0.359	0.363	0.366
		taud	2.602	2.631	2.627	2.645	2.622	2.635	2.670	2.682	2.575	2.576	2.590	2.627
	Ebn at Noon	Ebn at Noon	305	303	294	285	274	271	281	293	297	305	309	311
		Edh at Noon	33	32	30	28	26	25	25	26	31	33	33	32
(44) All-Sky Solar Radiation	RadAvg	2184	2075	1771	1463	1198	1079	1164	1422	1748	1986	2168	2239	
	RadStd	119	145	104	139	102	72	93	90	121	116	140	141	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page