

ILE MATTHEW, New Caledonia

WMO: 915980

Lat: 22.346S

Lon: 171.358E

Elev: 28

StdP: 100.99

Time Zone: 11.00 (E11)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.3	17.9	9.5	7.4	20.0	10.3	7.8	20.1	14.1	20.6	13.5	20.4	7.0	140	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	2.1	29.5	25.7	28.8	25.3	28.2	24.9	26.5	28.6	26.1	28.2	25.7	27.7	3.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.2	28.0	25.3	20.6	27.6	25.0	20.2	27.3	83.1	28.9	81.1	28.3	79.4	27.8	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	12.9	12.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	25.3	25.8	26.1	25.3	23.3	22.0	21.1	20.8	21.3	21.8	23.2	24.5
	DBStd	2.46	1.76	2.33	1.51	1.33	1.08	1.47	1.36	1.58	1.66	1.54	1.41	1.62
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	3	0	1	0	0	0	1	1	2	0	0	0	0
	CDD10.0	4883	476	443	501	458	414	361	345	333	339	367	396	451
	CDD18.3	1846	217	211	242	208	156	112	87	77	89	109	146	192
	CDH23.3	9191	1646	1892	2117	1384	343	110	29	27	78	125	362	1079
	CDH26.7	798	118	261	269	77	3	0	0	0	1	1	7	60
Wind	WSAvg	6.2	5.4	5.6	6.2	5.9	7.1	7.2	6.6	5.8	5.7	6.3	6.3	6.5
Precipitation	PrecAvg	1229	143	128	178	127	111	108	81	57	68	67	64	96
	PrecMax	1923	376	356	497	374	301	199	209	121	205	162	164	335
	PrecMin	726	10	18	44	25	6	25	9	5	12	9	7	8
	PrecStd	334	93	92	89	87	75	54	47	29	50	39	46	81
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.7	30.4	30.4	29.2	27.1	25.7	24.7	25.1	26.5	26.6	27.5	29.0
		MCWB	25.6	25.7	26.4	25.9	22.1	22.3	21.4	21.8	23.4	21.7	23.5	24.7
	2%	DB	28.4	29.5	29.5	28.2	26.0	25.1	24.1	24.1	25.1	25.5	26.6	28.1
		MCWB	24.9	25.3	26.0	25.3	22.2	21.7	21.0	21.0	22.1	21.1	23.1	24.4
	5%	DB	27.8	28.8	28.7	27.5	25.4	24.5	23.6	23.4	24.3	24.7	25.8	27.3
		MCWB	24.5	25.1	25.5	24.8	21.7	21.2	20.5	20.4	21.7	20.8	22.8	24.0
	10%	DB	27.3	28.1	28.1	27.0	24.8	24.0	23.1	22.8	23.6	23.9	25.1	26.7
		MCWB	24.2	24.7	25.2	24.2	21.2	20.7	19.9	19.8	21.0	20.4	21.8	23.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.6	27.2	26.9	23.7	23.0	23.0	22.6	24.1	22.8	25.1	25.8
		MCDB	28.4	29.2	29.4	28.7	25.0	24.5	24.0	24.2	26.1	25.1	26.3	27.4
	2%	WB	26.0	26.1	26.8	26.0	23.2	22.3	22.1	22.0	23.2	22.4	24.3	25.2
		MCDB	27.9	28.6	28.8	28.0	24.8	24.0	23.6	23.7	24.9	24.6	26.0	26.9
	5%	WB	25.6	25.7	26.2	25.3	22.6	21.7	21.3	21.4	22.5	22.0	23.5	24.9
		MCDB	27.5	28.1	28.3	27.3	24.6	23.5	23.0	23.2	24.1	24.1	25.5	26.6
	10%	WB	25.1	25.4	25.7	24.7	21.8	21.0	20.5	20.8	21.9	21.5	22.5	24.5
		MCDB	27.1	27.7	27.7	26.7	24.3	23.0	22.5	22.7	23.5	24.0	24.7	26.4
Mean Daily Temperature Range	5% DB	MDBR	2.1	2.3	2.1	2.0	1.8	1.8	1.9	1.8	2.0	2.0	2.0	2.3
		MCDBR	2.8	3.2	2.9	2.6	2.5	2.4	2.5	2.6	2.9	3.2	3.0	3.2
		MCWBR	1.6	1.5	1.6	1.5	2.0	2.3	2.6	2.1	1.9	1.8	2.0	1.8
	5% WB	MCDBR	2.8	3.0	3.1	2.6	2.5	2.5	2.8	2.8	3.0	2.9	3.0	2.8
		MCWBR	1.7	1.7	1.7	1.6	2.1	2.5	3.1	2.3	2.1	1.9	2.4	1.7
Clear-Sky Solar Irradiance	taub	0.381	0.376	0.379	0.367	0.359	0.349	0.331	0.329	0.353	0.359	0.363	0.366	
	taud	2.602	2.631	2.627	2.645	2.622	2.635	2.670	2.682	2.575	2.576	2.590	2.627	
	Ebn at Noon	963	955	927	898	864	855	886	923	937	960	974	979	
	Edh at Noon	104	100	96	88	83	79	78	83	99	104	105	102	
All-Sky Solar Radiation	RadAvg	6.88	6.54	5.58	4.61	3.78	3.40	3.67	4.48	5.51	6.26	6.84	7.06	
	RadStd	0.38	0.46	0.33	0.44	0.32	0.23	0.29	0.28	0.38	0.37	0.44	0.44	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page