

TARAWA BETIO, Kiribati

WMO: 916110

Lat: 1.355N

Lon: 172.923E

Elev: 13

StdP: 14.69

Time Zone: 12.00 (E12)

Period: 97-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	76.7	77.7	N/A	N/A	N/A	N/A	N/A	N/A	25.3	80.8	23.3	80.9	11.6	80	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.9	86.4	N/A	86.1	N/A	85.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.5	20.5	18.8	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	81.5	81.4	81.4	81.8	82.1	82.3	82.2	82.5	82.9	82.7	82.6	82.0
	DBStd	1.48	1.56	1.42	1.33	1.24	1.33	1.35	1.26	1.46	1.38	1.48	1.51	1.39
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11724	978	878	973	955	996	968	999	1007	988	1013	977	992
	CDD65	6249	513	458	508	505	531	518	534	542	538	548	527	527
	CDH74	74487	5862	5119	5735	5961	6356	6296	6488	6670	6712	6705	6385	6198
	CDH80	22685	1494	1193	1392	1691	1943	2022	2077	2259	2432	2285	2098	1799
Wind	WSAvg	10.1	12.5	13.6	11.9	11.1	8.8	7.9	7.8	7.3	8.5	10.1	9.9	11.7
Precipitation	PrecAvg	82.4	11.3	9.1	8.5	7.8	7.4	6.5	6.6	6.2	4.4	4.8	4.8	9.1
	PrecMax	151.2	32.4	21.3	19.1	21.6	24.4	16.4	20.0	20.0	14.2	15.8	18.8	20.1
	PrecMin	28.9	0.2	0.3	0.2	0.0	0.1	0.5	0.2	0.2	0.1	0.0	0.0	0.6
	PrecStd	30.2	8.4	5.7	6.0	5.8	5.3	4.6	5.2	5.3	3.7	4.8	5.1	5.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.1	85.5	85.4	85.5	85.5	85.5	85.8	86.4	87.3	87.1	87.1	86.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	85.4	85.2	84.7	85.0	85.2	85.3	85.4	85.6	86.3	86.3	86.3	85.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	85.0	84.6	84.3	84.5	84.7	85.0	85.1	85.3	85.8	85.7	85.7	85.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	84.4	84.1	83.7	84.1	84.4	84.5	84.6	85.0	85.4	85.3	85.2	84.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.7	2.8	3.2	3.3	3.1	3.4	3.7	3.7	3.9	3.5	3.3	3.5
		MCDBR	3.7	3.7	3.9	3.8	3.5	3.7	4.0	4.0	4.6	4.5	4.4	4.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.422	0.424	0.423	0.403	0.389	0.384	0.384	0.380	0.384	0.379	0.389	0.416
	taud		2.502	2.488	2.515	2.587	2.628	2.640	2.644	2.646	2.618	2.631	2.602	2.525
	Ebn at Noon		288	288	286	286	283	281	282	289	293	298	296	288
	Edh at Noon		36	36	35	32	30	29	29	30	31	31	32	34
All-Sky Solar Radiation	RadAvg		1756	1877	1855	1888	1887	1809	1819	1944	2042	2050	1951	1742
	RadStd		266	243	283	196	124	139	131	151	154	168	139	257

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page