

LAUTOKA, Fiji

WMO: 916790

Lat: 17.600S

Lon: 177.450E

Elev: 0

StdP: 101.33

Time Zone: 12.00 (PCF)

Period: 98-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	20.8	N/A	N/A	N/A	N/A	N/A	N/A	8.7	26.3	7.8	25.9	1.6	130	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	4.6	31.0	N/A	30.5	N/A	30.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.1	6.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.1	27.4	27.5	27.5	27.1	26.0	25.2	24.2	24.3	25.0	25.6	26.4	27.0		
	DBStd	1.55	0.96	0.92	0.76	0.83	1.00	1.09	1.09	1.19	1.16	1.11	0.87	0.93		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	5867	539	489	542	512	496	456	439	442	450	482	492	527		
	CDD18.3	2826	281	256	284	262	238	206	181	183	200	224	242	269		
	CDH23.3	25353	3049	2732	3061	2675	2035	1479	978	1051	1420	1819	2285	2769		
	CDH26.7	5269	879	768	855	671	351	158	40	52	134	226	441	695		
Wind	WSAvg	2.2	2.7	2.5	2.6	2.1	1.9	2.0	2.1	2.1	2.1	2.2	2.2	2.4		
Precipitation	PrecAvg	1947	356	297	311	176	91	68	57	80	81	87	132	210		
	PrecMax	3489	1131	659	664	496	318	306	183	260	220	276	316	536		
	PrecMin	958	83	34	91	36	0	4	4	1	3	11	5	27		
	PrecStd	636	258	162	153	111	81	68	39	69	60	64	77	120		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	32.0	31.3	31.5	30.2	29.5	28.2	28.6	29.5	29.7	30.3	31.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	30.7	30.8	30.6	30.4	29.4	28.7	27.6	27.7	28.6	29.0	29.5	30.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	30.1	30.2	30.1	29.8	28.9	28.1	27.1	27.2	28.0	28.4	29.0	29.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	29.7	29.7	29.7	29.3	28.5	27.6	26.6	26.8	27.4	27.9	28.6	29.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.7	4.6	4.9	4.9	4.7	4.9	4.7	4.7	4.5	4.7	4.7		
		MCDBR	5.1	5.3	5.0	5.4	5.2	5.1	5.0	5.1	5.2	5.0	5.0	5.1		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Clear-Sky Solar Irradiance	taub		0.389	0.386	0.378	0.376	0.366	0.365	0.358	0.361	0.374	0.380	0.381	0.381		
	taud		2.593	2.609	2.649	2.642	2.643	2.627	2.632	2.631	2.580	2.578	2.599	2.614		
	Ebn at Noon		955	948	935	900	874	856	873	902	923	942	957	963		
	Edh at Noon		105	102	95	90	84	83	84	90	101	104	104	103		
All-Sky Solar Radiation	RadAvg		6.14	5.79	5.37	4.76	4.26	3.99	4.18	4.66	5.35	5.84	6.14	6.22		
	RadStd		0.65	0.50	0.40	0.36	0.32	0.22	0.22	0.42	0.39	0.38	0.54	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.18	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+67	+66

Nomenclature: See separate page