

NADI, Fiji

WMO: 916800

Lat: 17.755S

Lon: 177.443E

Elev: 18

StdP: 101.11

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 16.8	(c) 17.9	(d) 13.1	(e) 9.4	(f) 21.1	(g) 14.1	(h) 10.0	(i) 21.4	(j) 8.4	(k) 26.1	(l) 7.8	(m) 26.0	(n) 2.2	(o) 120	(p) 0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 7.2	(c) 32.2	(d) 25.6	(e) 31.9	(f) 25.6	(g) 31.2	(h) 25.5	(i) 27.1	(j) 30.6	(k) 26.7	(l) 30.1	(m) 26.4	(n) 29.8	(o) 5.0	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.0	25.9	21.3	28.8	25.4	20.6	28.2	85.9	30.8	84.1	30.5	82.8	30.0	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.2	(b) 7.2	(c) 6.4	(e) 14.7	(f) 34.3	(g) 1.0	(h) 1.2	(i) 13.9	(j) 35.1	(k) 13.3	(l) 35.8	(m) 12.8	(n) 36.5	(o) 12.0	(p) 37.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.8	27.3	27.3	27.2	26.6	25.3	24.5	23.7	23.8	24.7	25.5	26.4	27.0		
	DBStd	1.78	0.96	0.95	0.84	0.91	1.25	1.48	1.44	1.48	1.49	1.33	1.01	0.97		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	5753	536	484	534	499	474	434	425	428	441	481	492	527		
	CDD18.3	2712	277	251	276	249	216	184	167	170	191	223	242	268		
	CDH23.3	22954	2762	2439	2602	2176	1617	1240	1043	1078	1366	1822	2181	2627		
	CDH26.7	7015	972	849	894	708	438	289	192	207	324	508	707	925		
(14) Wind	WSAvg	2.9	2.9	2.8	2.6	2.5	2.6	2.7	2.9	3.0	3.1	3.2	3.1	3.0		
(15) Precipitation	PrecAvg	1853	334	324	329	177	86	61	48	65	79	94	134	191		
	PrecMax	3289	1181	788	918	580	331	312	190	256	327	342	461	562		
	PrecMin	864	13	46	75	22	1	0	0	0	1	2	7	26		
	PrecStd	488	226	176	172	123	78	63	47	61	70	81	85	121		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	33.1	32.8	32.2	31.2	31.0	30.4	30.8	31.7	32.0	32.3	33.0		
		MCWB	26.0	26.4	26.4	25.7	25.0	24.6	23.7	23.5	23.8	24.2	24.9	25.5		
	2%	DB	32.0	32.1	31.9	31.2	30.2	30.0	29.2	29.4	30.1	30.8	31.2	31.9		
		MCWB	25.8	26.1	26.1	25.6	24.6	24.2	23.2	23.0	23.5	24.0	24.7	25.2		
	5%	DB	31.2	31.2	31.1	30.8	29.8	29.1	28.4	28.8	29.2	30.0	30.4	31.1		
		MCWB	25.8	26.0	26.0	25.5	24.4	23.9	22.8	22.8	23.3	23.9	24.6	25.2		
	10%	DB	30.8	30.8	30.8	30.1	29.0	28.3	27.9	27.9	28.5	29.2	29.9	30.3		
		MCWB	25.7	25.9	25.9	25.2	23.9	23.3	22.5	22.4	22.9	23.5	24.5	25.0		
	0.4%	WB	27.4	27.6	27.6	27.1	26.2	25.9	25.2	25.1	25.5	26.0	26.6	27.0		
		MCDB	30.9	31.1	30.8	30.4	29.6	29.3	28.3	28.7	29.1	29.5	30.4	30.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.8	27.0	27.0	26.5	25.7	25.2	24.5	24.3	24.7	25.4	25.9	26.4		
		MCDB	30.4	30.6	30.3	29.8	29.0	28.5	27.7	27.8	28.4	28.9	29.5	30.0		
	5%	WB	26.4	26.6	26.6	26.1	25.3	24.7	24.0	23.7	24.2	24.8	25.5	26.1		
		MCDB	29.9	30.0	29.8	29.4	28.5	27.9	27.2	27.1	27.9	28.4	29.1	29.6		
	10%	WB	26.1	26.2	26.2	25.7	24.7	24.1	23.4	23.2	23.7	24.4	25.0	25.7		
		MCDB	29.4	29.4	29.4	28.9	27.8	27.3	26.6	26.5	27.3	27.9	28.7	29.2		
	5% DB	MDBR	7.2	7.3	7.3	7.5	8.0	8.3	8.7	8.4	8.2	7.9	7.7	7.6		
		MCDBR	8.0	8.1	8.0	8.3	8.5	8.8	9.1	9.2	8.9	8.7	8.3	8.3		
		MCWBR	3.6	3.7	3.7	3.9	4.1	4.3	4.5	4.4	4.2	4.0	3.9	3.7		
		MCWBR	7.3	7.3	7.4	7.4	7.5	7.9	8.0	8.0	8.0	7.5	7.4	7.4		
(35) Mean Daily Temperature Range	5% WB	MCWBR	3.6	3.6	3.7	3.8	4.0	4.3	4.4	4.3	4.2	3.9	3.8	3.7		
		MCWBR	3.6	3.6	3.7	3.8	4.0	4.3	4.4	4.3	4.2	3.9	3.8	3.7		
	Clear-Sky Solar Irradiance	taub	0.389	0.386	0.378	0.375	0.364	0.363	0.357	0.359	0.373	0.380	0.380	0.380		
		taud	2.589	2.606	2.643	2.637	2.645	2.628	2.633	2.632	2.575	2.574	2.595	2.611		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	956	949	934	900	876	858	875	904	924	943	957	964		
		Edh at Noon	106	103	96	91	84	83	84	90	101	105	104	103		
(44) All-Sky Solar Radiation	RadStd	RadAvg	6.18	5.85	5.40	4.75	4.23	3.93	4.13	4.61	5.33	5.83	6.14	6.25		
		RadStd	0.64	0.49	0.39	0.35	0.32	0.23	0.22	0.42	0.40	0.39	0.55	0.31		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.20	+0.23	N/A	N/A	+60	+60
(47) Regional (7 neighbors)		+0.18	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+67	+66

Nomenclature: See separate page