

NAUSORI, Fiji

WMO: 916830

Lat: 18.043S

Lon: 178.559E

Elev: 17

StdP: 14.69

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	62.7	64.6	57.1	69.6	71.2	58.9	74.2	71.3	20.0	76.1	18.4	76.7	0.9	300	0.281

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.2	89.5	79.3	88.2	79.1	87.6	79.0	80.9	86.4	80.1	85.6	79.7	85.0	9.3	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.6	83.4	78.9	150.2	83.1	78.5	147.8	82.7	44.7	86.9	43.9	86.3	43.3	85.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	16.1	14.1	DB	59.7	91.9	1.8	1.5	58.4	93.0	57.4	93.8	56.4	94.7	55.1	95.8	(4)
(5)			WB	58.5	82.6	1.6	1.1	57.4	83.4	56.4	84.0	55.5	84.6	54.4	85.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.3	80.5	80.8	80.8	79.3	76.6	75.1	73.6	73.5	74.7	76.1	77.9	79.4
	DBStd	3.51	1.80	1.84	1.64	1.91	2.46	2.54	2.57	2.64	2.70	2.63	2.20	2.04
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9981	947	862	953	880	825	753	733	729	740	808	838	913
	CDD65	4506	482	442	488	430	360	303	268	264	290	343	388	448
	CDH74	32778	4487	4159	4509	3555	2269	1533	1066	1014	1363	2041	2850	3932
CDH80	7519	1328	1304	1375	875	352	173	82	82	139	274	550	985	
Wind	WSAvg	4.9	4.6	4.3	3.9	4.3	4.5	4.5	4.8	5.2	5.7	5.8	5.4	5.6
Precipitation	PrecAvg	113.1	13.4	11.3	14.7	12.7	8.9	5.7	4.9	5.3	6.8	9.4	9.6	12.4
	PrecMax	153.9	25.7	23.1	31.5	37.2	19.5	15.2	11.2	15.3	19.4	23.1	25.4	36.4
	PrecMin	75.7	1.6	4.0	4.4	4.1	1.5	0.7	1.1	0.8	0.5	1.3	1.1	2.8
	PrecStd	17.0	6.1	4.5	6.0	6.2	4.7	4.0	2.4	3.8	4.0	6.0	6.0	7.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	90.9	89.9	89.2	86.3	85.5	84.1	84.2	85.0	86.3	88.0	89.4
		MCWB	79.4	80.6	79.7	79.3	78.1	77.0	75.6	75.8	76.1	77.4	78.4	78.9
	2%	DB	88.9	89.5	88.8	87.7	84.6	83.6	82.2	82.3	83.3	84.4	86.2	87.8
		MCWB	79.2	79.4	79.4	78.9	76.8	75.9	74.5	74.4	75.3	76.1	77.3	78.7
	5%	DB	87.7	88.0	87.8	86.2	83.7	82.2	80.6	80.6	81.6	82.7	84.6	86.2
		MCWB	79.1	79.2	79.3	78.3	76.1	75.2	73.5	73.2	74.3	75.2	76.6	78.0
	10%	DB	86.2	86.4	86.3	84.6	82.2	80.6	79.0	78.9	80.0	81.2	83.0	84.6
		MCWB	78.2	78.6	78.6	77.5	75.2	74.1	72.5	72.4	73.4	74.3	75.8	77.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	81.9	81.6	80.8	79.5	78.8	77.5	77.3	78.1	78.9	79.8	80.4
		MCDB	86.9	87.4	86.5	86.1	83.9	82.9	81.4	81.7	82.4	83.8	84.8	86.0
	2%	WB	80.4	80.8	80.6	79.9	78.4	77.6	76.2	75.9	76.8	77.8	78.8	79.6
		MCDB	86.0	86.5	86.3	85.1	82.6	81.4	80.0	79.9	80.9	82.3	83.8	84.9
	5%	WB	79.7	80.0	79.9	79.2	77.7	76.5	75.1	74.8	75.9	76.9	78.0	79.0
		MCDB	85.0	85.5	85.3	84.2	81.6	80.1	78.5	78.5	79.6	81.0	82.7	84.1
	10%	WB	79.1	79.3	79.3	78.5	76.7	75.7	74.2	74.0	74.9	76.1	77.2	78.3
		MCDB	84.0	84.4	84.3	83.2	80.4	79.0	77.5	77.6	78.4	79.8	81.5	83.1
Mean Daily Temperature Range	5% DB	MDBR	11.6	12.2	12.0	11.1	11.1	10.8	10.8	10.4	10.0	10.3	10.7	11.1
		MCDBR	13.8	14.0	13.7	13.3	12.7	12.9	12.9	13.0	12.3	12.2	13.1	13.0
		MCWBR	5.8	5.9	5.8	5.9	6.0	6.4	6.3	6.4	5.9	5.5	5.9	5.6
	5% WB	MCDBR	12.2	12.8	12.5	12.0	11.2	11.0	10.8	10.8	10.9	10.9	11.9	11.7
		MCWBR	5.7	5.9	5.8	5.9	5.9	6.1	6.0	6.0	5.9	5.4	5.8	5.6
Clear-Sky Solar Irradiance	taub	0.383	0.382	0.379	0.377	0.374	0.373	0.363	0.367	0.383	0.384	0.384	0.384	0.384
	taud	2.615	2.625	2.643	2.637	2.613	2.603	2.617	2.608	2.551	2.566	2.588	2.602	
	Ebn at Noon	305	302	296	285	274	269	275	284	290	298	303	305	
	Edh at Noon	33	32	30	29	28	27	27	29	33	34	33	33	
All-Sky Solar Radiation	RadAvg	1927	1835	1691	1435	1266	1128	1204	1345	1560	1745	1850	1879	
	RadStd	194	143	111	110	88	84	61	133	135	143	181	115	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.38	N/A	N/A	N/A	N/A	+0.45	N/A	N/A	+153	+153
(47)	Regional (7 neighbors)	+0.32	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+121	+119

Nomenclature: See separate page