

SUVA, Fiji

WMO: 916890

Lat: 18.133S

Lon: 178.433E

Elev: 0

StdP: 14.70

Time Zone: 12.00 (PCF)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	67.0	68.2	N/A	N/A	N/A	N/A	N/A	N/A	19.6	72.5	17.5	73.2	3.8	20	0.291

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	8.5	87.4	N/A	86.5	N/A	85.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.6	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.8	17.3	14.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.6	80.4	81.0	81.2	79.9	77.5	75.9	74.0	74.0	75.0	76.0	77.5	79.3
	DBStd	3.30	1.82	1.67	1.62	1.79	1.90	2.43	2.45	2.43	2.59	2.40	1.95	1.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10082	942	867	966	898	851	777	745	743	751	807	826	909
	CDD65	4607	477	447	501	448	386	327	280	278	301	342	376	444
	CDH74	34336	4635	4519	5024	4094	2695	1724	996	908	1288	1881	2615	3957
	CDH80	5523	993	1140	1232	743	222	78	39	29	64	116	231	636
Wind	WSAvg	6.1	7.2	5.6	5.1	5.8	5.5	5.9	5.4	5.6	5.9	6.9	7.0	7.6
Precipitation	PrecAvg	112.8	13.5	11.1	12.9	12.2	8.9	6.1	5.2	6.2	7.0	8.7	9.0	12.1
	PrecMax	144.5	28.2	21.2	22.3	20.7	15.0	13.7	9.8	14.9	16.5	17.9	23.1	30.3
	PrecMin	74.4	3.9	4.3	5.3	3.7	3.8	1.7	2.0	1.5	1.6	2.1	3.3	4.3
	PrecStd	15.9	6.0	4.1	4.5	4.6	3.3	3.6	1.8	3.5	3.7	4.5	4.6	5.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.1	88.4	88.3	87.7	85.1	83.9	83.1	82.8	84.1	84.6	85.7	87.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	86.6	87.3	87.1	86.2	83.4	81.9	81.0	80.6	81.9	82.6	83.7	85.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	85.3	86.2	86.1	85.0	82.3	80.8	79.4	79.1	80.2	81.1	82.4	84.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	84.2	85.1	85.1	83.7	81.1	79.7	78.2	78.0	78.9	80.0	81.2	83.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.4	8.5	7.5	7.2	6.3	7.2	6.5	6.5	6.9	7.1	7.5
		MCDBR	9.0	9.3	9.5	9.0	8.2	7.4	8.6	8.2	8.0	8.5	9.2	8.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.383	0.383	0.379	0.377	0.373	0.373	0.363	0.367	0.382	0.384	0.384	0.384
	taud		2.617	2.622	2.642	2.639	2.613	2.600	2.614	2.607	2.550	2.563	2.587	2.602
	Ebn at Noon		305	302	296	285	274	268	275	284	290	298	303	305
	Edh at Noon		33	32	30	29	28	27	27	29	33	34	33	33
All-Sky Solar Radiation	RadAvg		1933	1842	1695	1437	1264	1128	1203	1344	1562	1747	1854	1890
	RadStd		193	142	110	109	88	84	62	133	138	141	180	115

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	+0.32	N/A	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+121	+119

Nomenclature: See separate page