

SUVA, Fiji

WMO: 916890

Lat: 18.133S

Lon: 178.433E

Elev: 0

StdP: 101.33

Time Zone: 12.00 (PCF)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.4	20.1	N/A	N/A	N/A	N/A	N/A	N/A	8.8	22.5	7.8	22.9	1.7	20	0.291

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	4.7	30.8	N/A	30.3	N/A	29.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.2	7.7	6.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.3	26.9	27.2	27.3	26.6	25.3	24.4	23.4	23.3	23.9	24.5	25.3	26.3
	DBStd	1.84	1.01	0.93	0.90	1.00	1.05	1.35	1.36	1.35	1.44	1.33	1.08	1.00
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5601	523	482	537	499	473	432	414	413	417	448	459	505
	CDD18.3	2559	265	248	278	249	214	182	156	154	167	190	209	247
	CDH23.3	19076	2575	2511	2791	2274	1497	958	553	504	716	1045	1453	2198
CDH26.7	3068	552	633	684	413	123	43	22	16	36	64	128	353	
Wind	WSAvg	2.7	3.2	2.5	2.3	2.6	2.5	2.6	2.4	2.5	2.6	3.1	3.1	3.4
Precipitation	PrecAvg	2866	343	283	327	310	225	156	131	157	177	222	228	307
	PrecMax	3670	717	538	566	527	382	348	248	378	420	454	588	770
	PrecMin	1889	99	109	134	93	96	42	51	39	40	54	83	110
	PrecStd	404	152	104	115	116	83	92	46	90	95	114	116	150
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.3	31.3	30.9	29.5	28.8	28.4	28.2	28.9	29.2	29.8	30.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	30.3	30.7	30.6	30.1	28.6	27.7	27.2	27.0	27.7	28.1	28.7	29.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	29.6	30.1	30.0	29.4	27.9	27.1	26.3	26.2	26.8	27.3	28.0	29.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	29.0	29.5	29.5	28.7	27.3	26.5	25.6	25.6	26.1	26.7	27.3	28.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.7	4.7	4.2	4.0	3.5	4.0	3.6	3.6	3.8	4.0	4.2
		MCDBR	5.0	5.2	5.3	5.0	4.6	4.1	4.8	4.6	4.5	4.7	5.1	4.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.383	0.383	0.379	0.377	0.373	0.373	0.363	0.367	0.382	0.384	0.384	0.384	
	taud	2.617	2.622	2.642	2.639	2.613	2.600	2.614	2.607	2.550	2.563	2.587	2.602	
	Ebn at Noon	962	951	933	898	865	846	867	895	915	939	954	960	
	Edh at Noon	103	101	96	90	87	85	85	92	103	106	105	104	
All-Sky Solar Radiation	RadAvg	6.09	5.81	5.34	4.53	3.99	3.56	3.79	4.24	4.92	5.51	5.84	5.96	
	RadStd	0.61	0.45	0.35	0.34	0.28	0.26	0.20	0.42	0.43	0.44	0.57	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	+0.18	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+67	+66

Nomenclature: See separate page