

LAKEBA, Fiji

WMO: 916910

Lat: 18.233S

Lon: 178.800W

Elev: 10

StdP: 14.69

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	66.0	68.2	56.9	69.1	71.9	58.6	73.6	72.5	20.1	71.6	17.8	73.8	3.1	30	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.0	88.2	80.6	87.3	80.2	86.5	79.7	83.0	85.9	82.2	85.3	81.5	84.7	6.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.2	167.7	85.0	81.3	162.9	84.3	80.5	158.5	83.6	47.0	86.1	46.1	85.4	45.3	84.8	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	14.5	12.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.4	81.0	81.7	81.2	80.3	77.7	76.5	74.9	75.1	76.2	77.1	78.9	80.3		
	DBStd	3.14	1.89	1.87	1.67	1.71	2.70	2.01	2.15	2.39	2.07	2.41	1.91	1.82		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	1	0	0	0	0	1	0	0	0	0	0	0	0		
	CDD50	10364	961	888	967	908	859	794	773	778	787	842	866	941		
	CDD65	4889	496	468	502	458	394	344	308	313	337	377	416	476		
	CDH74	40322	5193	5143	5381	4440	3028	2014	1277	1357	1786	2484	3494	4725		
(13)	CDH80	8071	1449	1653	1609	937	301	93	40	46	91	230	521	1101		
(14)	Wind	WSAvg	5.6	5.9	4.7	5.0	5.4	5.6	5.7	6.4	6.3	5.9	5.6	5.3		
(15) Precipitation	PrecAvg	61.1	7.8	6.9	7.6	7.0	4.6	4.3	2.9	2.7	3.3	4.0	4.4	5.9		
	PrecMax	87.8	15.6	17.4	20.6	19.4	12.4	11.2	6.3	5.6	7.3	7.5	9.1	12.2		
	PrecMin	34.1	0.8	1.1	0.7	0.6	0.9	0.1	0.1	0.4	0.4	0.2	1.1	0.9		
	PrecStd	15.7	4.1	4.0	4.1	4.4	2.8	2.9	1.6	1.4	1.9	2.0	2.4	2.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.7	90.0	88.8	87.8	85.4	84.2	82.8	82.7	84.1	84.8	86.5	88.1		
		MCWB	80.4	81.6	81.2	80.7	79.9	78.6	76.8	76.9	78.4	77.1	79.4	79.4		
	2%	DB	87.4	88.5	87.5	86.4	83.8	82.1	81.0	81.3	82.1	83.7	85.2	86.8		
		MCWB	80.2	81.0	80.6	79.6	78.5	76.1	75.3	75.9	76.7	76.6	78.7	79.0		
	5%	DB	86.4	87.4	86.7	85.3	82.7	81.0	80.0	80.1	80.9	82.6	83.9	85.7		
		MCWB	79.6	80.5	80.1	78.8	77.1	75.5	74.6	75.0	75.6	75.9	77.5	78.5		
	10%	DB	85.5	86.4	85.9	84.3	81.7	80.1	78.8	79.0	79.8	81.3	82.9	84.7		
		MCWB	79.1	79.8	79.6	78.1	76.2	74.9	74.1	74.7	75.1	76.5	77.7	77.7		
	0.4%	WB	83.5	84.4	83.9	83.5	82.1	80.6	79.1	78.7	79.3	79.0	81.5	82.0		
		MCDB	86.2	87.0	86.3	86.2	83.6	82.0	80.6	81.2	81.6	81.7	84.4	84.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	82.4	82.9	82.7	81.7	80.4	78.5	77.8	77.5	78.2	78.1	80.2	81.0		
		MCDB	85.3	86.5	85.6	84.2	82.5	80.2	79.4	79.7	80.7	81.2	83.0	84.1		
	5%	WB	81.4	81.9	81.8	80.6	79.3	77.3	76.5	76.5	77.2	77.3	79.2	80.2		
		MCDB	84.8	85.8	85.0	83.2	81.3	79.6	78.4	78.7	79.6	80.6	82.2	83.7		
	10%	WB	80.2	81.1	80.9	79.5	78.2	76.3	75.3	75.4	76.4	76.5	78.2	79.4		
		MCDB	84.0	85.0	84.3	82.5	80.4	78.9	77.7	77.9	78.7	79.9	81.4	83.1		
	5% DB	MDBR	8.5	9.0	8.9	7.7	7.3	6.8	6.9	6.9	6.7	7.0	7.5	8.0		
		MCDBR	9.6	10.4	9.9	9.3	8.4	8.3	8.5	8.0	8.1	8.5	8.5	9.4		
		MCWBR	4.7	4.8	5.1	4.8	4.8	4.9	4.7	4.5	4.5	4.5	4.2	4.4		
		MCWBR	9.4	9.6	9.4	8.7	7.3	7.2	7.5	7.6	7.7	7.2	8.2	8.3		
(40) Clear-Sky Solar Irradiance	taub		0.387	0.383	0.379	0.397	0.386	0.387	0.376	0.382	0.397	0.388	0.385	0.389		
		taud	2.618	2.640	2.659	2.590	2.603	2.583	2.599	2.585	2.539	2.567	2.598	2.598		
	Ebn at Noon		304	302	296	279	270	264	271	279	285	297	302	303		
		Edh at Noon	33	31	30	30	28	27	28	30	33	34	33	33		
(44) All-Sky Solar Radiation	RadAvg		2030	1932	1784	1529	1339	1192	1283	1463	1691	1876	1978	2005		
	RadStd		187	164	126	129	96	90	66	143	124	142	149	123		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page