

LAKEBA, Fiji

WMO: 916910

Lat: 18.233S

Lon: 178.800W

Elev: 3

StdP: 101.29

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	20.1	13.8	9.9	22.2	14.8	10.5	22.5	9.0	22.0	8.0	23.2	1.4	30	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.0	31.2	27.0	30.7	26.8	30.3	26.5	28.3	29.9	27.9	29.6	27.5	29.3	2.7	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	24.0	29.4	27.4	23.3	29.0	27.0	22.6	28.7	91.5	30.0	89.4	29.7	87.4	29.4	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.5	5.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.8	27.2	27.6	27.3	26.8	25.4	24.7	23.8	23.9	24.6	25.1	26.0	26.9		
	DBStd	1.74	1.05	1.04	0.93	0.95	1.50	1.11	1.20	1.33	1.15	1.34	1.06	1.01		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	1	0	0	0	0	1	0	0	0	0	0	0	0		
	CDD10.0	5758	534	493	537	504	477	441	429	432	437	468	481	523		
	CDD18.3	2716	276	260	279	254	219	191	171	174	187	209	231	264		
	CDH23.3	22401	2885	2857	2989	2467	1682	1119	709	754	992	1380	1941	2625		
	CDH26.7	4484	805	918	894	521	167	52	22	26	51	128	289	612		
(14) Wind	WSAvg	2.5	2.6	2.1	2.3	2.4	2.5	2.5	2.8	2.8	2.7	2.6	2.5	2.4		
(15) Precipitation	PrecAvg	1553	199	174	192	177	118	108	74	68	83	101	111	149		
	PrecMax	2229	397	443	522	492	315	285	161	141	186	191	231	310		
	PrecMin	865	20	27	17	14	22	3	3	9	9	5	29	22		
	PrecStd	398	103	101	104	111	71	74	40	36	47	51	61	70		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.5	32.2	31.5	31.0	29.7	29.0	28.2	28.2	28.9	29.4	30.3	31.2		
		MCWB	26.9	27.6	27.3	27.1	26.6	25.9	24.9	24.9	25.8	25.1	26.4	26.3		
	2%	DB	30.8	31.4	30.9	30.2	28.8	27.9	27.2	27.4	27.8	28.7	29.5	30.5		
		MCWB	26.8	27.2	27.0	26.5	25.8	24.5	24.0	24.4	24.8	24.8	25.9	26.1		
	5%	DB	30.2	30.8	30.4	29.6	28.2	27.2	26.7	26.7	27.2	28.1	28.8	29.8		
		MCWB	26.5	26.9	26.7	26.0	25.0	24.2	23.7	23.9	24.2	24.4	25.3	25.8		
	10%	DB	29.7	30.2	29.9	29.0	27.6	26.7	26.0	26.1	26.6	27.4	28.3	29.3		
		MCWB	26.1	26.6	26.4	25.6	24.5	23.9	23.4	23.4	23.7	23.9	24.7	25.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.6	29.1	28.8	28.6	27.8	27.0	26.2	25.9	26.3	26.1	27.5	27.8		
		MCDB	30.1	30.6	30.2	30.1	28.7	27.8	27.0	27.3	27.6	27.6	29.1	29.2		
	2%	WB	28.0	28.3	28.2	27.6	26.9	25.8	25.4	25.3	25.7	25.6	26.8	27.2		
		MCDB	29.6	30.3	29.8	29.0	28.1	26.8	26.3	26.5	27.1	27.3	28.3	29.0		
	5%	WB	27.4	27.7	27.7	27.0	26.3	25.2	24.7	24.7	25.1	25.2	26.2	26.8		
		MCDB	29.3	29.9	29.4	28.4	27.4	26.4	25.8	26.0	26.5	27.0	27.9	28.7		
	10%	WB	26.8	27.3	27.2	26.4	25.7	24.6	24.1	24.1	24.7	24.7	25.7	26.3		
		MCDB	28.9	29.4	29.1	28.1	26.9	26.1	25.4	25.5	26.0	26.6	27.4	28.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.0	5.0	4.3	4.0	3.8	3.8	3.8	3.7	3.9	4.2	4.5		
		MCDBR	5.3	5.8	5.5	5.2	4.7	4.6	4.7	4.4	4.5	4.7	4.7	5.2		
	5% WB	MCWBR	2.6	2.7	2.9	2.7	2.7	2.7	2.7	2.6	2.5	2.5	2.3	2.4		
		MCWBR	5.2	5.4	5.2	4.8	4.1	4.0	4.2	4.2	4.3	4.0	4.5	4.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.387	0.383	0.379	0.397	0.386	0.387	0.376	0.382	0.397	0.388	0.385	0.389		
		taud	2.618	2.640	2.659	2.590	2.603	2.583	2.599	2.585	2.539	2.567	2.598	2.598		
	Ebn at Noon	Ebn at Noon	957	951	933	878	852	832	853	880	900	935	953	956		
		Edh at Noon	103	99	94	95	88	86	87	94	105	106	104	105		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.40	6.09	5.62	4.82	4.22	3.76	4.04	4.61	5.33	5.91	6.24	6.32		
	RadStd	RadStd	0.59	0.52	0.40	0.41	0.30	0.28	0.21	0.45	0.39	0.45	0.47	0.39		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page