

ONO-I-LAU, Fiji

WMO: 916990

Lat: 20.667S

Lon: 178.717W

Elev: 92

StdP: 14.65

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	66.5	67.6	52.4	58.6	70.4	54.4	63.1	70.6	24.0	69.7	22.7	70.1	10.2	150	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.2	87.8	80.4	86.7	79.6	85.8	78.9	82.4	85.7	81.3	84.8	80.4	84.1	8.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.5	164.5	84.4	80.2	157.2	83.6	79.3	152.3	82.8	46.3	85.6	45.1	84.8	44.2	84.3	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
23.1	21.0	19.2	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	57.6	83.2	1.4	2.3	56.5	84.9	55.7	86.3	54.9	87.6	53.9	89.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	77.2	81.0	81.6	81.1	79.7	76.8	74.3	72.9	73.8	75.3	77.4	79.5
		DBStd	3.85	1.85	1.99	2.02	2.38	2.20	2.15	2.27	2.51	2.42	2.26	1.99
		HDD50	0	0	0	0	0	0	0	0	0	0	0	0
		HDD65	0	0	0	0	0	0	0	0	0	0	0	0
		CDD50	9915	960	885	965	890	832	728	711	713	785	821	914
		CDD65	4440	495	465	500	440	367	278	246	246	263	320	449
		CDH74	30359	4954	4865	5114	3875	1989	736	434	474	658	1240	2253
		CDH80	5269	1122	1276	1173	629	116	18	8	11	26	64	216
(14)	Wind	WSAvg	10.1	10.0	9.1	9.1	10.1	9.4	9.6	10.2	10.7	11.0	11.1	9.8
(15)	Precipitation	PrecAvg	68.8	7.4	7.4	10.4	8.3	4.6	3.8	3.5	4.4	4.6	4.2	4.0
(16)		PrecMax	149.4	23.3	29.6	64.6	23.4	15.0	14.8	8.7	11.6	14.7	13.0	20.6
(17)		PrecMin	32.5	0.6	0.9	1.2	1.0	0.4	0.1	0.5	0.2	0.0	0.4	0.4
(18)		PrecStd	22.3	4.4	5.6	9.9	5.5	3.4	3.2	2.1	3.1	3.4	3.1	4.1
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	88.9	89.4	88.2	87.7	84.5	82.0	81.1	81.5	82.6	83.3	84.9	87.9
(20)		0.4% MCWB	79.9	82.2	81.3	79.7	77.4	76.7	74.6	76.0	76.7	76.5	77.9	78.7
(21)		2% DB	87.1	87.9	86.8	86.1	82.4	79.8	79.1	79.5	80.4	81.7	83.6	86.0
(22)		2% MCWB	79.5	81.1	80.4	79.1	76.1	74.2	73.3	74.0	74.8	75.1	76.7	77.9
(23)		5% DB	85.9	86.7	85.8	84.6	81.2	78.5	77.7	77.9	78.7	80.6	82.4	84.6
(24)		5% MCWB	78.7	79.9	79.7	78.0	74.9	73.0	72.2	72.2	72.9	74.0	75.5	77.3
(25)		10% DB	84.8	85.5	84.8	83.4	80.1	77.3	76.3	76.5	77.3	79.2	81.2	83.3
(26)		10% MCWB	77.6	78.8	78.9	77.2	74.1	72.2	71.2	70.8	71.7	72.8	74.4	76.4
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	82.3	85.5	84.5	82.8	79.6	78.2	77.0	77.3	77.7	78.1	80.5	81.1
(28)		0.4% MCDB	86.1	87.4	86.3	85.9	82.4	81.1	79.0	80.2	80.4	81.7	83.0	85.3
(29)		2% WB	81.1	82.7	82.0	80.6	78.1	76.4	75.1	75.5	76.1	76.8	78.8	79.9
(30)		2% MCDB	85.0	86.1	84.8	83.6	80.7	78.3	77.3	77.9	78.9	80.4	81.2	83.8
(31)		5% WB	80.1	81.3	80.9	79.6	77.0	75.0	73.7	74.2	74.9	75.7	77.7	79.0
(32)		5% MCDB	84.2	85.0	84.4	82.7	79.6	77.2	76.5	76.4	77.7	78.8	80.6	82.6
(33)		10% WB	79.3	80.3	79.9	78.6	75.8	73.7	72.5	72.8	73.5	74.6	76.6	78.2
(34)		10% MCDB	83.3	84.0	83.5	81.9	78.9	76.3	75.6	75.2	76.2	77.6	79.8	81.7
(35)	Mean Daily Temperature Range	MDBR	7.1	7.2	6.7	6.4	5.8	5.4	5.9	6.1	6.2	6.6	6.8	6.8
(36)		5% DB MCDBR	8.5	8.4	7.6	7.8	6.9	6.6	7.4	7.1	7.6	8.0	7.9	8.3
(37)		5% WB MCWBR	4.4	4.6	4.3	4.5	4.0	4.4	4.8	4.6	4.3	4.3	4.1	3.9
(38)		5% WB MCDBR	8.2	8.4	7.6	7.6	6.4	6.4	6.9	6.9	7.1	7.4	7.2	7.1
(39)		5% WB MCWBR	5.0	5.2	4.9	5.1	4.3	4.8	5.3	5.1	4.5	4.5	4.0	3.9
(40)	Clear-Sky Solar Irradiance	taub	0.384	0.379	0.380	0.392	0.372	0.375	0.359	0.368	0.380	0.374	0.374	0.381
(41)		taud	2.612	2.639	2.641	2.590	2.623	2.595	2.625	2.600	2.558	2.574	2.599	2.601
(42)		Ebn at Noon	305	302	294	278	272	265	273	281	290	300	306	306
(43)		Edh at Noon	33	31	30	30	27	26	26	29	32	33	33	33
(44)	All-Sky Solar Radiation	RadAvg	2102	1963	1752	1474	1264	1097	1197	1374	1637	1880	2049	2128
(45)		RadStd	187	159	98	141	77	74	59	117	162	132	168	106

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page