

ONO-I-LAU, Fiji

WMO: 916990

Lat: 20.667S

Lon: 178.717W

Elev: 28

StdP: 100.99

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.1	19.8	11.3	8.4	21.3	12.4	9.0	21.5	10.7	20.9	10.2	21.2	4.6	150	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.0	31.0	26.9	30.4	26.4	29.9	26.0	28.0	29.8	27.4	29.3	26.9	28.9	3.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.5	29.1	26.8	22.5	28.7	26.3	21.8	28.2	89.9	29.8	87.1	29.3	84.9	29.1	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.4	8.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	14.2	28.5	0.8	1.3	13.6	29.4	13.2	30.2	12.7	30.9	12.2	31.8	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.1	27.2	27.6	27.3	26.5	24.9	23.5	22.7	22.7	23.2	24.1	25.2	26.4		
	DBStd	2.14	1.03	1.11	1.12	1.32	1.22	1.19	1.26	1.39	1.35	1.26	1.15	1.10		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	5508	533	492	536	494	462	404	395	395	396	436	456	508		
	CDD18.3	2467	275	258	278	244	204	154	137	137	146	178	206	249		
	CDH23.3	16866	2752	2703	2841	2153	1105	409	241	263	366	689	1252	2093		
	CDH26.7	2927	623	709	652	349	64	10	4	6	14	36	120	339		
(14) Wind	WSAvg	4.5	4.5	4.1	4.1	4.5	4.2	4.3	4.6	4.8	4.9	4.9	4.4	4.8		
(15) Precipitation	PrecAvg	1747	189	189	265	212	118	97	88	112	116	107	102	132		
	PrecMax	3796	591	752	1642	595	380	376	222	294	374	329	409	523		
	PrecMin	825	16	24	31	26	10	2	12	5	0	10	2	9		
	PrecStd	566	113	141	252	140	86	81	53	80	86	80	88	104		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.6	31.9	31.2	31.0	29.2	27.8	27.3	27.5	28.1	28.5	29.4	31.1		
		MCWB	26.6	27.9	27.4	26.5	25.2	24.8	23.6	24.5	24.8	24.7	25.5	26.0		
	2%	DB	30.6	31.1	30.5	30.1	28.0	26.6	26.2	26.4	26.9	27.6	28.6	30.0		
		MCWB	26.4	27.3	26.9	26.2	24.5	23.4	22.9	23.3	23.8	23.9	24.8	25.5		
	5%	DB	29.9	30.4	29.9	29.2	27.4	25.9	25.4	25.5	26.0	27.0	28.0	29.2		
		MCWB	25.9	26.6	26.5	25.6	23.8	22.8	22.4	22.3	22.7	23.4	24.2	25.2		
	10%	DB	29.4	29.7	29.3	28.5	26.7	25.2	24.6	24.7	25.2	26.2	27.4	28.5		
		MCWB	25.3	26.0	26.0	25.1	23.4	22.3	21.8	21.6	22.0	22.7	23.6	24.7		
	0.4%	WB	27.9	29.7	29.1	28.2	26.4	25.7	25.0	25.1	25.4	25.6	26.9	27.3		
		MCDB	30.0	30.8	30.1	29.9	28.0	27.3	26.1	26.8	26.9	27.6	28.3	29.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.3	28.2	27.8	27.0	25.6	24.7	23.9	24.1	24.5	24.9	26.0	26.6		
		MCDB	29.5	30.0	29.4	28.6	27.1	25.7	25.2	25.5	26.1	26.9	27.3	28.8		
	5%	WB	26.7	27.4	27.2	26.4	25.0	23.9	23.2	23.4	23.8	24.3	25.4	26.1		
		MCDB	29.0	29.5	29.1	28.2	26.4	25.1	24.7	24.6	25.4	26.0	27.0	28.1		
	10%	WB	26.3	26.8	26.6	25.9	24.3	23.2	22.5	22.7	23.1	23.7	24.8	25.7		
		MCDB	28.5	28.9	28.6	27.7	26.1	24.6	24.2	24.0	24.6	25.3	26.5	27.6		
	5% DB	MDBR	3.9	4.0	3.7	3.5	3.2	3.0	3.3	3.4	3.5	3.7	3.8	3.8		
		MCDBR	4.7	4.7	4.2	4.3	3.8	3.7	4.1	4.0	4.2	4.4	4.4	4.6		
		MCWBR	2.4	2.6	2.4	2.5	2.2	2.4	2.7	2.5	2.4	2.4	2.3	2.1		
		MCWBR	4.5	4.7	4.2	4.2	3.5	3.5	3.8	3.8	4.0	4.1	4.0	3.9		
(35) Mean Daily Temperature Range	5% WB	MCWBR	2.8	2.9	2.7	2.8	2.4	2.6	2.9	2.8	2.5	2.5	2.2	2.1		
(40) Clear-Sky Solar Irradiance	taub		0.384	0.379	0.380	0.392	0.372	0.375	0.359	0.368	0.380	0.374	0.374	0.381		
	taud		2.612	2.639	2.641	2.590	2.623	2.595	2.625	2.600	2.558	2.574	2.599	2.601		
	Ebn at Noon		960	953	928	877	858	834	862	887	913	947	964	964		
	Edh at Noon		103	99	95	94	84	83	83	91	102	105	104	105		
(44) All-Sky Solar Radiation	RadAvg		6.63	6.19	5.52	4.65	3.98	3.46	3.77	4.33	5.16	5.93	6.46	6.71		
	RadStd		0.59	0.50	0.31	0.44	0.24	0.23	0.19	0.37	0.51	0.42	0.53	0.33		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page