

ILE WALLIS, Wallis and Futuna

WMO: 917530

Lat: 13.238S

Lon: 176.199W

Elev: 24

StdP: 101.04

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.0	23.5	18.5	13.4	25.4	19.6	14.4	25.8	8.4	27.0	8.0	27.2	1.8	160	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	4.9	31.5	26.9	31.2	26.8	30.9	26.6	27.7	30.5	27.4	30.3	27.1	30.1	4.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.5	29.6	26.6	22.2	29.4	26.2	21.7	29.1	88.4	30.7	87.1	30.4	85.9	30.3	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	7.2	6.5	DB	21.4	31.9	1.4	0.5	20.4	32.2	19.5	32.5	18.7	32.8	17.7	33.1	(4)
(5)			WB	19.1	28.1	1.5	0.4	18.0	28.4	17.1	28.7	16.2	28.9	15.1	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	27.8	27.8	27.9	27.9	27.6	27.4	27.0	27.3	27.3	27.5	27.8	(6)	
(7)		DBStd	0.96	0.98	0.98	0.87	0.92	0.92	0.87	0.91	0.90	0.88	0.90	0.95	0.87	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6389	552	498	554	536	544	522	526	527	518	537	524	551	(10)
(11)		CDD18.3	3347	293	264	296	286	286	272	268	268	268	279	274	292	(11)
(12)		CDH23.3	35230	3234	2907	3272	3173	3018	2809	2588	2584	2683	2847	2908	3208	(12)
(13)		CDH26.7	9666	1014	914	1046	1019	850	669	519	521	609	701	821	983	(13)
(14)	Wind	WSAvg	3.6	3.2	3.3	3.0	3.1	3.3	4.0	4.1	4.3	4.2	3.7	3.2	3.1	(14)
(15)	Precipitation	PrecAvg	3150	369	286	306	296	222	163	206	164	198	298	300	341	(15)
(16)		PrecMax	4219	763	766	723	612	375	308	566	507	428	487	715	646	(16)
(17)		PrecMin	2333	114	25	42	94	57	36	60	10	13	78	95	135	(17)
(18)		PrecStd	472	155	159	167	140	93	79	140	104	101	107	121	124	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	31.7	31.7	31.7	31.2	30.7	30.2	30.2	30.6	30.9	31.2	31.5	(19)
(20)			MCWB	27.2	27.1	27.0	27.2	26.7	26.2	26.0	25.8	26.0	26.2	26.6	27.0	(20)
(21)		2%	DB	31.2	31.2	31.2	31.2	30.9	30.2	30.0	29.9	30.1	30.5	30.8	31.1	(21)
(22)			MCWB	26.9	26.8	26.8	26.9	26.6	26.1	25.9	25.7	25.8	26.1	26.4	26.8	(22)
(23)		5%	DB	30.8	30.9	30.9	30.9	30.4	29.9	29.6	29.6	29.8	30.1	30.4	30.7	(23)
(24)			MCWB	26.7	26.7	26.6	26.8	26.3	26.0	25.7	25.5	25.6	25.9	26.2	26.6	(24)
(25)		10%	DB	30.4	30.4	30.4	30.5	30.0	29.5	29.1	29.1	29.4	29.7	30.0	30.2	(25)
(26)			MCWB	26.5	26.5	26.5	26.6	26.1	25.7	25.4	25.2	25.5	25.7	26.1	26.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.1	27.9	27.8	27.7	27.6	27.2	26.9	26.7	27.0	27.2	27.4	27.7	(27)
(28)			MCDWB	31.0	30.8	30.6	30.7	30.3	29.9	29.6	29.4	29.6	29.8	30.3	30.5	(28)
(29)		2%	WB	27.5	27.5	27.4	27.4	27.1	26.7	26.5	26.2	26.5	26.7	27.0	27.3	(29)
(30)			MCDWB	30.4	30.4	30.3	30.4	30.0	29.4	29.1	29.1	29.3	29.5	30.1	30.2	(30)
(31)		5%	WB	27.1	27.1	27.1	27.1	26.7	26.4	26.1	25.9	26.2	26.4	26.6	27.0	(31)
(32)			MCDWB	29.9	30.1	30.0	30.2	29.6	29.0	28.8	28.8	29.0	29.2	29.6	30.0	(32)
(33)		10%	WB	26.8	26.7	26.7	26.7	26.4	26.1	25.7	25.6	25.8	26.1	26.3	26.7	(33)
(34)			MCDWB	29.4	29.5	29.6	29.7	29.1	28.7	28.3	28.3	28.6	28.9	29.1	29.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	4.8	4.9	4.9	4.6	3.9	3.9	4.0	4.2	4.4	4.7	4.7	(35)
(36)			MCDBR	5.3	5.4	5.4	5.3	5.2	4.4	4.4	4.5	4.5	4.9	5.3	5.3	(36)
(37)			MCWBR	2.3	2.3	2.4	2.5	2.4	2.2	2.2	2.3	2.2	2.3	2.4	2.4	(37)
(38)		5% WB	MCDWB	4.9	4.9	5.0	5.1	4.8	4.2	4.3	4.4	4.4	4.6	5.0	5.0	(38)
(39)			MCWBR	2.4	2.4	2.5	2.5	2.4	2.2	2.3	2.3	2.2	2.4	2.5	2.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.385	0.377	0.376	0.384	0.387	0.398	0.400	0.399	0.405	0.388	0.382	0.383	(40)	
(41)		taud	2.642	2.673	2.678	2.654	2.631	2.580	2.564	2.565	2.547	2.607	2.640	2.648	(41)	
(42)		Ebn at Noon	958	958	941	901	866	839	846	874	899	937	954	959	(42)	
(43)		Edh at Noon	100	96	94	91	88	90	93	98	105	102	100	99	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.77	5.68	5.67	5.16	4.59	4.31	4.56	5.22	5.80	5.94	5.88	5.88	(44)	
(45)		RadStd	0.68	0.63	0.37	0.44	0.34	0.25	0.21	0.24	0.29	0.37	0.38	0.33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.17	+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page