

ILE FUTUNA, Wallis and Futuna

WMO: 917540

Lat: 14.308S

Lon: 178.117W

Elev: 118

StdP: 14.63

Time Zone: 12.00 (E12)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	73.6	74.3	62.8	86.0	77.5	64.6	91.5	77.7	14.8	77.0	13.7	77.7	4.4	10	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.0	90.1	81.0	89.1	80.5	88.2	80.0	82.2	88.3	81.6	87.5	81.0	86.7	4.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.4	158.5	86.8	79.8	155.4	86.0	79.2	152.2	85.1	46.2	88.7	45.5	87.8	44.8	87.1	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
13.2	11.7	10.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			71.0	92.0	1.5	2.1	70.0	93.4	69.1	94.7	68.2	95.8	67.2	97.3		
			66.3	83.3	2.9	0.9	64.3	84.0	62.6	84.5	61.0	85.0	58.9	85.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	82.6	82.4	82.4	82.0	81.1	80.2	79.1	79.2	80.0	80.6	81.3	81.9
	DBStd	2.07	2.01	1.95	1.59	1.56	1.63	1.61	1.62	1.63	1.57	1.54	1.71	1.80
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11341	1011	907	1006	960	964	907	904	904	900	949	940	989
	CDD65	5866	546	487	541	510	499	457	439	439	450	484	490	524
	CDH74	57904	6032	5304	5836	5353	4941	4228	3604	3592	3999	4572	4904	5539
	CDH80	14167	1974	1680	1804	1504	1120	696	437	458	701	962	1250	1581
Wind	WSAvg	4.9	4.4	5.1	4.5	4.2	4.4	5.0	5.4	5.5	5.7	5.7	4.3	4.1
Precipitation	PrecAvg	130.4	14.8	12.9	13.3	12.1	9.8	7.4	6.1	7.1	9.3	8.9	12.6	16.0
	PrecMax	190.4	33.4	39.3	29.3	29.3	24.7	16.1	14.3	28.1	17.7	14.5	28.8	45.6
	PrecMin	96.1	1.7	3.0	3.7	1.2	1.3	2.0	1.3	1.2	3.1	3.7	4.3	4.1
	PrecStd	21.2	7.5	6.9	6.0	6.1	5.2	4.0	3.3	5.6	3.8	3.0	5.7	9.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.9	91.2	90.8	89.6	88.5	86.9	85.8	85.8	87.4	88.5	89.2	90.5
		MCWB	81.5	81.6	81.4	80.6	79.5	79.4	78.4	78.5	78.9	79.7	80.6	81.7
	2%	DB	90.1	89.5	89.1	88.1	87.1	85.5	84.5	84.6	85.7	86.8	87.9	88.7
		MCWB	80.9	80.9	80.6	80.0	79.2	78.6	77.6	77.6	78.2	78.9	79.7	80.4
	5%	DB	88.8	88.2	88.0	87.1	86.1	84.6	83.5	83.7	84.8	85.9	86.9	87.5
		MCWB	80.4	80.3	79.9	79.6	78.8	78.1	77.0	77.0	77.8	78.5	79.2	79.7
	10%	DB	87.4	87.1	87.0	86.3	85.0	83.7	82.5	82.7	83.9	84.7	85.9	86.4
		MCWB	79.8	79.8	79.6	79.2	78.3	77.5	76.2	76.4	77.4	77.9	78.7	79.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.8	82.8	82.8	81.9	81.4	80.8	79.8	80.1	80.1	80.9	81.6	82.6
		MCDB	89.6	89.2	88.8	87.5	86.3	85.2	84.1	83.9	85.1	86.6	87.7	88.8
	2%	WB	81.9	81.8	81.7	81.0	80.5	79.7	78.8	78.7	79.2	80.0	80.6	81.5
		MCDB	88.4	88.0	87.7	86.6	85.3	83.9	83.2	83.2	84.2	85.4	86.6	87.3
	5%	WB	81.2	81.0	80.8	80.3	79.7	78.9	78.1	78.0	78.6	79.2	79.9	80.6
		MCDB	87.4	86.9	86.6	85.8	84.4	83.1	82.1	82.1	83.5	84.4	85.5	86.2
	10%	WB	80.4	80.2	80.0	79.7	79.1	78.2	77.3	77.3	77.9	78.5	79.2	79.8
		MCDB	86.3	85.7	85.5	84.9	83.6	82.2	81.1	81.2	82.5	83.4	84.5	84.9
Mean Daily Temperature Range	5% DB	MDBR	9.0	8.8	9.1	8.5	7.5	6.3	6.3	6.5	7.2	7.8	8.4	8.5
		MCDBR	11.3	10.5	10.5	9.7	9.1	7.7	7.8	8.0	8.9	9.6	10.1	10.2
		MCWBR	5.5	4.9	4.9	4.5	4.3	3.9	4.1	4.1	4.3	4.7	4.7	4.8
	5% WB	MCDBR	10.2	9.6	9.9	9.0	8.0	7.3	7.3	7.3	8.3	8.7	9.4	9.5
MCWBR		5.4	4.9	5.1	4.5	4.1	4.0	4.0	4.3	4.4	4.6	4.8	4.9	
Clear-Sky Solar Irradiance	taub	0.385	0.379	0.377	0.387	0.389	0.401	0.396	0.401	0.409	0.392	0.385	0.387	
	taud	2.640	2.663	2.672	2.639	2.619	2.560	2.567	2.551	2.533	2.588	2.625	2.627	
	Ebn at Noon	304	303	298	284	273	264	268	276	284	296	302	303	
	Edh at Noon	32	31	30	29	28	29	29	31	34	33	32	32	
All-Sky Solar Radiation	RadAvg	1870	1815	1789	1579	1415	1331	1419	1599	1796	1875	1883	1837	
	RadStd	245	225	131	148	118	88	69	81	96	110	151	136	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page