

HIVA OA, French Polynesia

WMO: 919250

Lat: 9.806S

Lon: 139.036W

Elev: 174

StdP: 14.60

Time Zone: -9.50 (MRQ)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	70.9	71.5	61.4	81.9	78.2	63.7	88.7	78.1	21.0	80.3	19.6	80.7	2.1	30	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.4	90.3	77.5	89.1	77.1	88.2	76.7	80.0	86.9	79.1	86.2	78.5	85.5	8.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.0	146.4	84.4	77.1	142.1	83.5	76.4	138.7	82.9	43.7	87.2	42.8	86.4	42.1	85.7	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.5	17.8	16.1	DB	69.5	92.7	1.7	1.6	68.2	93.8	67.3	94.8	66.3	95.7	65.1	96.8	(4)
(5)			WB	65.1	81.0	1.7	1.2	63.9	81.8	62.9	82.5	61.9	83.2	60.7	84.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	80.5	81.0	81.3	81.1	80.2	79.0	78.2	78.0	78.6	79.2	79.9	80.5
	DBStd	1.86	1.59	1.65	1.62	1.52	1.38	1.39	1.36	1.22	1.45	1.49	1.56	1.62
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10874	944	868	972	933	937	871	875	867	859	905	898	945
	CDD65	5399	479	448	507	483	472	421	410	402	409	440	448	480
	CDH74	46799	4466	4319	4977	4670	4141	3341	2974	2816	3153	3558	3898	4486
	CDH80	12649	1410	1422	1574	1383	1086	644	440	452	642	951	1197	1448
Wind	WSAvg	6.2	6.6	6.3	5.7	5.4	5.2	5.8	6.5	6.6	6.9	6.4	6.1	6.6
Precipitation	PrecAvg	51.1	4.2	3.8	6.1	6.1	5.2	6.5	5.3	4.6	2.9	3.3	2.9	3.2
	PrecMax	91.0	21.4	10.4	23.8	18.3	15.8	23.1	14.1	13.5	8.4	11.8	8.0	9.9
	PrecMin	22.0	0.7	0.3	0.4	0.5	0.7	1.6	1.6	0.5	0.6	0.3	0.1	0.3
	PrecStd	16.6	3.9	2.4	4.8	4.9	3.5	4.0	3.0	2.9	1.8	2.6	1.9	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.6	91.5	91.3	90.8	89.6	87.7	86.4	86.5	87.9	89.8	90.4	90.8
		MCWB	76.9	77.7	78.6	78.7	77.4	76.2	75.2	75.0	75.0	76.7	77.1	76.7
	2%	DB	88.9	89.5	89.4	89.0	87.8	86.0	84.6	84.8	86.0	87.7	88.4	88.9
		MCWB	76.0	77.3	78.3	78.2	77.4	76.1	75.1	74.7	74.7	75.5	76.0	76.1
	5%	DB	87.4	88.0	87.9	87.5	86.4	84.6	83.5	83.6	84.6	86.2	87.0	87.6
		MCWB	75.7	77.0	77.9	77.7	77.2	75.7	74.8	74.4	74.5	75.0	75.4	75.6
	10%	DB	86.2	86.6	86.6	86.2	85.1	83.5	82.5	82.5	83.5	84.7	85.7	86.3
		MCWB	75.5	76.7	77.5	77.4	76.8	75.4	74.5	74.0	74.2	74.6	75.1	75.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.8	80.9	80.9	80.0	78.5	77.4	77.1	77.3	78.5	79.1	79.2
		MCDB	86.8	87.8	88.0	87.5	86.0	84.1	83.1	83.5	84.7	86.6	87.3	87.9
	2%	WB	78.2	79.2	79.7	79.6	78.8	77.4	76.4	76.1	76.3	77.2	77.8	78.0
		MCDB	85.4	86.6	86.8	86.2	85.1	83.1	82.2	82.4	83.5	85.0	85.8	86.4
	5%	WB	77.3	78.3	78.8	78.8	78.1	76.8	75.7	75.4	75.6	76.3	76.8	77.0
		MCDB	84.7	85.7	85.9	85.5	84.3	82.4	81.4	81.6	82.7	83.9	84.7	85.2
	10%	WB	76.4	77.4	78.0	78.1	77.3	76.1	75.2	74.7	75.0	75.5	76.0	76.1
		MCDB	83.9	84.7	84.9	84.5	83.6	81.7	80.8	80.7	81.9	82.9	83.7	84.3
Mean Daily Temperature Range	5% DB	MDBR	12.1	12.1	11.4	10.9	10.6	9.5	9.2	9.9	10.6	12.0	12.4	12.4
		MCDBR	13.9	14.0	13.2	12.9	12.6	11.4	10.9	11.7	12.2	14.1	14.1	14.0
		MCWBR	5.8	6.2	6.1	5.9	6.1	5.6	5.3	5.7	5.7	6.3	6.2	5.9
	5% WB	MCDBR	12.2	12.3	11.8	11.4	11.4	10.1	9.7	10.5	10.8	12.5	12.8	12.5
		MCWBR	6.1	6.1	6.1	5.9	6.1	5.5	5.2	5.5	5.6	6.2	6.4	6.1
Clear-Sky Solar Irradiance	taub	0.373	0.372	0.373	0.380	0.369	0.366	0.364	0.365	0.372	0.363	0.366	0.367	
	taud	2.594	2.614	2.621	2.611	2.635	2.623	2.621	2.605	2.576	2.606	2.607	2.611	
	Ebn at Noon	307	305	300	289	283	279	282	289	296	305	307	308	
	Edh at Noon	33	32	32	30	28	28	28	30	33	32	32	32	
All-Sky Solar Radiation	RadAvg	2246	2257	2113	1954	1777	1668	1718	1907	2100	2225	2231	2255	
	RadStd	139	86	119	119	64	39	58	51	52	78	97	90	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.03	N/A	N/A	N/A	N/A	+254	+254
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page