

BORA BORA, French Polynesia

WMO: 919290

Lat: 16.445S

Lon: 151.752W

Elev: 3

StdP: 101.29

Time Zone: -10.00 (W10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.4	23.0	15.9	11.3	24.7	17.0	12.1	25.0	12.7	24.8	11.4	25.2	4.1	120	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	5.0	32.5	26.6	31.9	26.3	31.4	26.1	27.2	31.3	26.8	30.9	26.6	30.5	5.0	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	29.8	25.7	20.9	29.5	25.4	20.6	29.2	85.7	31.6	84.2	31.1	83.0	30.7	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.8	9.0	DB	20.8	32.8	0.8	1.0	20.3	33.5	19.8	34.0	19.3	34.6	18.7	35.3	(4)
(5)			WB	17.7	27.5	1.1	0.7	17.0	27.9	16.3	28.3	15.7	28.7	15.0	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	28.0	28.1	28.5	28.2	27.6	26.9	26.4	26.2	26.6	27.0	27.6	27.9	(6)	
	DBStd	1.29	1.19	1.22	1.07	1.04	0.96	0.97	0.94	0.98	1.00	1.01	1.09	1.21	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6352	557	507	572	547	545	506	509	502	497	527	529	554	(10)	
	CDD18.3	3310	299	273	314	297	287	256	251	244	247	268	279	296	(11)	
	CDH23.3	33651	3338	3083	3659	3377	2965	2357	2097	1943	2110	2530	2942	3249	(12)	
	CDH26.7	9299	1077	1025	1308	1119	766	449	335	323	421	593	855	1027	(13)	
(14) Wind	WSAvg	5.1	4.9	5.2	4.8	4.7	5.0	5.5	5.6	5.5	5.4	5.3	5.0	4.6	(14)	
(15) Precipitation	PrecAvg	2036	275	246	211	138	144	105	91	79	84	129	228	300	(15)	
	PrecMax	2714	678	808	622	301	358	376	237	320	246	310	645	578	(16)	
	PrecMin	1049	76	41	60	20	40	15	16	9	6	24	27	72	(17)	
	PrecStd	352	158	150	114	83	71	82	58	62	57	72	139	146	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	33.1	33.1	32.7	31.7	30.6	30.3	30.9	31.4	31.9	32.8	32.7	(19)	
		MCWB	26.9	27.0	27.0	26.9	26.4	25.3	24.7	25.0	25.3	25.8	26.3	26.7	(20)	
	2%	DB	31.9	31.9	32.1	31.7	30.8	30.0	29.5	29.6	30.1	30.6	31.5	31.7	(21)	
		MCWB	26.2	26.3	26.6	26.4	25.9	25.0	24.3	24.3	24.6	25.2	25.8	26.2	(22)	
	5%	DB	31.2	31.3	31.5	31.2	30.2	29.5	29.0	29.0	29.5	30.0	30.8	31.1	(23)	
		MCWB	26.0	26.1	26.3	26.1	25.5	24.7	24.1	24.0	24.3	24.8	25.5	25.8	(24)	
	10%	DB	30.6	30.7	31.0	30.6	29.7	28.9	28.5	28.5	28.9	29.4	30.2	30.5	(25)	
		MCWB	25.7	25.9	26.1	25.8	25.2	24.4	23.9	23.6	24.0	24.5	25.3	25.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.4	27.7	27.3	27.0	26.2	25.7	25.7	25.9	26.5	27.0	27.3	(27)	
		MCDB	31.4	31.9	31.6	31.5	30.7	29.6	28.9	29.7	30.2	30.2	31.2	31.5	(28)	
	2%	WB	26.8	26.9	27.1	26.8	26.4	25.7	25.1	25.1	25.2	25.9	26.4	26.7	(29)	
		MCDB	30.9	31.0	31.1	30.8	29.9	28.9	28.4	28.5	29.1	29.6	30.5	30.7	(30)	
	5%	WB	26.4	26.5	26.7	26.5	26.0	25.2	24.7	24.6	24.9	25.5	26.0	26.3	(31)	
		MCDB	30.3	30.4	30.6	30.3	29.4	28.4	27.9	27.9	28.5	29.0	30.0	30.2	(32)	
	10%	WB	26.1	26.1	26.4	26.1	25.6	24.9	24.3	24.2	24.5	25.1	25.6	26.0	(33)	
		MCDB	29.7	29.8	30.1	29.8	28.8	28.1	27.5	27.4	28.0	28.5	29.3	29.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	4.9	5.0	4.7	4.4	4.2	4.3	4.6	4.8	4.8	5.0	4.8	(35)	
		MCDBR	5.6	5.5	5.6	5.3	4.9	4.6	4.7	5.0	5.4	5.4	5.7	5.6	(36)	
	5% WB	MCWBR	2.4	2.3	2.4	2.2	2.2	2.1	2.1	2.2	2.4	2.4	2.4	2.4	(37)	
		MCWBR	5.4	5.2	5.2	5.0	4.7	4.4	4.5	4.7	5.1	5.2	5.3	5.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.382	0.381	0.379	0.382	0.377	0.370	0.368	0.369	0.384	0.377	0.382	0.384	(40)	
		taud	2.632	2.638	2.640	2.641	2.641	2.640	2.633	2.622	2.580	2.612	2.620	2.627	(41)	
	Ebn at Noon		962	954	935	897	867	856	868	896	916	946	955	960	(42)	
		Edh at Noon	101	100	96	91	85	83	85	91	101	101	102	102	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.06	6.03	5.96	5.22	4.56	4.30	4.55	5.22	5.93	6.38	6.52	6.20	(44)	
	RadStd		0.59	0.66	0.33	0.41	0.27	0.23	0.19	0.27	0.21	0.40	0.42	0.71	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page