

TAHITI, French Polynesia

WMO: 919380

Lat: 17.554S

Lon: 149.607W

Elev: 5

StdP: 14.69

Time Zone: -10.00 (W10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	68.2	69.8	57.6	70.8	73.0	59.9	76.9	73.9	25.7	76.8	23.0	77.5	4.2	100	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.3	89.8	78.7	89.2	78.5	88.1	78.1	80.2	87.3	79.8	86.9	79.3	86.3	8.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.5	148.2	85.4	77.4	142.4	84.8	77.1	141.0	84.7	44.0	87.8	43.4	87.3	42.9	86.3	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.1	18.6	16.3	DB	65.4	91.5	1.7	1.0	64.2	92.2	63.2	92.8	62.3	93.4	61.1	94.1	(4)
(5)			WB	59.6	81.3	2.0	1.3	58.2	82.3	57.0	83.0	55.9	83.7	54.4	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.2	81.7	81.9	82.4	82.0	80.4	78.9	78.0	77.6	78.3	79.2	80.7	81.4	(6)
(7)		DBStd	2.39	1.76	1.72	1.55	1.47	1.61	1.81	1.77	1.95	1.69	1.63	1.60	1.83	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11022	984	894	1005	961	942	866	867	854	849	906	922	972	(10)
(11)		CDD65	5547	519	474	540	511	477	416	402	389	399	441	472	507	(11)
(12)		CDH74	53355	5632	5165	6014	5438	4488	3390	3017	2888	3218	3955	4810	5340	(12)
(13)		CDH80	15779	1887	1759	2144	1831	1290	842	651	569	700	976	1434	1696	(13)
(14)	Wind	WSAvg	6.6	7.1	6.9	6.2	5.9	6.1	6.4	7.2	6.6	6.7	6.5	7.2	(14)	
(15)	Precipitation	PrecAvg	65.4	11.3	9.4	7.0	4.8	3.9	2.6	2.1	1.8	1.9	3.7	5.2	11.3	(15)
(16)		PrecMax	97.8	37.6	29.9	37.0	23.5	17.0	10.7	6.8	6.7	7.9	11.5	14.4	30.9	(16)
(17)		PrecMin	29.9	1.8	0.8	0.2	0.2	0.1	0.0	0.0	0.0	0.2	0.2	0.8	0.8	(17)
(18)		PrecStd	14.6	8.2	7.2	6.6	4.9	3.3	2.2	1.6	1.5	1.9	2.6	3.7	7.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	90.0	90.0	90.0	88.2	87.7	86.4	86.3	86.4	87.6	88.6	89.8	(19)
(20)			MCWB	78.6	78.9	79.3	78.4	77.8	76.9	75.4	75.4	74.8	76.5	77.8	79.0	(20)
(21)		2%	DB	89.2	89.4	89.6	89.3	87.7	86.3	85.6	84.9	85.8	86.3	87.8	88.2	(21)
(22)			MCWB	78.3	78.6	79.0	78.3	77.6	76.1	75.3	74.8	74.9	76.1	77.5	78.3	(22)
(23)		5%	DB	88.0	88.1	88.5	88.1	86.4	85.7	84.4	84.3	84.5	85.7	86.5	87.7	(23)
(24)			MCWB	77.9	78.3	78.6	78.1	76.8	75.8	74.7	74.5	74.6	75.9	76.9	78.1	(24)
(25)		10%	DB	87.2	87.5	87.8	87.5	85.8	84.3	83.8	83.0	84.0	84.4	86.0	86.4	(25)
(26)			MCWB	77.6	78.1	78.4	77.9	76.5	75.0	74.3	73.6	74.4	75.2	76.7	77.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	81.0	81.1	80.1	79.9	78.4	77.7	77.8	78.9	79.8	80.7	(27)	
(28)			MCD B	87.4	87.1	88.6	87.6	86.6	85.1	84.5	84.2	84.2	85.2	87.0	87.6	(28)
(29)		2%	WB	79.8	80.0	80.1	79.7	78.9	77.5	76.5	76.4	76.5	77.9	78.8	79.7	(29)
(30)			MCD B	86.5	86.7	87.5	87.1	85.6	84.5	83.4	83.1	83.5	84.6	85.8	86.6	(30)
(31)		5%	WB	79.0	79.4	79.5	79.0	78.0	76.7	75.7	75.5	75.7	77.0	78.0	79.0	(31)
(32)			MCD B	85.8	86.3	87.0	86.5	84.8	83.8	82.7	82.4	83.0	84.0	85.1	85.9	(32)
(33)		10%	WB	78.3	78.7	78.9	78.3	77.2	75.8	75.0	74.6	74.9	76.1	77.2	78.2	(33)
(34)			MCD B	85.1	85.8	86.3	85.7	84.1	82.9	82.0	81.6	82.3	83.0	84.4	85.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.9	10.9	11.3	11.3	11.4	11.9	12.0	11.9	11.6	11.2	10.8	10.4	(35)
(36)			MCDBR	11.8	11.9	12.0	12.1	12.0	12.6	12.5	12.4	12.2	11.9	11.5	11.4	(36)
(37)			MCWBR	6.3	6.4	6.4	6.4	6.4	6.9	6.9	7.2	6.7	6.7	6.2	6.3	(37)
(38)		5% WB	MCDBR	10.7	10.9	11.3	11.3	11.1	11.7	11.6	11.4	11.4	11.0	10.8	10.5	(38)
(39)			MCWBR	6.2	6.3	6.4	6.4	6.5	6.9	6.9	7.1	6.7	6.7	6.4	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.383	0.382	0.380	0.382	0.375	0.366	0.363	0.364	0.381	0.376	0.382	0.385	(40)	
(41)		taud	2.621	2.629	2.629	2.626	2.634	2.640	2.635	2.635	2.622	2.575	2.603	2.612	2.618	(41)
(42)		Ebn at Noon	305	302	296	284	274	272	276	285	291	300	303	304	(42)	
(43)		Edh at Noon	32	32	31	29	27	26	27	29	32	32	33	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1920	1899	1843	1590	1378	1295	1374	1586	1807	1956	2042	1928	(44)	
(45)		RadStd	180	199	95	119	91	74	50	71	89	122	114	218	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	(e) +0.77	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page