

TAKAROA, French Polynesia

WMO: 919430

Lat: 14.454S

Lon: 145.025W

Elev: 10

StdP: 14.69

Time Zone: -10.00 (W10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	74.8	75.7	64.7	91.5	78.7	66.4	97.2	79.3	29.5	78.3	27.4	79.0	10.5	70	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.4	89.2	79.3	88.3	78.7	87.7	78.3	80.9	86.8	80.1	86.1	79.6	85.7	10.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.8	85.2	78.3	146.9	84.7	77.5	143.2	84.4	44.5	86.4	43.7	86.4	43.1	86.1	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	23.1	21.2	DB	72.5	90.0	0.9	1.7	71.8	91.2	71.3	92.2	70.8	93.2	70.2	94.4	(4)
(5)			WB	66.9	80.9	1.3	1.6	66.0	82.1	65.2	83.0	64.4	83.9	63.5	85.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	83.0	83.3	83.9	83.8	82.7	81.6	80.5	80.0	80.6	81.4	82.3	82.7	(6)	
	DBStd	1.97	1.64	1.76	1.70	1.50	1.41	1.36	1.32	1.45	1.39	1.51	1.48	1.75	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	11730	1022	932	1051	1013	1015	947	946	931	919	973	969	1012	(10)	
	CDD65	6255	557	512	586	563	550	497	481	466	469	508	519	547	(11)	
	CDH74	68525	6505	6103	7125	6750	6275	5195	4583	4233	4456	5218	5785	6297	(12)	
(13)	CDH80	19588	2175	2185	2727	2494	1928	1150	699	603	752	1163	1673	2039	(13)	
(14)	Wind	WSAvg	11.9	11.8	11.9	12.0	10.9	11.0	12.6	13.0	12.5	12.9	12.0	11.3	10.7	(14)
(15) Precipitation	PrecAvg	58.9	7.9	6.9	5.3	4.5	3.6	3.7	2.9	2.7	3.1	4.8	7.2	7.8	(15)	
	PrecMax	89.0	23.7	23.9	15.5	17.8	18.2	12.6	11.8	6.7	8.6	11.0	24.1	24.8	(16)	
	PrecMin	27.4	2.2	1.7	0.6	0.2	0.3	0.1	0.9	0.6	0.4	0.9	1.3	0.7	(17)	
	PrecStd	12.2	4.6	4.5	3.1	3.9	3.0	2.6	2.0	1.5	2.1	2.4	4.5	5.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	90.0	90.7	89.9	88.3	87.4	85.5	85.6	86.4	87.3	88.1	89.1	(19)	
		MCWB	79.3	80.1	81.1	79.3	78.3	77.3	76.2	75.7	76.2	77.3	78.4	79.4	(20)	
	2%	DB	88.1	88.5	89.0	88.7	87.3	85.9	84.7	84.6	85.3	86.3	87.2	88.0	(21)	
		MCWB	78.1	79.0	79.5	78.8	77.9	77.0	75.8	75.4	75.8	76.8	78.0	78.4	(22)	
	5%	DB	87.1	87.6	88.0	87.8	86.5	85.1	84.0	83.8	84.5	85.5	86.4	87.2	(23)	
		MCWB	77.8	78.4	78.9	78.4	77.7	76.6	75.5	75.2	75.5	76.5	77.6	78.0	(24)	
	10%	DB	86.3	86.8	87.1	86.9	85.8	84.3	83.3	83.1	83.6	84.7	85.7	86.3	(25)	
		MCWB	77.5	78.1	78.6	78.2	77.5	76.2	75.2	74.9	75.2	76.2	77.2	77.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.7	81.9	82.2	81.0	80.0	79.0	78.1	77.4	77.9	79.0	79.9	80.8	(27)	
		MCDB	86.6	88.1	89.1	86.8	86.3	85.0	83.5	83.6	84.1	85.4	86.3	87.3	(28)	
	2%	WB	80.1	80.5	80.7	80.0	79.2	78.2	77.3	76.8	77.1	78.0	79.1	79.8	(29)	
		MCDB	85.2	86.0	87.0	86.1	85.3	84.0	82.7	82.7	83.3	84.3	85.4	86.1	(30)	
	5%	WB	79.1	79.5	79.9	79.3	78.7	77.6	76.6	76.3	76.4	77.4	78.4	79.1	(31)	
		MCDB	85.3	85.7	86.3	85.7	84.7	83.3	82.1	82.1	82.5	83.5	84.6	85.3	(32)	
	10%	WB	78.3	78.8	79.2	78.9	78.2	77.1	76.2	75.7	76.0	76.9	77.9	78.4	(33)	
		MCDB	84.8	85.5	85.7	85.5	84.2	82.8	81.7	81.4	81.9	83.0	84.1	84.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	6.9	6.4	6.4	6.1	5.7	5.6	5.9	6.3	6.5	6.7	7.1	(35)	
		MCDBR	7.5	7.4	7.1	7.1	6.9	6.4	6.3	6.7	7.0	7.2	7.3	7.8	(36)	
	5% WB	MCWBR	3.3	3.3	3.0	3.0	3.1	3.0	3.1	3.0	3.2	3.2	3.2	3.4	(37)	
		MCWBR	7.1	7.0	6.8	6.8	6.3	5.9	5.8	6.1	6.6	6.8	7.0	7.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.382	0.381	0.382	0.381	0.373	0.369	0.368	0.368	0.376	0.374	0.378	0.383	(40)	
		taud	2.616	2.625	2.616	2.630	2.649	2.639	2.623	2.617	2.592	2.618	2.628	2.615	(41)	
	Ebn at Noon		305	303	296	286	278	274	277	286	293	301	304	304	(42)	
		Edh at Noon	33	32	31	30	27	27	28	29	32	32	32	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		2066	2036	1985	1806	1563	1464	1543	1752	1981	2101	2114	2077	(44)	
	RadStd		127	182	102	121	118	67	63	62	91	107	110	168	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page