

HAO, French Polynesia

WMO: 919440

Lat: 18.063S

Lon: 140.961W

Elev: 16

StdP: 14.69

Time Zone: -10.00 (W10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.8	72.7	58.3	72.7	75.0	60.2	77.8	75.5	30.1	75.5	28.2	76.2	16.5	130	0.586

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.0	87.1	78.0	86.4	77.8	85.9	77.6	79.7	84.6	79.1	84.3	78.7	84.0	11.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.2	146.6	83.2	77.4	142.6	82.9	77.0	140.6	82.8	43.1	85.1	42.6	84.6	42.1	84.2	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.4	25.1	23.1	DB	69.3	88.8	1.2	1.3	68.5	89.7	67.7	90.4	67.1	91.1	66.2	92.1	(4)
(5)			WB	62.2	80.6	1.8	2.0	60.9	82.1	59.9	83.3	58.9	84.4	57.6	85.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.0	81.6	82.1	82.7	81.8	80.5	78.9	77.7	77.4	77.7	78.6	80.2	81.0
	DBStd	2.45	1.64	1.74	1.49	1.59	1.47	1.62	1.78	1.62	1.76	1.72	1.53	1.66
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10950	980	899	1014	954	944	867	858	849	830	886	907	962
	CDD65	5475	515	479	549	504	479	417	393	384	380	421	457	497
	CDH74	50974	5590	5346	6294	5482	4648	3395	2636	2412	2498	3236	4309	5128
CDH80	9708	1393	1507	1941	1386	749	284	114	92	155	320	687	1080	
Wind	WSAvg	13.8	13.6	13.7	13.6	12.9	13.6	13.6	14.7	14.5	14.5	13.8	14.0	12.8
Precipitation	PrecAvg	56.2	5.7	6.9	3.9	4.4	4.1	3.8	2.8	2.4	3.3	4.1	7.2	7.2
	PrecMax	83.5	12.6	23.9	8.1	13.3	9.9	10.9	6.3	7.5	8.4	9.3	15.4	20.3
	PrecMin	36.3	1.6	1.5	0.8	1.1	0.6	0.2	0.8	0.7	0.5	0.7	1.1	1.2
	PrecStd	10.3	2.6	5.1	2.0	3.1	2.4	2.6	1.7	1.5	2.3	2.3	3.5	4.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.1	87.7	88.4	87.4	85.9	84.2	82.8	82.8	83.9	84.6	86.2	87.1
		MCWB	77.8	78.3	78.5	77.6	77.1	75.5	75.0	74.4	74.7	75.6	77.0	77.7
	2%	DB	86.1	86.7	87.2	86.3	84.6	83.2	82.0	81.8	82.6	83.6	84.8	85.9
		MCWB	77.6	77.9	78.3	77.4	76.6	75.2	74.6	73.9	74.1	75.0	76.4	77.4
	5%	DB	85.3	86.0	86.4	85.5	84.0	82.5	81.3	81.0	81.7	82.7	84.1	84.9
		MCWB	77.3	77.7	78.1	77.1	76.3	75.0	74.1	73.5	73.8	74.8	76.2	77.0
	10%	DB	84.5	85.3	85.7	84.7	83.2	81.8	80.6	80.4	80.8	81.9	83.3	84.1
		MCWB	77.0	77.5	77.8	76.8	76.0	74.7	73.7	73.3	73.5	74.5	75.9	76.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.3	81.2	80.2	79.4	78.0	77.3	76.6	77.0	77.7	78.8	79.5
		MCDB	84.7	85.2	85.8	84.2	82.5	82.0	80.8	80.5	81.0	82.5	83.7	84.1
	2%	WB	79.1	79.2	79.6	79.0	78.3	77.0	76.2	75.6	76.0	76.9	77.9	78.8
		MCDB	84.1	84.5	85.1	84.1	82.3	81.3	80.2	79.9	80.5	81.5	82.9	83.8
	5%	WB	78.3	78.8	79.0	78.3	77.8	76.3	75.4	75.1	75.3	76.2	77.3	78.2
		MCDB	83.6	84.2	84.8	83.6	82.2	80.9	79.8	79.6	80.1	81.0	82.3	83.2
	10%	WB	77.9	78.2	78.3	77.9	77.1	75.7	74.8	74.5	74.7	75.6	76.9	77.6
		MCDB	83.2	83.7	84.3	83.3	82.0	80.5	79.3	79.1	79.5	80.4	81.8	82.6
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.9	6.0	5.7	5.6	5.3	5.3	5.8	6.1	6.3	5.9	5.9
		MCDBR	6.4	6.4	6.5	6.3	6.0	5.8	5.7	6.2	6.8	6.9	6.6	6.6
		MCWBR	3.3	3.2	3.3	3.5	3.3	3.2	3.3	3.4	3.5	3.7	3.3	3.4
	5% WB	MCDBR	5.9	5.8	6.1	5.9	5.6	5.3	5.3	5.5	6.1	6.3	6.1	6.3
MCWBR		3.5	3.3	3.3	3.6	3.6	3.3	3.4	3.4	3.5	3.7	3.3	3.5	
Clear-Sky Solar Irradiance	taub	0.379	0.378	0.378	0.377	0.369	0.364	0.361	0.358	0.371	0.368	0.375	0.380	
	taud	2.618	2.630	2.624	2.645	2.650	2.646	2.638	2.638	2.595	2.621	2.628	2.624	
	Ebn at Noon	306	303	296	285	276	272	276	287	293	303	305	306	
	Edh at Noon	33	32	31	29	27	26	27	28	31	32	32	32	
All-Sky Solar Radiation	RadAvg	2072	2041	1959	1681	1433	1306	1409	1660	1892	2049	2127	2088	
	RadStd	158	170	116	126	128	72	64	61	108	117	113	200	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page