

HAO, French Polynesia

WMO: 919440

Lat: 18.063S

Lon: 140.961W

Elev: 5

StdP: 101.26

Time Zone: -10.00 (W10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.1	22.6	14.6	10.4	23.9	15.6	11.1	24.2	13.4	24.2	12.6	24.6	7.4	130	0.586

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	3.3	30.6	25.6	30.2	25.4	29.9	25.3	26.5	29.2	26.2	29.0	25.9	28.9	5.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.7	20.9	28.5	25.2	20.4	28.3	25.0	20.1	28.2	82.5	29.5	81.1	29.2	80.1	29.0	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.2	10.3	20.7	31.5	0.7	0.7	20.3	32.0	19.9	32.5	19.5	32.9	19.0	33.4		
(5)			16.8	27.0	1.0	1.1	16.1	27.8	15.5	28.5	14.9	29.1	14.2	29.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	27.6	27.8	28.2	27.7	26.9	26.1	25.4	25.2	25.4	25.9	26.8	27.2	(6)
(7)		DBStd	1.36	0.91	0.97	0.83	0.89	0.82	0.90	0.99	0.90	0.98	0.96	0.85	0.92	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6083	544	499	563	530	524	482	477	472	461	492	504	534	(10)
(11)		CDD18.3	3042	286	266	305	280	266	232	218	213	211	234	254	276	(11)
(12)		CDH23.3	28319	3106	2970	3497	3046	2582	1886	1464	1340	1388	1798	2394	2849	(12)
(13)	CDH26.7	5393	774	837	1078	770	416	158	63	51	86	178	382	600	(13)	
(14)	Wind	WSAvg	6.2	6.1	6.1	6.1	5.7	6.1	6.6	6.5	6.5	6.1	6.3	5.7	(14)	
(15)	Precipitation	PrecAvg	1428	145	174	99	112	103	97	70	62	84	103	183	184	(15)
(16)		PrecMax	2122	320	607	207	338	252	277	161	191	214	235	391	515	(16)
(17)		PrecMin	921	40	38	21	28	16	6	20	18	13	19	28	31	(17)
(18)		PrecStd	262	65	130	52	78	60	66	42	38	58	59	89	117	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.6	30.9	31.3	30.8	29.9	29.0	28.2	28.2	28.8	29.2	30.1	30.6	(19)
MCWB			25.4	25.7	25.8	25.3	25.1	24.2	23.9	23.6	23.7	24.2	25.0	25.4	(20)	
2%		DB	30.1	30.4	30.7	30.2	29.2	28.4	27.8	27.7	28.1	28.6	29.3	29.9	(21)	
		MCWB	25.4	25.5	25.7	25.2	24.8	24.0	23.6	23.3	23.4	23.9	24.7	25.2	(22)	
5%		DB	29.6	30.0	30.2	29.7	28.9	28.1	27.4	27.2	27.6	28.2	28.9	29.4	(23)	
		MCWB	25.2	25.4	25.6	25.1	24.6	23.9	23.4	23.1	23.2	23.8	24.5	25.0	(24)	
10%		DB	29.2	29.6	29.8	29.3	28.5	27.7	27.0	26.9	27.1	27.7	28.5	29.0	(25)	
		MCWB	25.0	25.3	25.5	24.9	24.4	23.7	23.2	22.9	23.0	23.6	24.4	24.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.8	27.3	26.8	26.3	25.5	25.2	24.8	25.0	25.4	26.0	26.4	(27)
MCDWB			29.3	29.6	29.9	29.0	28.1	27.8	27.1	26.9	27.2	28.0	28.7	29.0	(28)	
2%		WB	26.1	26.2	26.4	26.1	25.7	25.0	24.6	24.2	24.4	24.9	25.5	26.0	(29)	
		MCDWB	29.0	29.2	29.5	28.9	28.0	27.4	26.8	26.6	26.9	27.5	28.3	28.8	(30)	
5%		WB	25.7	26.0	26.1	25.7	25.4	24.6	24.1	23.9	24.1	24.6	25.2	25.7	(31)	
		MCDWB	28.7	29.0	29.4	28.7	27.9	27.2	26.5	26.4	26.7	27.2	27.9	28.4	(32)	
10%		WB	25.5	25.7	25.7	25.5	25.1	24.3	23.8	23.6	23.7	24.2	24.9	25.4	(33)	
		MCDWB	28.5	28.7	29.1	28.5	27.8	26.9	26.3	26.2	26.4	26.9	27.7	28.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.2	3.3	3.3	3.2	3.1	2.9	2.9	3.2	3.4	3.5	3.3	3.3	(35)
MCDBR			3.6	3.5	3.6	3.5	3.3	3.2	3.2	3.5	3.8	3.8	3.7	3.7	(36)	
MCWBR			1.8	1.8	1.8	2.0	1.9	1.8	1.8	1.9	2.0	2.1	1.8	1.9	(37)	
5% WB		MCDWB	3.3	3.2	3.4	3.3	3.1	2.9	2.9	3.1	3.4	3.5	3.4	3.5	(38)	
		MCWBR	1.9	1.8	1.8	2.0	2.0	1.8	1.9	1.9	2.0	2.1	1.9	1.9	(39)	
		Clear-Sky Solar Irradiance	taub	0.379	0.378	0.378	0.377	0.369	0.364	0.361	0.358	0.371	0.368	0.375	0.380	(40)
taud	2.618		2.630	2.624	2.645	2.650	2.646	2.638	2.638	2.595	2.621	2.628	2.624	(41)		
Ebn at Noon	965		955	933	898	870	857	870	904	925	954	962	964	(42)		
Edh at Noon	103		100	98	90	84	81	84	89	99	100	101	102	(43)		
(44)	All-Sky Solar Radiation	RadAvg	6.53	6.43	6.17	5.30	4.52	4.12	4.44	5.23	5.96	6.46	6.71	6.58	(44)	
RadStd		0.50	0.54	0.37	0.40	0.40	0.23	0.20	0.19	0.34	0.37	0.36	0.63	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page