

HEREHERETUE, French Polynesia

WMO: 919450

Lat: 19.867S

Lon: 144.996W

Elev: 10

StdP: 14.69

Time Zone: -10.00 (W10)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	67.9	69.3	54.6	63.4	71.5	56.5	68.0	72.4	26.2	76.4	23.0	76.1	4.8	120	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	7.9	87.7	78.8	86.9	78.4	86.2	78.1	80.7	85.8	79.9	85.0	79.2	84.3	9.7	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.2	84.6	78.3	147.0	83.8	77.6	143.7	83.2	44.3	86.0	43.4	84.9	42.7	84.5	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.4	20.9	18.9	DB	63.7	93.0	2.7	11.1	61.7	101.0	60.2	107.5	58.6	113.7	56.7	121.8	(4)
(5)			WB	58.6	81.5	0.8	2.0	58.0	83.0	57.5	84.2	57.0	85.3	56.4	86.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.6	81.0	81.5	82.1	80.7	78.4	76.7	75.7	75.3	75.7	77.0	78.8	80.0
	DBStd	3.10	1.77	1.72	1.94	2.01	2.08	2.12	2.03	2.22	2.08	2.08	1.97	1.94
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10426	961	882	995	922	880	802	796	784	770	838	865	931
	CDD65	4951	496	462	530	472	415	352	331	319	320	373	415	466
	CDH74	40569	5147	4994	5907	4695	3195	2055	1502	1442	1491	2345	3393	4403
	CDH80	7914	1297	1380	1831	1054	403	127	54	54	73	212	543	886
Wind	WSAvg	10.2	9.2	11.2	9.9	10.1	9.7	10.0	10.2	9.8	10.8	10.2	10.6	10.2
Precipitation	PrecAvg	68.7	7.5	6.5	6.2	5.9	5.7	4.1	3.0	3.3	3.1	4.2	6.5	10.1
	PrecMax	104.4	23.5	16.6	25.9	23.9	14.1	15.9	8.2	11.9	8.9	10.6	16.7	31.2
	PrecMin	43.3	1.8	0.1	0.7	0.4	0.2	0.4	0.0	0.0	0.0	0.0	0.3	1.5
	PrecStd	13.9	5.3	3.6	5.0	4.1	3.9	3.3	1.9	2.8	2.1	2.8	4.3	5.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.8	88.6	90.6	87.3	85.5	83.7	82.8	82.9	82.9	84.4	86.8	87.1
		MCWB	78.5	79.2	82.0	78.4	77.1	75.7	75.1	74.6	74.0	75.9	77.8	78.5
	2%	DB	86.7	87.3	88.1	86.5	84.3	82.5	81.5	81.5	81.8	83.1	85.0	85.8
		MCWB	78.1	78.4	79.6	78.1	76.6	75.2	74.1	73.7	73.7	75.1	76.9	77.8
	5%	DB	86.0	86.5	86.9	85.6	83.3	81.5	80.4	80.5	80.8	82.2	83.9	84.9
		MCWB	77.8	78.1	78.8	77.7	75.9	74.4	73.5	73.1	73.4	74.5	76.2	77.3
	10%	DB	85.1	85.6	86.0	84.6	82.3	80.5	79.4	79.6	79.8	81.2	83.0	84.1
		MCWB	77.4	77.8	78.3	77.2	75.1	73.7	72.8	72.6	72.8	74.1	75.7	76.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.4	82.3	80.8	78.5	77.6	76.7	76.5	76.3	77.5	78.8	80.4
		MCDB	85.9	85.6	88.6	85.5	83.1	81.0	80.9	80.6	80.5	81.9	84.2	85.3
	2%	WB	79.8	80.2	80.8	79.5	77.6	76.5	75.5	75.5	75.3	76.8	77.9	79.2
		MCDB	84.7	84.7	86.5	84.4	82.3	80.6	79.8	79.4	79.8	81.2	83.1	83.9
	5%	WB	78.9	79.4	79.9	78.7	77.0	75.8	74.6	74.7	74.5	76.1	77.2	78.5
		MCDB	83.9	84.5	85.5	83.8	81.8	80.0	79.0	78.7	79.1	80.6	82.4	83.1
	10%	WB	78.2	78.7	79.1	78.1	76.4	75.1	74.0	73.9	73.8	75.4	76.6	77.9
		MCDB	83.3	84.2	84.6	83.2	81.1	79.4	78.3	78.1	78.4	79.9	81.6	82.5
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.8	7.9	7.2	7.4	7.3	7.1	7.7	7.3	7.6	7.7	7.3
		MCDBR	8.7	9.2	8.9	8.2	8.2	8.2	7.9	8.4	8.4	8.6	8.4	8.4
		MCWBR	3.9	4.4	3.9	3.5	4.0	4.1	4.1	4.3	4.1	4.1	3.8	3.8
	5% WB	MCDBR	7.5	8.1	8.4	7.3	7.4	7.1	7.4	7.9	7.6	7.7	7.9	7.4
MCWBR		4.0	4.7	4.1	3.6	3.9	4.2	4.2	4.8	4.2	3.9	4.0	3.8	
Clear-Sky Solar Irradiance	taub	0.379	0.379	0.377	0.380	0.371	0.363	0.359	0.359	0.376	0.370	0.377	0.382	
	taud	2.627	2.629	2.634	2.632	2.642	2.644	2.644	2.636	2.581	2.605	2.615	2.622	
	Ebn at Noon	306	302	296	283	273	270	275	285	291	302	305	305	
	Edh at Noon	32	32	30	29	26	25	26	28	32	32	33	32	
All-Sky Solar Radiation	RadAvg	2012	1940	1881	1567	1331	1210	1324	1535	1799	1953	2102	1984	
	RadStd	186	196	118	134	101	85	50	77	100	158	114	224	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page