

HEREHERETUE, French Polynesia

WMO: 919450

Lat: 19.867S

Lon: 144.996W

Elev: 3

StdP: 101.29

Time Zone: -10.00 (W10)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.9	20.7	12.5	9.1	22.0	13.6	9.7	22.4	11.7	24.7	10.3	24.5	2.1	120	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	4.4	31.0	26.0	30.5	25.8	30.1	25.6	27.1	29.9	26.6	29.4	26.2	29.1	4.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.2	25.7	21.0	28.8	25.4	20.5	28.4	85.1	30.0	83.2	29.4	81.4	29.2	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	9.3	8.5	17.6	33.9	1.5	6.2	16.5	38.3	15.6	41.9	14.8	45.4	13.7	49.9		
			14.8	27.5	0.5	1.1	14.4	28.3	14.2	29.0	13.9	29.6	13.6	30.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	27.2	27.5	27.8	27.1	25.8	24.8	24.3	24.1	24.3	25.0	26.0	26.7
	DBStd	1.72	0.98	0.95	1.08	1.12	1.16	1.18	1.13	1.23	1.16	1.16	1.10	1.08
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5792	534	490	553	512	489	446	442	436	428	466	481	517
	CDD18.3	2751	276	257	294	262	231	196	184	177	178	207	231	259
	CDH23.3	22538	2859	2774	3282	2608	1775	1142	834	801	828	1303	1885	2446
(13)	CDH26.7	4397	721	767	1017	586	224	71	30	30	41	118	302	492
(14)	Wind	WSAvg	4.5	4.1	5.0	4.4	4.5	4.3	4.5	4.4	4.8	4.6	4.7	4.6
(15) Precipitation	PrecAvg	1745	190	165	158	150	144	103	77	83	78	107	166	257
	PrecMax	2653	596	421	657	607	358	403	208	303	227	268	424	792
	PrecMin	1101	45	2	19	11	6	9	0	0	0	1	8	38
	PrecStd	354	134	91	127	105	100	83	48	70	54	70	109	149
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	31.5	32.6	30.7	29.7	28.7	28.2	28.3	28.3	29.1	30.4	30.6
		MCWB	25.8	26.2	27.8	25.8	25.1	24.3	23.9	23.7	23.3	24.4	25.4	25.9
	2%	DB	30.4	30.7	31.1	30.3	29.1	28.1	27.5	27.5	27.7	28.4	29.4	29.9
		MCWB	25.6	25.8	26.4	25.6	24.8	24.0	23.4	23.1	23.2	23.9	24.9	25.5
	5%	DB	30.0	30.3	30.5	29.8	28.5	27.5	26.9	26.9	27.1	27.9	28.8	29.4
		MCWB	25.4	25.6	26.0	25.4	24.4	23.6	23.1	22.9	23.0	23.6	24.6	25.2
	10%	DB	29.5	29.8	30.0	29.2	27.9	27.0	26.4	26.4	26.5	27.4	28.3	28.9
		MCWB	25.2	25.4	25.7	25.1	24.0	23.1	22.7	22.6	22.7	23.4	24.3	24.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.4	28.0	27.1	25.8	25.3	24.8	24.7	24.6	25.3	26.0	26.9
		MCDB	29.9	29.8	31.4	29.7	28.4	27.2	27.2	27.0	27.0	27.7	29.0	29.6
	2%	WB	26.6	26.8	27.1	26.4	25.3	24.7	24.1	24.2	24.1	24.9	25.5	26.2
		MCDB	29.3	29.3	30.3	29.1	28.0	27.0	26.5	26.3	26.6	27.4	28.4	28.8
	5%	WB	26.1	26.4	26.6	26.0	25.0	24.3	23.7	23.7	23.6	24.5	25.1	25.8
		MCDB	28.8	29.2	29.7	28.8	27.7	26.6	26.1	25.9	26.2	27.0	28.0	28.4
	10%	WB	25.7	26.0	26.2	25.6	24.7	24.0	23.3	23.3	23.2	24.1	24.8	25.5
		MCDB	28.5	29.0	29.2	28.4	27.3	26.3	25.7	25.6	25.8	26.6	27.6	28.1
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.3	4.4	4.0	4.1	4.0	4.0	4.3	4.1	4.2	4.3	4.0
		MCDBR	4.9	5.1	4.9	4.5	4.6	4.5	4.4	4.6	4.7	4.8	4.7	4.6
		MCWBR	2.2	2.4	2.2	2.0	2.2	2.3	2.3	2.4	2.3	2.3	2.1	2.1
	5% WB	MCDBR	4.2	4.5	4.7	4.0	4.1	4.0	4.1	4.4	4.2	4.3	4.4	4.1
		MCWBR	2.2	2.6	2.3	2.0	2.2	2.3	2.3	2.6	2.3	2.2	2.2	2.1
(40) Clear-Sky Solar Irradiance	taub		0.379	0.379	0.377	0.380	0.371	0.363	0.359	0.359	0.376	0.370	0.377	0.382
	taud		2.627	2.629	2.634	2.632	2.642	2.644	2.644	2.636	2.581	2.605	2.615	2.622
	Ebn at Noon		965	953	932	891	862	851	866	899	918	951	961	962
	Edh at Noon		102	100	96	90	83	80	82	88	100	101	103	102
(44) All-Sky Solar Radiation	RadAvg		6.34	6.12	5.93	4.94	4.20	3.81	4.17	4.84	5.67	6.16	6.63	6.26
	RadStd		0.59	0.62	0.37	0.42	0.32	0.27	0.16	0.24	0.31	0.50	0.36	0.71

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page