

MUROROA, French Polynesia

WMO: 919520

Lat: 21.813S

Lon: 138.798W

Elev: 10

StdP: 14.69

Time Zone: -10.00 (W10)

Period: 86-97

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	67.2	68.3	53.7	61.4	70.2	55.3	65.0	70.7	31.6	71.7	29.7	72.0	15.2	140	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.6	86.7	78.1	85.9	77.7	85.1	77.3	79.9	84.1	79.2	83.4	78.6	82.8	11.3	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.6	148.7	82.2	78.0	145.4	81.9	77.3	142.2	81.5	43.3	84.3	42.7	83.5	42.1	83.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.6	26.0	23.8	64.8	89.2	1.4	2.5	63.8	91.0	63.0	92.5	62.2	93.9	61.2	95.7		
			58.0	81.3	1.9	1.2	56.7	82.1	55.5	82.8	54.4	83.5	53.1	84.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.4	80.7	80.7	81.4	80.1	77.5	75.2	74.2	73.9	74.2	75.1	76.8	78.5
	DBStd	3.45	1.71	2.03	1.73	1.97	1.99	2.38	2.42	2.45	2.22	2.25	2.22	2.00
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9984	953	859	973	903	853	757	751	741	726	779	805	884
	CDD65	4509	488	439	508	453	388	307	286	276	276	314	355	419
	CDH74	31090	4807	4298	5219	4166	2500	1212	845	777	806	1208	2007	3245
	CDH80	4483	958	875	1175	670	155	39	11	7	14	45	151	383
(14) Wind	WSAvg	13.8	13.4	13.1	12.2	12.8	14.8	14.5	14.3	15.1	14.2	14.4	13.7	12.7
(15) Precipitation	PrecAvg	63.4	5.5	6.1	6.2	4.6	5.2	5.0	5.2	4.1	4.2	5.5	6.9	7.7
	PrecMax	88.7	12.2	18.9	14.0	15.9	12.1	11.0	12.0	10.3	12.0	12.6	12.6	15.2
	PrecMin	43.1	1.8	0.4	0.9	1.3	0.6	1.1	1.0	0.7	0.8	0.8	1.8	2.2
	PrecStd	12.6	3.2	4.2	3.8	3.1	3.3	3.1	3.0	2.9	2.8	3.3	3.1	3.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.5	87.5	87.9	87.2	84.3	82.8	81.1	81.0	81.7	82.8	84.6	86.0
		MCWB	78.4	78.6	78.8	79.0	76.9	75.3	73.4	73.7	74.5	74.6	76.1	77.2
	2%	DB	86.0	86.3	86.7	85.4	82.8	81.2	79.8	79.6	80.0	81.3	82.8	84.3
		MCWB	77.6	77.9	78.2	77.8	76.2	74.3	72.9	73.0	73.3	74.2	75.7	76.8
	5%	DB	85.1	85.4	85.8	84.4	81.7	79.9	78.8	78.6	79.0	79.9	81.7	83.2
		MCWB	77.3	77.5	77.8	77.3	75.6	73.7	72.5	72.6	72.6	73.4	75.4	76.3
	10%	DB	84.2	84.3	84.8	83.4	80.7	78.7	77.7	77.6	77.9	78.8	80.6	82.2
		MCWB	77.0	77.1	77.3	76.8	74.9	73.2	72.1	72.1	72.0	72.6	74.9	75.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.4	80.7	80.1	79.0	77.4	76.2	76.0	76.3	77.0	78.1	80.0
		MCDB	85.1	84.9	85.0	84.7	82.3	79.8	78.7	77.8	79.6	79.1	81.0	82.2
	2%	WB	79.1	79.6	79.7	79.2	77.9	76.2	74.9	74.8	75.1	75.6	77.2	78.6
		MCDB	83.7	83.9	84.2	83.4	81.3	79.1	77.5	77.4	77.7	78.8	80.4	81.8
	5%	WB	78.4	78.8	79.0	78.4	77.0	75.3	74.0	74.1	74.3	74.8	76.4	77.7
		MCDB	82.9	82.9	83.7	82.6	80.5	78.6	77.0	77.1	77.3	78.4	79.7	81.1
	10%	WB	77.8	78.1	78.2	77.7	76.2	74.4	73.2	73.2	73.3	74.0	75.7	77.0
		MCDB	82.5	82.4	83.1	82.1	79.8	77.9	76.6	76.8	76.7	77.7	79.1	80.6
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	6.5	6.6	6.1	5.6	5.7	5.8	5.8	6.2	6.2	6.2	6.3
		MCDBR	7.4	7.5	7.6	6.9	6.6	7.0	6.8	6.6	7.3	7.3	7.4	7.5
	5% WB	MCWBR	3.7	3.6	3.8	3.4	3.9	4.2	4.0	3.8	4.2	4.0	3.7	3.8
		MCWBR	6.8	6.9	7.2	6.5	6.2	6.6	6.4	6.1	7.0	6.8	6.7	6.7
(40) Clear-Sky Solar Irradiance	taub		0.372	0.375	0.371	0.375	0.366	0.359	0.354	0.354	0.372	0.366	0.372	0.377
		taud	2.637	2.631	2.647	2.636	2.646	2.644	2.646	2.639	2.573	2.602	2.618	2.626
	Ebn at Noon		308	303	297	282	273	269	274	285	292	303	306	307
		Edh at Noon	32	32	30	28	26	25	25	28	32	32	32	32
(44) All-Sky Solar Radiation	RadAvg		2082	2042	1873	1523	1247	1118	1232	1477	1760	1888	2055	2061
	RadStd		193	180	131	130	91	89	55	77	105	159	141	193

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page