

MUROROA, French Polynesia

WMO: 919520

Lat: 21.813S

Lon: 138.798W

Elev: 3

StdP: 101.29

Time Zone: -10.00 (W10)

Period: 86-97

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.5	20.2	12.1	8.8	21.2	12.9	9.3	21.5	14.1	22.0	13.3	22.2	6.8	140	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	3.7	30.4	25.6	29.9	25.4	29.5	25.2	26.6	29.0	26.2	28.5	25.9	28.2	5.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.2	27.9	25.5	20.8	27.7	25.2	20.3	27.5	82.8	29.1	81.4	28.6	80.0	28.3	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	11.6	10.7	DB	18.2	31.8	0.8	1.4	17.6	32.8	17.2	33.6	16.8	34.4	16.2	35.4	(4)
(5)			WB	14.5	27.4	1.1	0.7	13.7	27.8	13.1	28.2	12.5	28.6	11.7	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	27.1	27.0	27.4	26.7	25.3	24.0	23.5	23.3	23.5	24.0	24.9	25.8	(6)	
	DBStd	1.92	0.95	1.13	0.96	1.10	1.11	1.32	1.34	1.36	1.23	1.25	1.24	1.11	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	5547	529	477	541	502	474	421	417	412	403	433	447	491	(10)	
	CDD18.3	2505	271	244	282	252	216	171	159	153	153	174	197	233	(11)	
	CDH23.3	17272	2671	2388	2899	2314	1389	673	469	432	448	671	1115	1803	(12)	
(13)	CDH26.7	2491	532	486	653	372	86	22	6	4	8	25	84	213	(13)	
(14)	Wind	WSAvg	6.2	6.0	5.8	5.4	5.7	6.6	6.5	6.4	6.8	6.3	6.4	6.1	5.7	(14)
(15) Precipitation	PrecAvg	1610	140	156	158	118	131	128	131	103	107	140	175	195	(15)	
	PrecMax	2254	310	480	356	403	308	280	304	261	306	321	321	385	(16)	
	PrecMin	1095	46	10	24	34	14	29	26	17	21	21	45	55	(17)	
	PrecStd	320	81	107	96	80	84	78	76	74	72	83	80	88	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.8	30.8	31.1	30.7	29.1	28.2	27.3	27.2	27.6	28.2	29.2	30.0	(19)	
		MCWB	25.8	25.9	26.0	26.1	24.9	24.0	23.0	23.2	23.6	23.7	24.5	25.1	(20)	
	2%	DB	30.0	30.2	30.4	29.7	28.2	27.3	26.6	26.5	26.7	27.4	28.2	29.1	(21)	
		MCWB	25.3	25.5	25.7	25.5	24.6	23.5	22.7	22.8	23.0	23.4	24.3	24.9	(22)	
	5%	DB	29.5	29.7	29.9	29.1	27.6	26.6	26.0	25.9	26.1	26.6	27.6	28.5	(23)	
		MCWB	25.1	25.3	25.4	25.2	24.2	23.2	22.5	22.5	22.6	23.0	24.1	24.6	(24)	
	10%	DB	29.0	29.1	29.3	28.5	27.1	25.9	25.4	25.3	25.5	26.0	27.0	27.9	(25)	
		MCWB	25.0	25.0	25.1	24.9	23.8	22.9	22.3	22.3	22.2	22.5	23.9	24.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.9	27.0	26.7	26.1	25.2	24.6	24.4	24.6	25.0	25.6	26.6	(27)	
		MCDB	29.5	29.4	29.4	29.3	28.0	26.6	25.9	25.5	26.4	26.1	27.2	27.9	(28)	
	2%	WB	26.2	26.4	26.5	26.2	25.5	24.6	23.8	23.8	24.0	24.2	25.1	25.9	(29)	
		MCDB	28.7	28.8	29.0	28.6	27.4	26.2	25.3	25.2	25.4	26.0	26.9	27.7	(30)	
	5%	WB	25.8	26.0	26.1	25.8	25.0	24.1	23.4	23.4	23.5	23.8	24.7	25.4	(31)	
		MCDB	28.3	28.3	28.7	28.1	26.9	25.9	25.0	25.1	25.1	25.8	26.5	27.3	(32)	
	10%	WB	25.5	25.6	25.7	25.4	24.5	23.6	22.9	22.9	23.0	23.3	24.3	25.0	(33)	
		MCDB	28.1	28.0	28.4	27.8	26.5	25.5	24.8	24.9	24.8	25.4	26.2	27.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	3.6	3.7	3.4	3.1	3.2	3.2	3.2	3.5	3.4	3.4	3.5	(35)	
		MCDBR	4.1	4.2	4.2	3.9	3.7	3.9	3.8	3.7	4.1	4.1	4.1	4.2	(36)	
	5% WB	MCWBR	2.0	2.0	2.1	1.9	2.2	2.3	2.2	2.1	2.3	2.2	2.1	2.1	(37)	
		MCWBR	3.8	3.8	4.0	3.6	3.4	3.7	3.5	3.4	3.9	3.8	3.7	3.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.372	0.375	0.371	0.375	0.366	0.359	0.354	0.354	0.372	0.366	0.372	0.377	(40)	
		taud	2.637	2.631	2.647	2.636	2.646	2.644	2.646	2.639	2.573	2.602	2.618	2.626	(41)	
	Ebn at Noon		972	956	935	890	860	847	864	899	919	954	966	968	(42)	
		Edh at Noon	101	100	94	89	82	78	80	87	100	101	102	102	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.56	6.44	5.91	4.80	3.93	3.52	3.88	4.66	5.55	5.95	6.48	6.50	(44)	
	RadStd		0.61	0.57	0.41	0.41	0.29	0.28	0.17	0.24	0.33	0.50	0.44	0.61	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page