

HOKITIKA, New Zealand

WMO: 936140

Lat: 42.7131S

Lon: 170.9844E

Elev: 132

StdP: 14.63

Time Zone: 12.00 (NZL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.6	34.4	24.5	18.7	39.4	26.9	20.9	39.2	26.2	53.4	22.6	52.6	4.5	140	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.6	71.1	63.8	69.3	62.9	67.8	62.1	65.8	68.7	64.6	67.4	63.5	66.3	8.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	92.1	67.2	63.6	88.3	66.1	62.3	84.4	65.0	30.7	68.9	29.8	67.3	28.9	66.5	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.1	19.5	16.6	DB	26.2	75.5	7.0	3.3	21.2	77.9	17.1	79.8	13.2	81.7	8.2	84.1
			WB	24.5	67.4	6.4	1.7	19.8	68.6	16.1	69.6	12.4	70.6	7.8	71.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.0	60.1	60.5	58.3	54.6	51.1	47.0	45.6	47.0	49.5	51.5	53.9	57.5	(6)
	DBStd	6.23	3.78	3.78	3.68	3.56	4.12	3.95	3.62	3.53	3.33	3.33	3.40	3.98	(7)
	HDD50	478	0	1	1	6	35	107	145	105	49	22	5	2	(8)
	HDD65	4386	157	129	210	312	431	539	602	559	466	417	332	232	(9)
	CDD50	1579	313	296	257	144	69	18	8	11	33	70	124	236	(10)
	CDD65	12	6	4	1	0	0	0	0	0	0	0	0	1	(11)
	CDH74	10	6	2	0	0	0	0	0	0	0	0	0	2	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	6.9	7.1	6.6	6.3	6.1	6.2	6.2	6.1	6.2	7.4	8.2	8.1	7.7	(14)
(15) Precipitation	PrecAvg	110.0	9.4	7.0	8.7	8.5	9.7	9.3	8.5	9.1	9.6	10.5	9.7	10.2	(15)
	PrecMax	133.0	23.1	14.6	16.9	21.0	19.8	18.3	16.1	20.3	18.9	19.4	19.0	18.0	(16)
	PrecMin	92.0	2.6	1.5	1.6	0.2	3.1	3.1	1.1	2.4	3.8	4.2	1.7	2.0	(17)
	PrecStd	11.3	4.5	3.1	3.7	4.1	3.9	3.7	3.9	4.0	3.6	3.9	3.9	4.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.4	73.4	71.6	67.0	64.2	58.9	57.9	59.7	61.6	63.6	67.0	71.3	(19)
		MCWB	65.5	65.0	61.7	58.0	57.3	53.8	51.0	50.7	53.2	54.9	59.1	63.1	(20)
	2%	DB	71.1	70.9	68.7	64.1	61.0	57.1	55.9	56.7	58.8	61.2	64.3	68.4	(21)
		MCWB	64.2	64.5	61.7	58.2	56.8	53.9	51.1	50.7	53.1	55.4	57.7	62.0	(22)
	5%	DB	69.0	69.1	66.8	62.6	59.4	55.7	54.2	55.2	57.4	59.4	62.4	66.4	(23)
		MCWB	63.2	63.4	61.1	58.1	56.0	52.8	50.0	50.6	52.7	54.6	56.9	60.8	(24)
	10%	DB	67.3	67.7	65.3	61.3	58.0	54.1	52.5	53.6	56.0	57.9	60.6	64.5	(25)
		MCWB	62.1	62.6	60.5	57.5	55.0	51.3	48.7	49.9	52.3	53.8	55.9	60.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.1	67.4	65.7	62.5	60.3	57.0	55.6	55.0	56.6	58.7	61.4	65.2	(27)
		MCDB	72.3	70.4	67.8	63.9	61.3	57.7	56.1	56.3	58.2	61.1	64.2	68.7	(28)
	2%	WB	65.8	66.1	64.3	61.0	58.6	55.3	53.3	53.2	55.5	57.2	59.5	63.6	(29)
		MCDB	68.8	68.9	66.1	62.2	59.8	56.3	54.5	54.8	56.9	59.2	62.1	66.3	(30)
	5%	WB	64.5	64.8	62.8	59.8	57.1	53.7	51.3	51.9	54.4	56.1	58.4	62.3	(31)
		MCDB	67.3	67.8	65.4	61.2	58.6	55.0	52.9	53.8	56.1	58.0	60.8	64.9	(32)
	10%	WB	63.2	63.6	61.5	58.2	55.5	51.8	49.5	50.6	53.1	55.0	57.2	61.1	(33)
		MCDB	66.2	66.7	64.3	60.3	57.5	53.5	51.5	52.8	55.2	57.0	59.4	63.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.6	12.8	12.7	12.2	12.5	13.4	13.1	12.3	11.7	11.7	11.4	(35)
		MCDBR	13.7	14.3	14.4	13.8	12.7	12.7	14.5	14.2	14.2	13.3	14.1	13.5	(36)
	5% WB	MCWBR	8.8	9.6	9.2	9.7	9.4	9.7	10.6	10.0	10.1	9.1	9.3	8.8	(37)
		MCWBR	11.1	12.1	10.5	9.7	9.6	9.1	10.7	11.2	10.2	10.1	10.0	10.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.344	0.336	0.316	0.306	0.297	0.291	0.281	0.303	0.327	0.334	0.330	0.339	(40)
		taud	2.552	2.592	2.656	2.666	2.650	2.625	2.655	2.608	2.528	2.524	2.560	2.569	(41)
	Ebn at Noon		312	305	298	279	259	249	263	276	289	303	314	315	(42)
		Edh at Noon	33	30	26	22	19	17	18	23	29	32	33	33	(43)
(44) All-Sky Solar Radiation	RadAvg		1932	1747	1311	860	542	423	504	725	1052	1424	1782	1927	(44)
	RadStd		147	132	76	84	44	35	42	48	95	121	182	145	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.54	+0.95	N/A	N/A	N/A	N/A	-97	-184	N/A
(47) Regional (3 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	-70	N/A	N/A

Nomenclature: See separate page