

TROUGHTON ISLAND, Australia

WMO: 941020

Lat: 13.754S

Lon: 126.149E

Elev: 26

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	70.1	71.3	43.6	41.8	74.8	46.1	46.2	75.7	28.8	73.9	27.3	74.0	13.0	120	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.6	92.7	80.4	91.8	80.5	91.1	80.4	85.9	88.2	84.4	87.7	83.4	87.6	11.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
85.4	186.8	87.3	83.6	176.0	86.2	82.3	168.6	85.9	50.6	88.2	48.6	87.3	47.4	87.8	90.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	25.2	23.0	65.6	94.1	10.6	0.8	58.0	94.7	51.8	95.2	45.9	95.7	38.2	96.2		
(5)			53.0	85.6	7.4	2.2	47.7	87.2	43.3	88.5	39.1	89.7	33.7	91.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	83.0	84.7	84.6	85.0	85.7	83.2	79.0	77.6	78.2	81.5	84.0	86.6	86.7	(6)
(7)		DBStd	3.92	2.18	2.38	2.22	2.13	2.46	2.96	2.17	1.93	1.90	2.96	1.28	3.59	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	2	0	0	0	0	0	0	0	0	0	2	0	0	(9)
(10)		CDD50	12062	1077	968	1084	1070	1030	870	856	875	944	1055	1097	1136	(10)
(11)		CDD65	6589	612	548	619	620	565	420	391	410	494	592	647	671	(11)
(12)		CDH74	76469	7967	6977	7998	8111	6512	3443	2606	2936	4912	7117	8677	9213	(12)
(13)		CDH80	31074	3562	3005	3586	3835	2357	677	338	459	1334	2782	4360	4779	(13)
(14)	Wind	WSAvg	11.9	14.9	13.7	11.2	10.2	13.4	14.4	11.9	10.3	9.7	10.5	10.6	12.5	(14)
(15)	Precipitation	PrecAvg	44.6	11.2	9.8	7.4	2.9	1.1	0.2	0.2	0.1	0.2	1.1	2.3	8.2	(15)
(16)		PrecMax	70.8	23.6	17.7	16.9	11.5	8.3	2.3	0.8	0.2	0.8	6.2	4.3	18.8	(16)
(17)		PrecMin	26.9	4.6	3.3	2.5	0.1	0.0	0.0	0.0	0.0	0.1	0.5	1.1	1.1	(17)
(18)		PrecStd	10.3	4.0	3.9	4.3	2.6	1.8	0.4	0.2	0.0	0.2	1.2	0.9	4.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.8	91.9	92.5	93.4	91.4	88.2	85.7	85.9	88.9	91.0	92.6	116.8	(19)
(20)		MCWB	82.0	82.3	81.3	76.9	75.0	74.5	71.3	72.4	76.3	78.2	81.4	83.0	83.0	(20)
(21)		2%	DB	90.6	90.9	91.3	92.1	89.9	86.2	84.3	84.6	87.7	89.9	91.7	94.9	(21)
(22)		MCWB	81.9	82.0	81.1	77.7	74.9	72.7	71.1	71.9	76.5	78.6	81.0	82.3	82.3	(22)
(23)		5%	DB	89.7	89.9	90.2	91.0	88.8	84.8	83.2	83.6	86.6	89.0	90.9	92.0	(23)
(24)		MCWB	81.7	81.9	81.2	78.0	74.6	72.1	70.7	71.5	76.4	78.6	80.7	81.9	81.9	(24)
(25)		10%	DB	88.7	88.7	89.1	90.0	87.5	83.6	82.0	82.6	85.5	88.1	90.2	90.8	(25)
(26)		MCWB	81.4	81.5	81.0	77.9	74.2	71.5	70.2	71.0	76.1	78.5	80.5	81.5	81.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	87.3	87.7	88.0	83.5	80.9	78.7	77.3	79.1	81.0	83.2	84.6	87.4	(27)
(28)		MDCB	88.1	88.9	89.0	88.6	86.0	84.3	80.3	81.4	85.0	86.3	88.3	90.0	90.0	(28)
(29)		2%	WB	85.0	84.6	84.8	82.1	79.9	77.1	75.8	77.0	79.7	81.7	83.5	85.1	(29)
(30)		MDCB	87.2	87.4	87.9	88.2	85.1	82.8	79.9	81.0	84.1	85.9	88.1	88.5	88.5	(30)
(31)		5%	WB	83.6	83.2	83.2	81.1	78.8	75.9	74.8	75.8	78.9	80.7	82.5	83.7	(31)
(32)		MDCB	87.0	86.9	87.5	87.4	84.3	81.9	79.5	80.6	83.3	85.9	88.3	88.2	88.2	(32)
(33)		10%	WB	82.6	82.4	82.1	80.3	77.8	74.7	73.8	74.7	78.1	79.9	81.8	82.6	(33)
(34)		MDCB	86.7	86.6	87.0	86.9	84.3	81.1	78.9	79.8	82.8	85.5	87.8	88.3	88.3	(34)
(35)	Mean Daily Temperature Range	MDBR	7.3	6.9	7.5	8.5	8.5	8.5	9.2	9.6	8.5	8.2	7.8	7.6	7.6	(35)
(36)		5% DB	MCDBR	8.0	7.8	8.4	9.2	9.3	8.9	9.8	9.9	8.7	8.4	8.1	8.3	(36)
(37)		MCWBR	4.4	4.1	4.3	4.7	5.6	6.0	6.1	5.7	4.0	3.7	3.7	4.0	4.0	(37)
(38)		5% WB	MCDBR	8.2	7.6	8.2	8.1	7.9	8.2	8.6	8.3	7.8	7.9	8.0	8.1	(38)
(39)		MCWBR	5.5	5.0	5.1	4.2	4.3	4.7	4.8	4.1	3.5	3.8	4.1	4.1	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.424	0.412	0.394	0.377	0.372	0.349	0.343	0.354	0.407	0.433	0.432	0.417	0.417	(40)
(41)		taud	2.502	2.540	2.590	2.603	2.567	2.591	2.590	2.551	2.432	2.382	2.420	2.508	2.508	(41)
(42)		Ebn at Noon	292	293	293	288	279	280	285	291	285	284	288	294	294	(42)
(43)		Edh at Noon	36	35	32	30	30	28	29	31	37	40	39	36	36	(43)
(44)	All-Sky Solar Radiation	RadAvg	1793	1846	1877	1850	1699	1621	1706	1929	2140	2246	2246	1965	1965	(44)
(45)		RadStd	232	259	223	159	99	67	50	34	48	73	69	173	173	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page