

NOONAMAH, Australia

WMO: 941050

Lat: 12.6100S

Lon: 131.0473E

Elev: 62

StdP: 14.66

Time Zone: 9.50 (AUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	56.5	59.9	N/A	N/A	N/A	N/A	N/A	N/A	23.6	77.6	21.1	79.0	1.1	150	0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.9	97.7	N/A	96.3	N/A	94.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.3	18.9	16.7	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.2	83.8	83.4	84.7	84.2	81.2	78.4	77.0	77.7	81.7	84.0	85.0	85.1
	DBStd	3.99	2.50	2.70	2.41	2.39	2.77	3.85	2.91	2.74	3.47	2.69	2.23	2.44
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11742	1048	934	1076	1026	968	852	836	859	951	1055	1049	1088
	CDD65	6267	583	514	611	576	503	402	371	394	501	590	599	623
	CDH74	72338	6923	5991	7409	7178	5618	4181	3624	3875	5681	7033	7278	7547
	CDH80	30535	2806	2312	3337	3344	2310	1433	1247	1260	2447	3235	3320	3484
(14) Wind	WSAvg	5.6	6.7	7.4	5.3	5.4	5.4	5.9	5.6	6.2	4.9	4.8	4.7	4.5
(15) Precipitation	PrecAvg	66.1	15.3	13.8	10.8	3.7	0.7	0.0	0.0	0.0	0.6	2.4	5.9	12.0
	PrecMax	102.2	30.0	35.8	24.9	23.2	3.1	0.2	0.3	0.3	2.3	6.2	9.8	23.9
	PrecMin	43.3	5.8	5.7	4.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	3.4	4.0
	PrecStd	12.6	5.8	6.4	5.0	4.7	0.8	0.0	0.1	0.1	0.7	1.7	1.5	5.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.2	95.2	96.2	96.7	95.0	93.5	93.6	94.6	99.9	99.8	98.9	97.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	92.0	93.0	94.0	94.3	93.2	91.6	91.8	92.5	97.2	97.1	96.9	95.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	90.2	90.9	92.2	92.4	91.7	89.9	90.1	90.4	94.9	95.5	95.1	94.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	88.2	89.2	90.5	89.8	89.8	87.7	87.7	87.8	92.5	93.6	93.1	92.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	9.1	10.3	10.5	15.4	17.3	18.9	16.5	16.5	16.1	13.7	12.9
		MCDBR	13.6	14.4	16.3	19.7	23.8	25.2	28.8	29.6	27.0	23.0	20.0	17.7
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub	taub	0.423	0.412	0.399	0.376	0.373	0.354	0.350	0.367	0.431	0.453	0.457	0.423
		taud	2.473	2.504	2.536	2.579	2.538	2.534	2.544	2.484	2.331	2.292	2.316	2.458
	Ebn at Noon	Ebn at Noon	292	294	292	288	279	279	284	287	278	278	280	292
		Edh at Noon	37	36	34	31	30	30	30	34	41	44	44	38
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1650	1724	1768	1838	1709	1642	1716	1915	2078	2148	2040	1803
	RadStd	RadStd	163	248	212	142	87	55	43	52	78	84	77	166

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	+0.43	N/A	+0.13	N/A	N/A	N/A

Nomenclature: See separate page