

NOONAMAH, Australia

WMO: 941050

Lat: 12.6100S

Lon: 131.0473E

Elev: 19

StdP: 101.10

Time Zone: 9.50 (AUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 13.6	(c) 15.5	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.6	(k) 25.3	(l) 9.4	(m) 26.1	(n) 0.5	(o) 150	(p) 0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 12	(b) 7.2	(c) 36.5	(d) N/A	(e) 35.7	(f) N/A	(g) 35.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.3	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 10.4	(b) 8.4	(c) 7.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	28.8	28.5	29.3	29.0	27.4	25.8	25.0	25.4	27.6	28.9	29.4	29.5		
	DBStd	2.22	1.39	1.50	1.34	1.33	1.54	2.14	1.62	1.52	1.93	1.49	1.24	1.35		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6523	582	519	598	570	538	473	464	477	528	586	583	604		
	CDD18.3	3482	324	286	339	320	279	223	206	219	278	328	333	346		
	CDH23.3	40188	3846	3328	4116	3988	3121	2323	2013	2153	3156	3907	4043	4193		
	CDH26.7	16964	1559	1284	1854	1858	1283	796	693	700	1359	1797	1844	1936		
(14) Wind	WSAvg	2.5	3.0	3.3	2.4	2.4	2.4	2.6	2.5	2.8	2.2	2.1	2.1	2.0		
(15) Precipitation	PrecAvg	1679	389	351	274	95	17	0	1	1	15	61	150	305		
	PrecMax	2595	763	910	633	589	80	5	8	8	58	157	250	608		
	PrecMin	1101	148	144	102	0	0	0	0	0	0	4	86	101		
	PrecStd	321	148	162	128	120	21	1	3	2	17	44	38	130		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.6	35.1	35.6	36.0	35.0	34.2	34.2	34.8	37.7	37.7	37.2	36.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	33.3	33.9	34.4	34.6	34.0	33.1	33.2	33.6	36.2	36.2	36.1	35.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	32.4	32.7	33.4	33.6	33.2	32.2	32.3	32.5	35.0	35.3	35.1	34.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.1	5.7	5.8	8.6	9.6	10.5	9.2	9.1	8.9	7.6	7.2		
		MCDBR	7.5	8.0	9.0	10.9	13.2	14.0	16.0	16.5	15.0	12.8	11.1	9.9		
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.423	0.412	0.399	0.376	0.373	0.354	0.350	0.367	0.431	0.453	0.457	0.423		
	taud		2.473	2.504	2.536	2.579	2.538	2.534	2.544	2.484	2.331	2.292	2.316	2.458		
	Ebn at Noon		921	926	919	909	880	881	895	904	876	877	884	920		
	Edh at Noon		118	114	108	98	96	94	95	106	130	139	138	120		
(44) All-Sky Solar Radiation	RadAvg		5.20	5.43	5.58	5.79	5.39	5.17	5.41	6.04	6.55	6.77	6.43	5.68		
	RadStd		0.51	0.78	0.67	0.45	0.28	0.17	0.13	0.17	0.25	0.27	0.24	0.52		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.24	N/A	+0.07	N/A	N/A	N/A	N/A

Nomenclature: See separate page