

PORT KEATS AWS, Australia

WMO: 941110

Lat: 14.233S

Lon: 129.450E

Elev: 59

StdP: 14.66

Time Zone: 9.50 (AUC)

Period: 83-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	58.6	61.4	N/A	N/A	N/A	N/A	N/A	N/A	12.1	74.5	11.6	74.7	4.9	140	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	11.1	94.5	N/A	93.4	N/A	92.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.8	10.9	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.2	84.1	84.0	84.0	82.2	79.5	75.1	74.4	75.1	81.0	84.3	85.6	85.2		
	DBStd	5.06	2.75	2.72	2.42	2.64	3.47	4.32	3.45	2.82	3.83	2.45	2.51	2.85		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	2	0	0	0	0	0	2	0	0	0	0	0	0		
	CDD50	11383	1058	951	1054	965	913	753	757	780	930	1064	1067	1091		
	CDD65	5910	593	531	589	515	448	305	292	315	480	599	617	626		
	CDH74	67512	7466	6752	7280	5655	4269	2254	2093	2338	5312	7557	8285	8251		
	CDH80	29529	3363	3093	3365	2464	1772	706	558	570	2039	3367	4181	4051		
(14) Wind	WSAvg	4.5	5.2	5.2	4.0	4.1	4.2	4.0	3.8	3.9	4.3	5.4	5.2	4.7		
(15) Precipitation	PrecAvg	54.2	13.2	12.5	8.8	3.4	1.1	0.4	0.2	0.1	0.2	1.2	2.9	10.2		
	PrecMax	89.3	23.1	25.6	22.0	12.2	6.7	3.0	0.6	0.6	1.0	6.4	4.7	21.1		
	PrecMin	28.9	4.8	4.2	2.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.6	1.6		
	PrecStd	13.3	5.0	5.7	5.8	2.9	1.4	0.6	0.1	0.1	0.2	1.3	0.9	4.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.1	93.7	94.8	94.6	94.1	91.2	89.2	89.3	95.2	96.1	95.1	96.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	91.8	92.1	92.9	93.2	91.6	87.9	86.8	86.8	92.4	92.8	93.2	93.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	90.9	91.1	91.7	91.7	89.8	86.2	85.0	85.0	90.1	90.8	91.9	92.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	89.8	89.9	90.4	90.2	88.1	84.4	83.2	83.3	88.0	89.6	91.0	90.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	11.1	12.8	16.3	18.6	18.8	18.9	17.7	13.7	10.9	11.1	10.4		
		MCDBR	11.5	12.5	15.0	18.7	19.2	19.9	20.0	19.1	15.7	13.1	11.6	11.4		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.419	0.417	0.396	0.376	0.368	0.349	0.342	0.360	0.424	0.453	0.454	0.426		
	taud		2.514	2.516	2.575	2.593	2.548	2.556	2.570	2.511	2.373	2.316	2.350	2.474		
	Ebn at Noon		294	292	292	288	279	280	285	288	279	278	282	291		
	Edh at Noon		36	36	33	30	30	29	29	33	40	43	42	37		
(44) All-Sky Solar Radiation	RadAvg		1783	1801	1845	1858	1704	1611	1705	1919	2111	2195	2127	1905		
	RadStd		190	262	215	122	84	65	48	48	74	88	93	166		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	-1.55	N/A	+1.22	+0.40	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page