

PORT KEATS AWS, Australia

WMO: 941110

Lat: 14.233S

Lon: 129.450E

Elev: 18

StdP: 101.11

Time Zone: 9.50 (AUC)

Period: 83-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 14.8	(c) 16.3	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 5.4	(k) 23.6	(l) 5.2	(m) 23.7	(n) 2.2	(o) 140	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 11	(b) 6.1	(c) 34.7	(d) N/A	(e) 34.1	(f) N/A	(g) 33.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.0	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 5.5	(b) 5.3	(c) 4.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	29.0	28.9	28.9	27.9	26.4	23.9	23.6	24.0	27.2	29.1	29.8	29.6		
	DBStd	2.81	1.53	1.51	1.34	1.47	1.93	2.40	1.92	1.56	2.13	1.36	1.39	1.59		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	1	0	0	0	0	0	1	0	0	0	0	0	0		
	CDD10.0	6324	588	528	586	536	507	418	421	433	517	591	593	606		
	CDD18.3	3283	329	295	327	286	249	169	162	175	267	333	343	348		
	CDH23.3	37507	4148	3751	4044	3142	2372	1252	1163	1299	2951	4198	4603	4584		
	CDH26.7	16405	1868	1718	1869	1369	984	392	310	317	1133	1871	2323	2251		
(14) Wind	WSAvg	2.0	2.3	2.3	1.8	1.8	1.9	1.8	1.7	1.7	1.9	2.4	2.3	2.1		
(15) Precipitation	PrecAvg	1376	335	317	224	86	27	10	5	2	5	31	74	259		
	PrecMax	2268	587	651	558	310	171	77	15	14	25	163	119	537		
	PrecMin	735	122	106	57	11	1	1	1	1	1	1	16	40		
	PrecStd	337	126	144	148	74	35	14	3	3	6	34	24	125		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.5	34.3	34.9	34.8	34.5	32.9	31.8	31.8	35.1	35.6	35.1	35.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	33.2	33.4	33.8	34.0	33.1	31.1	30.5	30.4	33.6	33.8	34.0	34.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	32.7	32.8	33.1	33.2	32.1	30.1	29.5	29.4	32.3	32.7	33.3	33.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	32.1	32.2	32.5	32.3	31.2	29.1	28.5	28.5	31.1	32.0	32.8	32.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	6.1	7.1	9.0	10.3	10.5	10.5	9.8	7.6	6.1	6.1	5.8		
		MCDBR	6.4	6.9	8.3	10.4	10.7	11.0	11.1	10.6	8.7	7.3	6.5	6.3		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.419	0.417	0.396	0.376	0.368	0.349	0.342	0.360	0.424	0.453	0.454	0.426		
	taud		2.514	2.516	2.575	2.593	2.548	2.556	2.570	2.511	2.373	2.316	2.350	2.474		
	Ebn at Noon		927	921	921	907	880	882	898	909	880	877	888	918		
	Edh at Noon		114	113	103	96	95	91	91	103	125	136	133	118		
(44) All-Sky Solar Radiation	RadAvg		5.62	5.68	5.82	5.86	5.37	5.08	5.38	6.05	6.66	6.92	6.71	6.00		
	RadStd		0.60	0.82	0.68	0.39	0.26	0.21	0.15	0.15	0.23	0.28	0.29	0.52		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	-0.86	N/A	+0.68	+0.22	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page