

PIRLANGIMPI, Australia

WMO: 941190

Lat: 11.4022S

Lon: 130.4217E

Elev: 63

StdP: 14.66

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	61.4	63.7	45.4	45.0	77.3	48.8	51.2	77.1	14.5	85.0	13.9	85.1	1.3	130	0.301

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.5	93.7	77.3	92.7	77.6	91.8	77.7	86.2	87.2	83.5	86.8	81.8	87.1	7.4	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
85.9	190.4	86.9	82.9	171.9	85.1	80.5	158.8	84.3	51.0	87.2	47.7	86.7	45.6	87.2	93.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.5	11.8	10.3	DB	57.7	96.5	2.1	1.5	56.2	97.6	55.0	98.5	53.9	99.3	52.3	100.3	
			WB	53.1	85.3	2.3	3.5	51.4	87.8	50.0	89.9	48.7	91.9	47.0	94.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.2	82.9	82.7	82.5	82.2	80.5	77.3	77.1	77.9	81.0	83.1	83.9	83.8	(6)
	DBStd	3.34	2.16	2.07	1.83	2.12	2.70	3.72	2.89	2.43	2.00	1.57	1.46	2.00	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	11398	1021	916	1007	966	944	819	841	866	929	1026	1016	1047	(10)
	CDD65	5923	556	496	542	516	479	369	376	401	479	561	566	582	(11)
	CDH74	59404	6142	5285	5498	5102	4496	3071	3047	3498	4646	5957	6155	6507	(12)
(13)	CDH80	22900	2208	1824	1846	1929	1757	1088	1094	1409	2005	2582	2597	2561	(13)
(14)	Wind	WSAvg	3.6	3.9	3.5	2.7	3.0	4.0	4.2	4.0	3.7	3.7	2.9	2.9	(14)
(15) Precipitation	PrecAvg	81.3	16.3	15.6	14.8	5.2	0.9	0.0	0.1	0.2	1.2	3.4	7.9	13.7	(15)
	PrecMax	108.9	30.7	30.7	27.8	22.0	3.8	0.5	1.8	2.8	4.9	9.0	18.7	33.6	(16)
	PrecMin	58.4	5.7	5.0	5.2	0.6	0.0	0.0	0.0	0.0	0.0	0.0	1.5	3.7	(17)
	PrecStd	14.5	6.7	5.9	6.4	4.3	0.9	0.1	0.4	0.6	1.5	2.7	3.2	7.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.7	92.7	92.7	93.6	92.6	91.3	90.8	92.1	94.2	95.4	95.2	94.2	(19)
		MCWB	81.2	80.7	80.0	76.4	75.1	75.5	71.5	70.3	73.2	74.0	78.8	80.2	(20)
	2%	DB	91.0	90.9	91.2	91.9	91.0	89.2	88.9	90.0	92.4	93.3	93.1	92.7	(21)
		MCWB	81.1	80.9	79.8	77.2	75.1	73.4	70.9	70.9	73.5	75.9	78.9	80.2	(22)
	5%	DB	89.6	89.5	89.6	90.6	89.7	87.7	87.5	88.6	90.7	91.8	91.8	91.3	(23)
		MCWB	80.9	80.5	79.4	77.6	75.0	72.3	70.7	70.6	74.4	76.4	79.0	80.3	(24)
	10%	DB	88.1	87.8	87.9	89.0	88.1	86.1	85.9	87.1	89.2	90.4	90.5	89.7	(25)
		MCWB	80.5	80.4	79.5	77.6	74.7	71.6	69.9	70.2	74.6	76.6	78.9	80.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	88.9	86.9	82.7	89.8	84.3	84.6	76.7	86.4	86.0	80.7	82.4	87.5	(27)
		MCDB	89.1	87.6	89.0	90.3	85.5	85.0	85.3	87.1	88.0	89.4	90.9	88.2	(28)
	2%	WB	84.5	84.3	81.4	82.9	79.3	77.3	74.7	76.1	78.8	79.2	81.0	83.4	(29)
		MCDB	86.6	86.6	87.9	85.8	86.2	83.8	83.6	84.5	87.0	88.4	90.0	87.5	(30)
	5%	WB	82.2	81.8	80.6	80.7	78.1	75.1	73.6	74.6	77.3	78.5	80.1	81.5	(31)
		MCDB	86.3	86.3	86.9	85.9	85.4	83.3	82.8	83.4	86.0	87.6	89.0	87.9	(32)
	10%	WB	80.8	80.8	79.9	79.5	77.1	73.8	72.6	73.4	76.3	77.8	79.5	80.6	(33)
		MCDB	86.2	86.0	85.8	84.9	84.1	82.1	81.3	82.4	84.9	86.4	88.0	87.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	10.7	11.7	14.3	16.9	18.9	19.8	20.9	18.7	16.7	15.1	12.5	(35)
		MCDBR	12.6	13.2	14.1	16.7	17.9	18.9	20.0	21.8	20.2	18.3	16.6	14.9	(36)
	5% WB	MCWBR	5.4	5.8	5.4	6.6	6.5	7.4	7.3	7.3	6.9	5.4	5.7	5.5	(37)
		MCWBR	11.6	12.1	12.4	12.7	15.8	17.6	18.2	18.6	16.9	15.6	15.2	13.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.416	0.406	0.398	0.377	0.373	0.362	0.362	0.380	0.423	0.441	0.431	0.407	(40)
		taud	2.521	2.547	2.570	2.623	2.601	2.577	2.566	2.504	2.386	2.354	2.420	2.531	(41)
	Ebn at Noon		294	295	292	289	280	278	281	284	280	282	287	296	(42)
		Edh at Noon	36	35	33	30	29	29	30	33	39	42	39	35	(43)
(44) All-Sky Solar Radiation	RadAvg		1601	1659	1664	1761	1669	1623	1691	1884	2062	2123	2039	1725	(44)
	RadStd		173	211	191	176	104	49	40	51	67	89	89	172	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.43	N/A	+0.13	N/A	N/A	N/A	N/A

Nomenclature: See separate page