

DARWIN, Australia

WMO: 941200

Lat: 12.4239S

Lon: 130.8925E

Elev: 115

StdP: 14.64

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	62.5	64.4	28.4	22.5	76.8	33.6	28.3	75.6	21.6	81.0	20.4	81.3	7.3	140	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	13.7	93.5	74.4	93.0	74.7	91.7	75.3	81.3	87.4	80.7	86.9	80.1	86.2	12.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	152.4	84.1	79.1	151.6	84.0	78.8	150.2	83.8	45.3	87.7	44.5	87.9	44.0	87.0	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.5	16.7	57.8	97.0	2.4	1.8	56.1	98.2	54.7	99.3	53.3	100.2	51.6	101.5		
(5)			46.6	82.9	1.9	0.7	45.3	83.4	44.2	83.8	43.1	84.2	41.8	84.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	83.0	82.7	82.9	83.1	80.7	77.6	77.0	77.9	81.7	84.2	84.6	84.2
	DBStd	3.60	2.34	2.28	2.03	2.04	2.95	3.58	2.93	2.58	2.14	1.81	1.88	2.47
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11539	1022	916	1020	992	953	828	836	864	950	1060	1039	1059
	CDD65	6064	557	496	555	542	488	378	371	399	500	595	589	594
	CDH74	66250	6392	5592	6176	6033	4788	3108	2987	3562	5452	7412	7515	7233
	CDH80	26963	2444	2053	2327	2494	1890	1110	1044	1322	2218	3364	3525	3172
(14) Wind	WSAvg	8.3	9.5	9.1	7.7	7.4	8.3	8.7	8.3	8.0	8.1	8.4	7.9	8.2
(15) Precipitation	PrecAvg	68.9	18.0	15.1	13.2	3.7	0.9	0.0	0.0	0.1	0.6	2.8	5.5	9.8
	PrecMax	109.2	37.0	42.0	39.9	15.6	11.8	1.6	1.1	1.5	5.1	9.6	14.6	26.1
	PrecMin	44.1	5.4	4.6	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.7
	PrecStd	14.4	7.9	7.4	7.2	3.1	1.8	0.2	0.2	0.3	0.9	2.2	2.9	5.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.4	91.8	93.2	93.8	93.2	91.4	91.3	91.7	93.6	95.0	94.8	94.8
		MCWB	78.7	79.3	75.9	72.5	71.0	70.0	68.0	65.3	67.5	71.5	76.0	77.7
	2%	DB	91.1	91.1	91.5	92.6	91.4	89.6	89.3	89.7	91.7	93.1	93.2	93.1
		MCWB	79.2	79.4	77.6	72.7	71.4	69.3	66.8	66.4	70.2	73.3	76.6	78.4
	5%	DB	89.7	89.7	89.9	91.4	89.8	87.9	87.6	88.0	90.0	91.6	91.8	91.6
		MCWB	79.2	79.2	77.9	73.0	71.4	68.5	66.9	66.9	71.4	74.7	77.1	78.5
	10%	DB	88.2	88.1	88.9	89.8	88.2	86.2	85.8	86.3	89.1	90.5	91.1	90.0
		MCWB	79.1	79.1	78.1	74.3	71.4	68.1	66.8	67.3	71.8	75.0	77.2	78.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	81.8	81.8	80.6	78.9	76.7	74.9	75.8	78.3	79.9	81.5	81.7
		MCDB	87.7	88.0	87.6	85.8	84.1	83.6	82.7	82.5	84.1	86.6	88.0	88.0
	2%	WB	80.9	80.9	80.8	79.5	77.9	75.1	73.6	74.5	77.3	79.1	80.5	80.8
		MCDB	86.8	86.9	86.6	84.8	83.3	81.3	81.3	81.7	83.9	85.9	87.4	87.4
	5%	WB	80.2	80.1	80.0	78.9	77.0	74.0	72.6	73.4	76.4	78.6	79.8	80.1
		MCDB	86.0	85.9	85.6	84.2	82.8	80.7	80.2	80.9	83.4	85.5	86.8	86.7
	10%	WB	79.8	79.7	79.5	78.3	76.1	72.7	71.5	72.4	75.7	78.0	79.1	79.7
		MCDB	85.4	85.2	84.9	83.7	82.3	79.9	79.1	80.2	82.9	85.2	86.2	86.3
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	10.9	11.9	14.6	16.6	18.5	19.5	19.9	16.8	14.5	13.7	12.2
		MCDBR	12.4	12.7	13.8	16.0	16.9	18.4	20.0	20.6	17.9	15.5	14.6	13.9
		MCWBR	5.2	5.4	5.6	6.2	7.0	8.3	8.2	8.6	7.1	6.2	5.9	5.7
	5% WB	MCDBR	11.3	11.4	11.9	13.5	14.5	16.6	17.7	17.1	15.0	13.8	13.5	12.4
		MCWBR	5.2	5.3	5.4	5.3	5.6	6.8	7.1	6.7	5.8	5.7	6.0	5.5
(40) Clear-Sky Solar Irradiance	taub		0.423	0.411	0.398	0.376	0.371	0.354	0.351	0.367	0.426	0.451	0.455	0.419
	taud		2.486	2.518	2.551	2.597	2.562	2.553	2.559	2.506	2.361	2.313	2.333	2.481
	Ebn at Noon		292	294	292	289	280	280	284	287	279	279	281	293
	Edh at Noon		37	36	34	30	30	29	30	33	40	43	43	37
(44) All-Sky Solar Radiation	RadAvg		1631	1706	1750	1826	1702	1635	1707	1903	2075	2150	2043	1783
	RadStd		161	240	209	144	87	52	42	49	70	79	78	169

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.43	N/A	+0.13	N/A	N/A	N/A	N/A
Regional (9 neighbors)	N/A	N/A	N/A	+0.43	N/A	+0.13	N/A	N/A	N/A	N/A

Nomenclature: See separate page