

DARWIN, Australia

WMO: 941200

Lat: 12.4239S

Lon: 130.8925E

Elev: 35

StdP: 100.91

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	18.0	-2.0	3.2	24.9	0.9	4.0	24.2	9.7	27.2	9.1	27.4	3.2	140	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	7.6	34.2	23.5	33.9	23.7	33.2	24.0	27.4	30.8	27.1	30.5	26.7	30.1	5.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.8	28.9	26.2	21.7	28.9	26.0	21.5	28.8	87.4	30.9	85.6	31.0	84.4	30.6	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.3	7.5	DB	14.3	36.1	1.3	1.0	13.4	36.8	12.6	37.4	11.9	37.9	10.9	38.6	(4)
(5)			WB	8.1	28.3	1.0	0.4	7.4	28.5	6.8	28.8	6.2	29.0	5.4	29.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	28.3	28.2	28.3	28.4	27.1	25.3	25.0	25.5	27.6	29.0	29.2	29.0	(6)	
	DBStd	2.00	1.30	1.27	1.13	1.13	1.64	1.99	1.63	1.43	1.19	1.01	1.04	1.37	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6411	568	509	567	551	529	460	464	480	528	589	577	588	(10)	
	CDD18.3	3369	309	276	308	301	271	210	206	222	278	331	327	330	(11)	
	CDH23.3	36806	3551	3107	3431	3352	2660	1727	1659	1979	3029	4118	4175	4018	(12)	
	CDH26.7	14979	1358	1141	1293	1386	1050	617	580	734	1232	1869	1958	1762	(13)	
(14) Wind	WSAvg	3.7	4.3	4.1	3.5	3.3	3.7	3.9	3.7	3.6	3.6	3.7	3.5	3.7	(14)	
(15) Precipitation	PrecAvg	1751	456	384	336	94	23	1	1	2	15	72	139	250	(15)	
	PrecMax	2774	940	1068	1014	396	299	41	28	37	130	245	371	664	(16)	
	PrecMin	1121	136	117	88	1	0	0	0	0	0	1	17	19	(17)	
	PrecStd	365	200	187	183	79	46	6	4	7	23	57	73	149	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	33.2	34.0	34.3	34.0	33.0	33.0	33.2	34.2	35.0	34.9	34.9	(19)	
		MCWB	26.0	26.3	24.4	22.5	21.7	21.1	20.0	18.5	19.7	22.0	24.4	25.4	(20)	
	2%	DB	32.8	32.9	33.0	33.7	33.0	32.0	31.8	32.1	33.2	34.0	34.0	33.9	(21)	
		MCWB	26.2	26.3	25.3	22.6	21.9	20.7	19.3	19.1	21.2	23.0	24.8	25.8	(22)	
	5%	DB	32.1	32.0	32.2	33.0	32.1	31.1	30.9	31.1	32.2	33.1	33.2	33.1	(23)	
		MCWB	26.2	26.2	25.5	22.8	21.9	20.3	19.4	19.4	21.9	23.7	25.0	25.9	(24)	
	10%	DB	31.2	31.2	31.6	32.1	31.2	30.1	29.9	30.2	31.7	32.5	32.8	32.2	(25)	
		MCWB	26.2	26.2	25.6	23.5	21.9	20.1	19.3	19.6	22.1	23.9	25.1	25.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.7	27.7	27.0	26.1	24.9	23.8	24.3	25.7	26.6	27.5	27.6	(27)	
		MCDB	30.9	31.1	30.9	29.9	28.9	28.7	28.2	28.1	29.0	30.3	31.1	31.1	(28)	
	2%	WB	27.2	27.2	27.1	26.4	25.5	24.0	23.1	23.6	25.1	26.2	26.9	27.1	(29)	
		MCDB	30.5	30.5	30.3	29.3	28.5	27.4	27.4	27.6	28.8	29.9	30.8	30.8	(30)	
	5%	WB	26.8	26.7	26.7	26.1	25.0	23.3	22.5	23.0	24.7	25.9	26.5	26.7	(31)	
		MCDB	30.0	29.9	29.8	29.0	28.2	27.0	26.8	27.2	28.6	29.7	30.4	30.4	(32)	
	10%	WB	26.5	26.5	26.4	25.7	24.5	22.6	21.9	22.4	24.3	25.6	26.2	26.5	(33)	
		MCDB	29.7	29.6	29.4	28.7	27.9	26.6	26.2	26.8	28.3	29.5	30.1	30.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.1	6.6	8.1	9.2	10.3	10.9	11.1	9.3	8.1	7.6	6.8	(35)	
		MCDBR	6.9	7.0	7.7	8.9	9.4	10.2	11.1	11.5	10.0	8.6	8.1	7.7	(36)	
	5% WB	MCWBR	2.9	3.0	3.1	3.4	3.9	4.6	4.6	4.8	3.9	3.5	3.3	3.1	(37)	
		MCWBR	6.3	6.4	6.6	7.5	8.0	9.2	9.8	9.5	8.3	7.7	7.5	6.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.423	0.411	0.398	0.376	0.371	0.354	0.351	0.367	0.426	0.451	0.455	0.419	(40)	
		taud	2.486	2.518	2.551	2.597	2.562	2.553	2.559	2.506	2.361	2.313	2.333	2.481	(41)	
	Ebn at Noon		922	926	920	910	882	882	894	905	881	880	885	923	(42)	
		Edh at Noon	117	113	106	96	94	92	93	104	127	137	135	117	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.14	5.38	5.52	5.76	5.37	5.15	5.38	6.00	6.54	6.78	6.44	5.62	(44)	
	RadStd		0.51	0.76	0.66	0.45	0.28	0.17	0.13	0.16	0.22	0.25	0.25	0.53	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	+0.24	N/A	+0.07	N/A	N/A	N/A	N/A	
(47)	Regional (9 neighbors)	N/A	N/A	N/A	+0.24	N/A	+0.07	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page