

POINT FAWCETT, Australia

WMO: 941220

Lat: 11.7628S

Lon: 130.0300E

Elev: 25

StdP: 14.68

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	58.6	61.3	44.1	42.6	75.7	47.5	48.6	74.2	15.3	81.3	14.1	81.6	5.0	110	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.8	92.4	79.8	91.5	79.9	90.7	79.6	86.0	87.6	84.1	87.2	82.8	87.3	8.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
85.5	187.7	87.0	83.4	174.9	85.8	81.7	165.1	85.9	50.7	87.7	48.3	86.8	46.9	87.3	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	18.0	15.0	55.5	94.4	3.7	1.4	52.8	95.4	50.7	96.2	48.6	97.0	45.9	98.0		
(5)			51.5	84.6	4.5	1.5	48.3	85.6	45.7	86.5	43.2	87.4	39.9	88.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.6	83.7	83.7	82.8	81.7	79.1	75.6	75.0	76.0	79.5	82.4	83.9	84.1	(6)
(7)		DBStd	4.17	2.15	2.06	1.88	2.00	3.02	3.68	3.26	2.87	2.44	2.15	1.89	2.16	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11170	1043	944	1015	951	901	769	775	807	886	1004	1018	1057	(10)
(11)		CDD65	5696	578	524	550	501	436	320	310	342	436	539	568	592	(11)
(12)		CDH74	64167	7074	6408	6313	5325	4278	2855	2828	3439	4791	6456	7072	7328	(12)
(13)		CDH80	25471	2871	2611	2408	2094	1582	876	829	1138	1833	2789	3239	3201	(13)
(14)	Wind	WSAvg	6.9	10.5	10.0	7.4	5.4	5.6	6.0	5.9	6.1	6.3	6.4	6.2	7.7	(14)
(15)	Precipitation	PrecAvg	70.6	15.0	14.9	11.5	5.7	1.8	0.1	0.1	0.0	0.7	2.0	5.2	13.4	(15)
(16)		PrecMax	93.9	26.1	31.4	20.3	22.5	6.5	1.7	0.5	0.4	5.1	7.0	9.6	28.0	(16)
(17)		PrecMin	43.5	5.7	4.8	2.9	0.3	0.6	0.0	0.0	0.0	0.0	0.0	0.6	3.3	(17)
(18)		PrecStd	13.4	5.5	6.3	4.3	5.7	1.2	0.3	0.1	0.1	1.3	1.9	2.3	6.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.6	91.6	91.5	92.3	91.3	89.7	89.0	90.3	91.8	93.3	93.4	93.7	(19)
MCWB			82.2	83.9	82.0	78.2	76.7	75.9	72.2	70.0	72.1	76.1	81.2	81.3	(20)	
2%		DB	90.3	90.4	90.2	90.8	89.8	87.9	87.5	88.4	90.0	91.6	92.0	92.1	(21)	
		MCWB	82.0	82.6	81.2	78.5	76.4	73.9	71.9	70.4	74.3	77.7	80.8	81.2	(22)	
5%		DB	89.2	89.3	89.2	89.8	88.5	86.5	86.1	87.0	88.8	90.4	91.0	90.8	(23)	
		MCWB	81.7	81.7	80.7	78.0	75.9	72.9	71.2	70.6	74.8	77.8	80.3	80.9	(24)	
10%		DB	88.1	88.2	88.1	88.6	87.3	85.1	84.6	85.7	87.6	89.3	90.0	89.6	(25)	
		MCWB	81.2	81.0	80.4	77.7	75.3	72.0	70.8	70.7	74.7	77.7	79.9	80.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	88.0	87.9	86.5	82.6	81.3	79.8	76.9	76.8	80.3	82.8	87.9	86.0	(27)
MCD B			88.6	89.9	87.9	88.7	87.7	86.7	84.6	85.1	87.3	87.1	90.1	87.5	(28)	
2%		WB	85.2	85.3	83.5	81.1	79.2	77.3	75.3	75.5	78.3	81.0	84.5	83.4	(29)	
		MCD B	86.5	87.4	88.1	87.9	86.1	84.8	83.2	83.9	85.8	87.7	87.9	87.8	(30)	
5%		WB	83.0	83.6	82.3	80.1	78.2	75.7	74.2	74.6	77.2	79.8	82.2	82.3	(31)	
		MCD B	87.0	86.6	87.4	87.1	85.2	83.1	82.2	83.0	85.3	87.5	87.4	88.4	(32)	
10%		WB	81.9	82.4	81.3	79.3	77.3	74.4	73.2	73.7	76.3	78.9	80.9	81.3	(33)	
		MCD B	86.8	86.6	86.7	86.0	84.3	81.7	81.3	82.1	84.5	86.9	88.1	87.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	9.0	10.7	14.0	16.6	18.2	19.7	20.5	17.5	15.0	13.0	10.8	(35)
MCDBR			10.2	10.2	12.4	15.9	17.3	19.1	20.4	21.4	18.5	16.2	13.9	12.7	(36)	
MCWBR			5.4	5.5	6.3	6.9	7.8	8.8	9.5	9.7	7.8	6.8	5.9	5.6	(37)	
5% WB		MCD BR	9.0	9.9	10.9	13.3	15.1	17.1	18.7	18.9	15.9	13.9	12.5	11.6	(38)	
		MCWBR	6.2	6.9	6.6	7.2	7.3	8.6	9.7	9.4	6.9	6.7	6.5	6.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.418	0.408	0.396	0.377	0.374	0.364	0.362	0.377	0.427	0.444	0.435	0.410	(40)	
taud		2.526	2.554	2.590	2.631	2.604	2.574	2.570	2.521	2.391	2.363	2.426	2.534	(41)		
Ebn at Noon		293	295	293	289	280	278	281	285	279	281	287	295	(42)		
Edh at Noon		36	35	32	30	29	29	30	33	39	41	39	35	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1641	1706	1721	1800	1692	1643	1714	1905	2084	2164	2084	1789	(44)	
(45)		RadStd	182	227	200	165	100	55	39	45	66	81	84	174	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	N/A	N/A	N/A	+0.43	N/A	+0.13	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page