

POINT FAWCETT, Australia

WMO: 941220

Lat: 11.7628S

Lon: 130.0300E

Elev: 8

StdP: 101.23

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	16.3	6.7	6.1	24.3	8.6	6.9	23.5	6.8	27.4	6.3	27.5	2.2	110	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.0	33.6	26.5	33.1	26.6	32.6	26.4	30.0	30.9	28.9	30.7	28.2	30.7	3.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
29.7	26.8	30.5	28.6	25.0	29.9	27.6	23.6	29.9	100.0	30.9	94.6	30.5	91.2	30.7	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.6	8.0	6.7	DB	13.0	34.7	2.0	0.8	11.6	35.2	10.4	35.7	9.2	36.1	7.7	36.7
			WB	10.9	29.2	2.5	0.8	9.1	29.8	7.6	30.3	6.2	30.8	4.4	31.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	28.7	28.7	28.2	27.6	26.1	24.2	23.9	24.5	26.4	28.0	28.9	28.9	(6)
	DBStd	2.32	1.19	1.14	1.04	1.11	1.68	2.05	1.81	1.59	1.36	1.19	1.05	1.20	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	6206	579	524	564	528	501	427	431	448	492	558	566	587	(10)
	CDD18.3	3164	321	291	306	278	242	178	172	190	242	299	316	329	(11)
	CDH23.3	35648	3930	3560	3507	2958	2377	1586	1571	1911	2662	3587	3929	4071	(12)
	CDH26.7	14151	1595	1451	1338	1163	879	487	461	632	1018	1549	1799	1778	(13)
(14) Wind	WSAvg	3.1	4.7	4.5	3.3	2.4	2.5	2.7	2.6	2.7	2.8	2.9	2.8	3.4	(14)
(15) Precipitation	PrecAvg	1794	382	379	291	146	46	3	2	1	18	52	133	341	(15)
	PrecMax	2385	662	797	516	571	164	44	13	9	129	177	243	711	(16)
	PrecMin	1104	146	123	73	7	14	0	0	0	0	0	16	83	(17)
	PrecStd	341	140	160	109	144	31	8	3	2	33	48	58	161	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	33.1	33.1	33.5	32.9	32.0	31.7	32.4	33.2	34.0	34.1	34.3	(19)
		MCWB	27.9	28.8	27.8	25.7	24.8	24.4	22.3	21.1	22.3	24.5	27.3	27.4	(20)
	2%	DB	32.4	32.4	32.3	32.7	32.1	31.0	30.8	31.3	32.2	33.1	33.3	33.4	(21)
		MCWB	27.8	28.1	27.3	25.8	24.7	23.3	22.2	21.3	23.5	25.4	27.1	27.3	(22)
	5%	DB	31.8	31.9	31.8	32.1	31.4	30.3	30.1	30.6	31.6	32.5	32.8	32.7	(23)
		MCWB	27.6	27.6	27.1	25.5	24.4	22.7	21.8	21.4	23.8	25.5	26.9	27.2	(24)
	10%	DB	31.2	31.2	31.2	31.4	30.7	29.5	29.2	29.8	30.9	31.8	32.2	32.0	(25)
		MCWB	27.3	27.2	26.9	25.4	24.1	22.2	21.5	21.5	23.7	25.4	26.6	27.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.1	31.0	30.3	28.1	27.4	26.6	25.0	24.9	26.8	28.2	31.0	30.0	(27)
		MCDB	31.5	32.1	31.0	31.5	31.0	30.4	29.2	29.5	30.7	30.6	32.3	30.9	(28)
	2%	WB	29.6	29.6	28.6	27.3	26.2	25.2	24.1	24.2	25.7	27.2	29.2	28.6	(29)
		MCDB	30.3	30.8	31.2	31.1	30.1	29.4	28.5	28.8	29.9	31.0	31.0	31.0	(30)
	5%	WB	28.3	28.6	28.0	26.7	25.7	24.3	23.5	23.7	25.1	26.6	27.9	27.9	(31)
		MCDB	30.5	30.4	30.8	30.6	29.6	28.4	27.9	28.3	29.6	30.8	30.8	31.3	(32)
	10%	WB	27.7	28.0	27.4	26.3	25.1	23.5	22.9	23.2	24.6	26.0	27.1	27.4	(33)
		MCDB	30.4	30.3	30.4	30.0	29.1	27.6	27.4	27.8	29.2	30.5	31.1	31.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.0	5.9	7.8	9.2	10.1	10.9	11.4	9.7	8.3	7.2	6.0	(35)
		MCDBR	5.7	5.7	6.9	8.8	9.6	10.6	11.3	11.9	10.3	9.0	7.7	7.1	(36)
	5% WB	MCWBR	3.0	3.1	3.5	3.8	4.3	4.9	5.3	5.4	4.3	3.8	3.3	3.1	(37)
		MCWBR	5.0	5.5	6.0	7.4	8.4	9.5	10.4	10.5	8.8	7.7	6.9	6.4	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.418	0.408	0.396	0.377	0.374	0.364	0.362	0.377	0.427	0.444	0.435	0.410	(40)
		taud	2.526	2.554	2.590	2.631	2.604	2.574	2.570	2.521	2.391	2.363	2.426	2.534	(41)
	Ebn at Noon	Ebn at Noon	925	929	923	910	882	875	885	897	881	886	904	931	(42)
		Edh at Noon	112	109	102	94	91	91	93	103	123	130	123	111	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	5.17	5.38	5.43	5.67	5.33	5.18	5.40	6.01	6.57	6.82	6.57	5.64	(44)
	RadStd	RadStd	0.57	0.71	0.63	0.52	0.31	0.17	0.12	0.14	0.21	0.26	0.27	0.55	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	+0.24	N/A	+0.07	N/A	N/A	N/A	N/A

Nomenclature: See separate page