

POINT STUART, Australia

WMO: 941270

Lat: 12.244S

Lon: 131.879E

Elev: 5

StdP: 14.69

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	59.1	61.5	41.0	37.8	73.0	44.7	43.7	73.5	18.6	82.7	17.2	83.2	4.6	120	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.8	95.4	79.4	93.5	78.8	92.2	78.5	85.0	89.2	83.6	88.7	82.7	87.9	10.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
83.9	177.4	87.5	82.5	169.3	86.5	81.4	163.3	85.6	49.3	89.7	47.8	88.8	46.7	88.0	90.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.9	16.6	14.8	DB	53.0	96.2	4.0	1.9	50.2	97.6	47.9	98.7	45.7	99.7	42.8	101.1	
			WB	47.6	85.3	2.3	2.6	45.9	87.1	44.6	88.6	43.3	90.0	41.6	91.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.9	83.1	82.7	82.8	82.1	79.3	76.2	75.3	76.6	81.0	83.5	84.5	84.1	
	DBStd	4.16	2.03	1.93	1.87	2.05	2.92	3.66	3.33	3.04	3.86	2.63	1.78	2.39	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11286	1025	916	1018	963	908	785	785	825	929	1038	1036	1058	
	CDD65	5811	560	496	553	513	443	335	320	360	479	573	586	593	
	CDH74	65204	6452	5599	6239	5678	4269	2842	2788	3469	5641	7261	7613	7353	
	CDH80	26281	2430	1991	2250	2113	1522	926	912	1198	2491	3407	3707	3334	
Wind	WSAvg	7.1	8.8	8.3	6.8	6.1	6.6	6.8	6.8	7.2	6.8	7.0	6.8	7.5	
Precipitation	PrecAvg	63.5	14.2	13.4	10.4	4.3	0.8	0.0	0.0	0.1	0.6	2.4	5.7	11.6	
	PrecMax	92.0	27.6	26.4	25.6	23.6	3.1	0.2	0.2	0.6	3.3	7.8	9.2	19.6	
	PrecMin	41.6	5.5	4.6	4.3	0.2	0.0	0.0	0.0	0.0	0.0	0.0	3.0	4.3	
	PrecStd	10.7	5.3	5.2	4.9	4.8	0.9	0.0	0.1	0.2	0.7	1.9	1.6	3.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.3	92.4	92.4	92.7	91.1	89.6	90.4	90.7	100.6	100.8	95.2	96.2	
		MCWB	81.5	83.5	82.6	78.3	75.8	73.8	69.9	68.8	59.6	65.1	79.4	81.6	
	2%	DB	91.3	90.8	90.7	90.7	89.5	88.1	88.2	89.0	95.5	94.8	93.6	93.9	
		MCWB	81.4	82.5	81.8	78.8	75.6	72.8	69.7	69.3	68.4	74.3	78.7	80.6	
	5%	DB	89.7	89.5	89.4	89.4	88.2	86.9	86.8	87.6	91.8	92.4	92.5	92.3	
		MCWB	81.2	82.0	81.2	78.4	75.2	72.0	69.4	69.0	72.9	76.3	78.3	79.9	
	10%	DB	88.3	88.1	88.2	88.2	87.1	85.5	85.2	86.2	89.7	91.0	91.4	90.8	
		MCWB	80.6	81.1	80.3	77.8	74.7	71.0	68.9	68.9	73.6	76.3	78.0	79.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	85.2	87.3	88.2	85.7	82.6	80.1	75.9	76.3	81.4	82.3	83.4	83.9
			MCDB	89.6	90.2	88.7	87.9	87.9	84.9	82.5	83.7	86.8	88.5	90.3	92.4
2%		WB	83.5	85.0	84.6	82.7	80.2	77.2	74.4	75.0	78.9	80.5	81.7	82.7	
		MCDB	88.2	89.1	89.1	87.0	85.6	83.6	81.9	82.9	85.5	88.9	89.9	90.5	
5%		WB	82.5	83.5	83.1	81.1	78.5	75.4	73.2	74.0	77.0	79.2	80.5	81.9	
		MCDB	87.2	88.0	87.7	86.1	83.8	82.8	81.3	82.4	85.6	87.6	89.4	89.3	
10%		WB	81.5	82.3	81.7	79.9	77.4	73.9	71.9	73.0	75.7	78.2	79.5	81.1	
		MCDB	86.3	86.8	86.3	85.2	83.2	81.8	80.2	81.5	84.9	86.8	88.3	88.2	
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.4	10.7	12.8	16.7	19.4	21.4	20.8	17.8	15.7	14.8	13.0	
		MCDBR	12.5	12.6	12.5	14.3	17.0	19.1	21.5	21.5	19.0	16.8	15.7	15.4	
		MCWBR	5.3	6.8	5.8	5.2	6.1	7.7	8.0	7.7	5.9	5.7	5.2	5.2	
	5% WB	MCDBR	11.3	12.1	12.3	12.9	13.1	16.2	18.4	16.7	15.5	14.9	15.5	14.0	
		MCWBR	5.9	7.2	6.9	5.8	5.3	7.0	7.4	6.4	5.8	6.0	6.1	5.8	
Clear-Sky Solar Irradiance	taub	0.418	0.421	0.403	0.378	0.367	0.355	0.348	0.366	0.423	0.450	0.453	0.426		
	taud	2.512	2.494	2.546	2.601	2.592	2.570	2.584	2.516	2.370	2.317	2.347	2.471		
	Ebn at Noon	294	291	291	288	281	280	285	287	280	279	282	291		
	Edh at Noon	36	36	34	30	29	29	29	33	40	43	42	37		
All-Sky Solar Radiation	RadAvg	1661	1728	1749	1823	1710	1644	1722	1931	2102	2160	2047	1809		
	RadStd	173	239	206	158	93	55	44	56	83	93	77	167		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page