

CAPE DON, Australia

WMO: 941290

Lat: 11.3072S

Lon: 131.7660E

Elev: 66

StdP: 14.66

Time Zone: 9.50 (AUC)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	70.4	71.6	50.9	55.3	77.1	53.7	61.5	77.2	14.5	78.0	14.1	77.9	6.6	100	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	8.1	91.4	80.7	90.4	80.3	89.6	80.0	84.2	87.9	83.4	87.4	82.7	87.0	7.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.3	174.4	86.2	82.4	169.5	85.6	81.7	165.3	85.3	48.5	88.3	47.5	87.3	46.8	87.1	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.6	15.0	13.2	68.4	93.2	2.5	1.6	66.5	94.4	65.0	95.4	63.6	96.3	61.8	97.5		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.2	84.1	83.6	83.4	83.5	82.2	79.1	77.9	78.4	81.1	83.8	85.2	84.7	
	DBStd	3.12	2.09	1.93	1.85	1.85	2.03	2.62	2.10	1.75	1.69	1.58	1.69	2.29	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11767	1057	940	1035	1006	997	873	866	881	932	1048	1055	1077	
	CDD65	6292	592	520	570	556	532	423	401	416	482	583	605	612	
	CDH74	69229	7394	6281	6751	6541	5648	3470	2712	3024	4735	6991	7856	7826	
	CDH80	24381	3002	2325	2402	2382	1709	678	418	553	1265	2652	3566	3429	
Wind	WSAvg	6.3	8.0	8.2	6.0	5.3	6.4	6.8	6.4	5.8	5.6	5.3	5.1	6.6	
Precipitation	PrecAvg	62.6	13.5	13.2	10.7	5.4	1.6	0.2	0.2	0.1	0.4	1.6	4.5	11.2	
	PrecMax	82.7	26.0	23.3	19.8	15.6	6.7	1.5	0.6	0.4	2.3	6.5	7.2	22.3	
	PrecMin	42.0	4.9	5.6	5.1	0.5	0.3	0.1	0.0	0.0	0.0	0.0	1.0	2.8	
	PrecStd	12.0	4.7	4.6	3.9	4.1	1.4	0.2	0.2	0.1	0.6	1.4	1.6	4.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.6	90.8	91.8	91.9	90.0	87.5	86.8	87.3	89.6	91.5	92.4	92.7	
		MCWB	82.8	81.7	81.3	79.9	77.3	75.0	74.2	74.7	76.6	77.8	80.9	82.2	
	2%	DB	89.9	89.2	89.2	90.0	88.7	86.0	84.9	85.4	87.8	89.9	90.8	90.8	
		MCWB	81.9	81.3	81.0	79.7	77.5	73.8	73.7	74.0	77.3	77.8	80.5	81.3	
	5%	DB	88.6	88.1	88.1	88.7	87.6	84.8	83.5	84.1	86.5	88.8	89.8	89.6	
		MCWB	81.4	81.1	80.8	79.4	77.2	73.5	72.9	72.8	77.1	78.0	80.1	80.8	
	10%	DB	87.5	87.0	87.0	87.6	86.4	83.6	82.3	82.9	85.4	87.7	88.9	88.6	
		MCWB	81.1	80.8	80.5	79.0	76.6	73.1	72.2	72.2	76.8	78.1	79.7	80.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	84.5	84.2	84.4	84.4	83.2	78.0	79.4	80.6	83.7	82.8	84.8	85.5
			MCDB	89.3	87.1	88.1	87.3	85.7	83.1	82.4	84.1	85.8	86.6	88.0	90.9
2%		WB	83.3	83.3	83.3	83.0	81.7	77.1	77.7	78.8	81.7	81.3	83.1	83.5	
		MCDB	88.2	86.6	87.3	86.5	84.6	82.5	81.1	83.1	84.3	86.1	87.8	89.2	
5%		WB	82.6	82.6	82.6	82.2	80.4	76.3	76.2	77.3	80.1	80.4	81.9	82.3	
		MCDB	87.3	86.2	86.7	86.0	84.1	81.8	80.7	81.8	83.8	85.8	87.6	88.8	
10%		WB	81.9	81.9	81.9	81.4	79.2	75.5	75.0	75.9	78.9	79.7	81.1	81.6	
		MCDB	86.6	85.7	86.0	85.5	83.6	80.9	80.6	80.9	83.8	85.3	87.1	87.8	
Mean Daily Temperature Range	5% DB	MDBR	6.8	6.6	7.2	8.2	8.6	8.5	9.4	10.0	9.4	8.5	8.1	7.3	
		MCDBR	7.6	7.6	8.5	9.5	9.4	9.1	10.0	10.9	10.3	9.7	8.7	8.2	
		MCWBR	3.8	3.7	4.5	4.0	4.1	4.7	4.9	5.4	4.4	4.0	3.8	3.8	
	5% WB	MCDBR	7.5	7.5	8.3	8.7	8.4	8.1	8.9	10.2	9.1	9.2	8.7	8.5	
		MCWBR	4.2	4.0	4.4	4.4	4.0	4.8	5.1	5.2	4.8	4.2	4.7	4.3	
Clear-Sky Solar Irradiance	taub	0.414	0.405	0.395	0.379	0.376	0.363	0.358	0.369	0.409	0.424	0.428	0.408		
	taud	2.537	2.560	2.593	2.627	2.605	2.593	2.602	2.553	2.438	2.415	2.439	2.541		
	Ebn at Noon	295	295	293	288	279	278	283	287	285	287	289	296		
	Edh at Noon	35	34	32	30	29	28	29	32	37	39	38	35		
All-Sky Solar Radiation	RadAvg	1644	1699	1690	1759	1676	1625	1704	1918	2108	2180	2100	1776		
	RadStd	183	212	190	185	111	58	47	49	64	82	95	200		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page