

CAPE DON, Australia

WMO: 941290

Lat: 11.3072S

Lon: 131.7660E

Elev: 20

StdP: 101.08

Time Zone: 9.50 (AUC)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	22.0	10.5	7.9	25.0	12.1	8.8	25.1	6.5	25.5	6.3	25.5	2.9	100	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	4.5	33.0	27.1	32.4	26.9	32.0	26.7	29.0	31.1	28.5	30.8	28.2	30.6	3.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.5	24.9	30.1	28.0	24.2	29.8	27.6	23.6	29.6	94.9	31.3	92.6	30.7	90.9	30.6	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.9	6.7	5.9	DB	20.2	34.0	1.4	0.9	19.2	34.7	18.4	35.2	17.6	35.7	16.5	36.4	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	29.0	28.7	28.6	28.6	27.9	26.2	25.5	25.8	27.3	28.8	29.5	29.3
	DBStd	1.74	1.16	1.07	1.03	1.03	1.13	1.46	1.17	0.97	0.94	0.88	0.94	1.27
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6537	587	522	575	559	554	485	481	489	518	582	586	598
	CDD18.3	3496	329	289	317	309	296	235	223	231	268	324	336	340
	CDH23.3	38461	4108	3489	3751	3634	3138	1928	1507	1680	2631	3884	4364	4348
(13)	CDH26.7	13545	1668	1292	1334	1323	949	377	232	307	703	1473	1981	1905
(14) Wind	WSAvg	2.8	3.6	3.7	2.7	2.3	2.9	3.1	2.9	2.6	2.5	2.4	2.3	3.0
(15) Precipitation	PrecAvg	1590	342	335	271	136	41	6	5	3	11	41	115	284
	PrecMax	2100	661	592	503	397	169	37	16	11	59	164	182	566
	PrecMin	1068	125	143	130	12	7	2	1	0	1	1	26	70
	PrecStd	304	120	118	98	105	36	6	4	3	14	36	41	116
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	32.7	33.2	33.3	32.2	30.8	30.5	30.7	32.0	33.1	33.5	33.7
		MCWB	28.2	27.6	27.4	26.6	25.2	23.9	23.5	23.7	24.8	25.4	27.2	27.9
	2%	DB	32.2	31.8	31.8	32.2	31.5	30.0	29.4	29.6	31.0	32.2	32.7	32.7
		MCWB	27.7	27.4	27.2	26.5	25.3	23.2	23.2	23.3	25.2	25.5	27.0	27.4
	5%	DB	31.5	31.2	31.2	31.5	30.9	29.3	28.6	28.9	30.3	31.6	32.1	32.0
		MCWB	27.4	27.3	27.1	26.3	25.1	23.1	22.7	22.7	25.0	25.5	26.7	27.1
	10%	DB	30.9	30.6	30.6	30.9	30.2	28.7	28.0	28.3	29.7	31.0	31.6	31.4
		MCWB	27.3	27.1	26.9	26.1	24.8	22.8	22.3	22.4	24.9	25.6	26.5	27.0
	0.4%	WB	29.2	29.0	29.1	29.1	28.4	25.6	26.3	27.0	28.7	28.2	29.3	29.7
		MCDB	31.9	30.6	31.2	30.7	29.8	28.4	28.0	28.9	29.9	30.4	31.1	32.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	28.5	28.5	28.5	28.4	27.6	25.0	25.4	26.0	27.6	27.4	28.4	28.6
		MCDB	31.2	30.3	30.7	30.3	29.2	28.1	27.3	28.4	29.1	30.1	31.0	31.8
	5%	WB	28.1	28.1	28.1	27.9	26.9	24.6	24.6	25.2	26.7	26.9	27.7	27.9
		MCDB	30.7	30.1	30.4	30.0	28.9	27.6	27.1	27.7	28.8	29.9	30.9	31.6
	10%	WB	27.7	27.7	27.7	27.4	26.2	24.2	23.9	24.4	26.1	26.5	27.3	27.5
		MCDB	30.3	29.9	30.0	29.7	28.7	27.2	27.0	27.2	28.8	29.6	30.6	31.0
(35) Mean Daily Temperature Range	5% DB	MDBR	3.8	3.7	4.0	4.6	4.8	4.7	5.2	5.5	5.2	4.7	4.5	4.1
		MCDBR	4.2	4.2	4.7	5.3	5.2	5.1	5.6	6.1	5.7	5.4	4.8	4.6
		MCWBR	2.1	2.0	2.5	2.2	2.3	2.6	2.7	3.0	2.5	2.2	2.1	2.1
	5% WB	MCDBR	4.1	4.2	4.6	4.8	4.7	4.5	4.9	5.7	5.1	5.1	4.8	4.7
		MCWBR	2.3	2.2	2.5	2.4	2.2	2.6	2.8	2.9	2.7	2.4	2.6	2.4
(40) Clear-Sky Solar Irradiance	taub		0.414	0.405	0.395	0.379	0.376	0.363	0.358	0.369	0.409	0.424	0.428	0.408
	taud		2.537	2.560	2.593	2.627	2.605	2.593	2.602	2.553	2.438	2.415	2.439	2.541
	Ebn at Noon		929	931	924	909	881	877	891	906	897	904	910	933
	Edh at Noon		111	108	102	94	91	89	90	100	117	123	121	110
(44) All-Sky Solar Radiation	RadAvg		5.18	5.36	5.33	5.54	5.28	5.12	5.37	6.04	6.65	6.87	6.62	5.60
(45)	RadStd		0.58	0.67	0.60	0.58	0.35	0.18	0.15	0.16	0.20	0.26	0.30	0.63

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page