

BRADSHAW, Australia

WMO: 941300

Lat: 14.941S

Lon: 130.809E

Elev: 249

StdP: 14.56

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	53.9	57.1	12.6	10.6	82.8	17.8	13.6	79.2	16.8	81.1	16.2	80.1	2.6	350	0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	22.5	103.7	70.8	102.1	71.2	100.6	71.8	82.0	92.3	80.8	91.0	80.0	89.6	8.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.6	155.0	86.2	78.5	149.3	84.4	77.8	145.7	83.7	46.1	92.1	44.7	91.5	43.8	90.1	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.4	15.3	13.8	48.4	106.9	2.8	1.5	46.4	108.0	44.7	108.9	43.1	109.8	41.0	110.9		
(5)			39.4	83.5	1.9	2.2	38.1	85.1	37.0	86.4	35.9	87.7	34.5	89.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	83.4	85.8	85.5	85.7	84.7	79.9	74.8	75.4	77.8	85.3	89.2	89.2	87.7	(6)
(7)		DBStd	6.34	3.37	3.36	2.99	3.39	4.88	5.71	4.99	4.68	3.83	2.80	3.27	3.65	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	4	0	0	0	0	0	3	1	0	0	0	0	0	(9)
(10)		CDD50	12190	1111	993	1106	1040	928	745	787	861	1060	1215	1175	1169	(10)
(11)		CDD65	6718	646	573	641	590	463	297	323	396	610	750	725	704	(11)
(12)		CDH74	87215	7992	6888	7883	7684	5598	3375	3740	4873	8589	11096	10200	9297	(12)
(13)		CDH80	47381	3957	3363	4020	4243	2869	1490	1715	2505	5066	6889	6112	5152	(13)
(14)	Wind	WSAvg	6.4	6.4	5.8	5.7	6.2	6.4	6.3	6.5	7.2	7.3	6.8	6.2	(14)	
(15)	Precipitation	PrecAvg	56.3	13.5	12.2	8.9	2.6	0.6	0.1	0.1	0.0	0.4	1.9	5.5	10.5	(15)
(16)		PrecMax	77.6	23.7	24.1	21.8	15.7	3.1	0.6	0.3	0.6	2.4	6.2	9.0	20.9	(16)
(17)		PrecMin	35.5	6.4	6.3	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.1	3.1	3.1	(17)
(18)		PrecStd	10.0	4.8	4.6	5.0	3.2	0.8	0.1	0.1	0.1	0.5	1.5	1.5	4.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.1	101.6	102.0	100.4	97.6	94.9	94.4	97.6	102.1	105.6	105.9	105.5	(19)
(20)			MCWB	75.7	76.6	75.2	71.9	70.8	68.3	67.0	67.2	68.0	68.1	70.5	72.1	(20)
(21)		2%	DB	98.8	99.4	99.6	98.7	95.5	92.4	92.4	95.3	100.3	103.5	103.4	102.1	(21)
(22)			MCWB	77.9	77.4	74.5	71.2	69.2	67.1	65.5	66.1	67.6	68.1	71.4	75.0	(22)
(23)		5%	DB	96.8	97.1	97.7	97.1	94.0	90.5	90.7	93.3	98.9	101.9	101.6	99.7	(23)
(24)			MCWB	77.9	77.5	74.1	70.8	68.4	66.3	64.7	64.6	67.4	68.6	71.9	76.1	(24)
(25)		10%	DB	94.4	94.5	95.5	95.6	92.2	88.3	88.9	91.4	97.4	100.3	99.4	97.2	(25)
(26)			MCWB	78.2	77.6	75.0	70.6	67.6	64.4	63.5	63.2	66.9	69.1	73.1	76.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.4	84.1	83.6	79.4	78.3	72.7	72.4	72.7	75.6	77.7	79.9	81.8	(27)
(28)			MCD B	94.2	93.8	92.4	87.6	86.9	83.1	87.6	88.7	88.3	88.5	91.4	92.3	(28)
(29)		2%	WB	81.6	81.7	81.5	78.1	76.6	70.4	69.7	71.0	74.6	76.7	78.9	80.6	(29)
(30)			MCD B	92.3	92.2	90.8	86.9	85.0	86.4	86.8	86.0	87.3	87.5	90.5	91.7	(30)
(31)		5%	WB	80.5	80.2	80.1	77.1	74.7	69.0	67.7	69.3	73.6	75.9	78.1	79.8	(31)
(32)			MCD B	90.7	89.8	88.9	85.9	85.7	86.2	86.3	85.3	87.1	87.3	89.5	90.3	(32)
(33)		10%	WB	79.7	79.2	79.1	76.0	72.4	67.4	65.7	67.3	72.5	75.0	77.3	79.0	(33)
(34)			MCD B	88.9	87.9	86.8	86.0	86.9	85.0	85.1	85.5	87.4	87.1	88.5	89.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.8	16.4	18.2	21.8	23.6	25.1	25.8	26.5	24.1	22.5	20.4	17.9	(35)
(36)			MCDBR	19.5	20.9	22.8	23.3	24.0	24.4	25.4	26.5	24.7	24.6	22.9	21.5	(36)
(37)			MCWBR	5.5	6.9	6.0	5.9	7.6	8.4	9.3	9.7	8.5	8.2	6.6	5.6	(37)
(38)		5% WB	MCD BR	16.6	17.2	16.9	18.6	17.8	21.7	22.3	23.0	21.3	20.7	19.8	17.9	(38)
(39)			MCWBR	6.1	7.5	7.1	6.6	7.6	7.4	8.4	8.2	7.4	6.7	5.8	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.414	0.410	0.400	0.373	0.363	0.336	0.335	0.348	0.421	0.452	0.463	0.431	(40)	
(41)		taud	2.478	2.485	2.504	2.539	2.506	2.536	2.524	2.463	2.290	2.239	2.265	2.410	(41)	
(42)		Ebn at Noon	295	294	291	288	280	283	286	291	280	279	279	290	(42)	
(43)		Edh at Noon	37	37	35	32	31	29	30	34	43	47	46	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1887	1877	1898	1882	1714	1629	1722	1945	2110	2170	2108	1979	(44)	
(45)		RadStd	174	253	203	126	96	76	56	63	107	116	92	151	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page