

BRADSHAW, Australia

WMO: 941300

Lat: 14.941S

Lon: 130.809E

Elev: 76

StdP: 100.42

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.2	13.9	-10.8	1.5	28.2	-7.9	1.9	26.2	7.5	27.3	7.2	26.7	1.2	350	0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	12.5	39.8	21.6	39.0	21.8	38.1	22.1	27.8	33.5	27.1	32.8	26.6	32.0	4.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.1	30.1	25.8	21.3	29.1	25.4	20.8	28.7	89.4	33.4	86.1	33.0	84.0	32.3	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.8	6.2	9.1	41.6	1.6	0.8	8.0	42.2	7.1	42.7	6.2	43.2	5.0	43.8		
(5)			4.1	28.6	1.1	1.2	3.4	29.5	2.8	30.2	2.2	30.9	1.4	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	29.9	29.7	29.8	29.3	26.6	23.8	24.1	25.4	29.6	31.8	31.8	31.0
	DBStd	3.52	1.87	1.87	1.66	1.88	2.71	3.17	2.77	2.60	2.13	1.55	1.82	2.03
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	0	0	0	0	0	2	1	0	0	0	0	0
	CDD10.0	6772	617	552	614	578	516	414	437	478	589	675	653	649
	CDD18.3	3732	359	318	356	328	257	165	179	220	339	417	403	391
	CDH23.3	48453	4440	3827	4379	4269	3110	1875	2078	2707	4772	6164	5667	5165
	CDH26.7	26323	2198	1868	2233	2357	1594	828	953	1392	2814	3827	3396	2862
Wind	WSAvg	2.9	2.9	2.6	2.6	2.8	2.9	2.8	2.8	2.9	3.2	3.3	3.1	2.8
Precipitation	PrecAvg	1431	343	311	227	67	15	2	2	1	9	49	139	267
	PrecMax	1970	602	612	553	398	79	15	7	14	61	158	228	532
	PrecMin	901	163	159	41	0	1	0	0	0	0	2	79	79
	PrecStd	254	123	118	128	81	20	3	2	3	13	38	38	104
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.0	38.7	38.9	38.0	36.5	34.9	34.7	36.4	38.9	40.9	41.1	40.8
		MCWB	24.3	24.8	24.0	22.1	21.6	20.1	19.5	19.6	20.0	20.1	21.4	22.3
	2%	DB	37.1	37.4	37.5	37.0	35.3	33.6	33.6	35.2	37.9	39.7	39.7	38.9
		MCWB	25.5	25.2	23.6	21.8	20.7	19.5	18.6	18.9	19.8	20.1	21.9	23.9
	5%	DB	36.0	36.2	36.5	36.2	34.4	32.5	32.6	34.1	37.2	38.9	38.7	37.6
		MCWB	25.5	25.3	23.4	21.5	20.2	19.1	18.1	18.1	19.6	20.3	22.2	24.5
	10%	DB	34.7	34.7	35.3	35.3	33.5	31.3	31.6	33.0	36.3	37.9	37.5	36.2
		MCWB	25.7	25.4	23.9	21.5	19.8	18.0	17.5	17.3	19.4	20.6	22.9	24.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.6	28.9	28.7	26.3	25.7	22.6	22.5	22.6	24.2	25.4	26.6	27.7
		MCDB	34.6	34.4	33.5	30.9	30.5	28.4	30.9	31.5	31.3	31.4	33.0	33.5
	2%	WB	27.6	27.6	27.5	25.6	24.8	21.3	20.9	21.6	23.7	24.9	26.0	27.0
		MCDB	33.5	33.4	32.7	30.5	29.4	30.2	30.4	30.0	30.7	30.8	32.5	33.2
	5%	WB	27.0	26.8	26.7	25.0	23.7	20.6	19.9	20.7	23.1	24.4	25.6	26.5
		MCDB	32.6	32.1	31.6	30.0	29.8	30.1	30.1	29.6	30.6	30.7	32.0	32.4
	10%	WB	26.5	26.2	26.2	24.4	22.5	19.7	18.7	19.6	22.5	23.9	25.1	26.1
		MCDB	31.6	31.1	30.5	30.0	30.5	29.4	29.5	29.7	30.8	30.6	31.4	31.7
Mean Daily Temperature Range	5% DB	MDBR	8.8	9.1	10.1	12.1	13.1	14.0	14.3	14.7	13.4	12.5	11.3	10.0
		MCDBR	10.8	11.6	12.7	12.9	13.4	13.5	14.1	14.7	13.7	13.7	12.7	12.0
		MCWBR	3.1	3.8	3.3	3.3	4.2	4.7	5.2	5.4	4.7	4.6	3.6	3.1
	5% WB	MCDBR	9.2	9.6	9.4	10.4	9.9	12.1	12.4	12.8	11.8	11.5	11.0	9.9
		MCWBR	3.4	4.2	3.9	3.6	4.2	4.1	4.6	4.6	4.1	3.7	3.2	3.1
Clear-Sky Solar Irradiance	taub	0.414	0.410	0.400	0.373	0.363	0.336	0.335	0.348	0.421	0.452	0.463	0.431	
	taud	2.478	2.485	2.504	2.539	2.506	2.536	2.524	2.463	2.290	2.239	2.265	2.410	
	Ebn at Noon	931	927	916	907	883	892	903	918	883	878	880	915	
	Edh at Noon	118	116	111	101	98	92	95	107	135	147	145	126	
All-Sky Solar Radiation	RadAvg	5.95	5.92	5.98	5.93	5.40	5.14	5.43	6.13	6.65	6.84	6.64	6.24	
	RadStd	0.55	0.80	0.64	0.40	0.30	0.24	0.18	0.20	0.34	0.36	0.29	0.48	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page