

MCCLUER ISLAND, Australia

WMO: 941350

Lat: 11.047S

Lon: 132.979E

Elev: 2

StdP: 101.30

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	22.6	11.7	8.6	23.8	13.7	9.8	24.2	13.0	24.7	12.4	24.8	7.1	130	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.3	32.5	27.0	32.0	26.8	31.6	26.7	29.2	30.3	28.4	30.2	27.7	30.1	4.4	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.9	25.5	30.0	28.0	24.1	29.6	27.2	22.9	29.3	95.9	30.2	92.1	30.0	88.8	30.2	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	11.7	10.9	DB	20.4	33.3	1.5	0.4	19.4	33.6	18.5	33.8	17.7	34.0	16.6	34.3	(4)
(5)			WB	14.3	28.7	1.5	1.1	13.2	29.5	12.3	30.1	11.4	30.7	10.3	31.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	29.0	28.7	28.8	28.6	27.4	25.6	25.0	25.4	26.8	28.1	29.5	29.8	(6)	
	DBStd	1.90	1.08	1.09	1.08	0.99	1.04	1.41	1.04	0.90	0.88	0.88	0.85	1.16	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6464	589	524	581	558	538	468	466	477	503	562	584	612	(10)	
	CDD18.3	3423	331	291	323	308	280	218	208	219	253	304	334	354	(11)	
	CDH23.3	38567	4217	3603	4025	3872	3091	1784	1409	1574	2419	3481	4348	4744	(12)	
	CDH26.7	12990	1763	1396	1586	1507	788	182	44	63	359	1066	1957	2279	(13)	
(14) Wind	WSAvg	6.5	6.8	6.5	5.4	6.2	7.8	7.9	7.9	7.4	6.2	5.8	4.7	5.2	(14)	
(15) Precipitation	PrecAvg	1343	313	243	250	147	41	7	2	0	3	8	66	231	(15)	
	PrecMax	1932	645	510	497	408	249	72	22	1	32	56	206	486	(16)	
	PrecMin	502	79	83	57	24	0	0	0	0	0	0	6	35	(17)	
	PrecStd	359	138	109	127	100	63	16	5	0	7	12	43	127	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	32.4	32.2	32.1	30.7	29.4	28.2	28.5	29.9	31.2	32.7	33.2	(19)	
		MCWB	27.1	27.1	27.1	27.1	26.0	24.7	22.9	23.1	24.8	25.7	27.2	27.3	(20)	
	2%	DB	31.9	31.7	31.6	31.4	30.0	28.7	27.6	27.8	29.2	30.7	32.2	32.6	(21)	
		MCWB	26.8	26.9	26.9	26.5	25.4	24.4	22.9	23.1	24.5	25.6	26.8	27.0	(22)	
	5%	DB	31.4	31.1	31.1	30.8	29.5	28.2	27.1	27.4	28.7	30.2	31.6	32.1	(23)	
		MCWB	26.8	26.7	26.7	26.2	25.2	24.1	22.9	22.9	24.4	25.5	26.5	26.7	(24)	
	10%	DB	30.8	30.6	30.6	30.4	29.1	27.7	26.7	27.0	28.3	29.7	31.1	31.6	(25)	
		MCWB	26.7	26.6	26.5	26.1	25.1	23.8	22.8	22.7	24.2	25.4	26.2	26.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.5	28.0	28.6	29.2	27.4	26.6	25.8	24.7	26.1	27.2	29.5	30.6	(27)	
		MCDB	30.4	30.6	30.6	30.9	29.0	27.2	26.2	26.8	28.4	29.2	30.2	31.4	(28)	
	2%	WB	27.8	27.6	28.0	28.1	26.7	25.9	24.8	24.3	25.6	26.6	28.7	29.6	(29)	
		MCDB	30.2	30.2	30.2	30.0	28.8	27.1	26.3	26.6	28.0	29.0	29.9	30.4	(30)	
	5%	WB	27.5	27.3	27.5	27.4	26.4	25.3	24.2	24.0	25.2	26.2	28.0	28.8	(31)	
		MCDB	30.0	29.8	30.0	29.6	28.6	27.2	26.2	26.5	27.7	28.9	29.7	30.1	(32)	
	10%	WB	27.2	27.1	27.2	26.9	26.0	24.8	23.8	23.6	24.8	26.0	27.2	27.4	(33)	
		MCDB	29.9	29.6	29.8	29.4	28.4	27.2	26.1	26.3	27.5	28.8	30.1	30.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.3	3.3	3.4	3.2	3.0	3.1	3.0	3.1	3.1	3.1	3.3	3.3	(35)	
		MCDBR	3.7	3.7	3.7	3.6	3.2	3.1	3.2	3.3	3.4	3.5	3.8	3.7	(36)	
		MCWBR	1.7	1.7	1.9	1.8	2.0	2.3	2.4	2.1	1.6	1.6	1.7	1.6	(37)	
	5% WB	MCDBR	3.4	3.4	3.5	3.3	2.7	2.6	2.6	2.9	3.0	3.0	3.7	3.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.416	0.406	0.394	0.384	0.384	0.371	0.362	0.369	0.403	0.422	0.420	0.405	(40)	
		taud	2.539	2.564	2.605	2.622	2.592	2.592	2.611	2.567	2.457	2.418	2.464	2.554	(41)	
	Ebn at Noon		927	931	926	905	874	871	888	906	902	905	917	935	(42)	
		Edh at Noon	111	108	101	95	92	90	98	98	115	123	118	109	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.22	5.40	5.27	5.42	5.21	5.00	5.29	6.07	6.69	6.99	6.82	5.74	(44)	
	RadStd		0.64	0.73	0.59	0.65	0.38	0.23	0.18	0.17	0.20	0.27	0.30	0.68	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.40	N/A	N/A	N/A	N/A	-0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page