

JABIRU, Australia

WMO: 941370

Lat: 12.6594S

Lon: 132.8939E

Elev: 92

StdP: 14.65

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	62.5	64.9	33.5	28.2	84.3	37.7	33.3	81.0	16.5	85.1	15.3	84.8	2.6	120	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	22.5	100.0	72.0	98.5	72.3	97.2	72.7	81.2	88.4	80.6	88.1	80.0	87.3	8.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.8	155.1	83.0	79.1	151.3	82.5	78.4	148.1	82.2	45.1	88.9	44.4	88.3	43.7	87.5	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.8	13.5	12.0	57.0	103.1	2.9	1.7	54.9	104.3	53.3	105.3	51.6	106.2	49.6	107.5		
(5)			49.6	82.6	1.6	0.9	48.5	83.3	47.5	83.8	46.6	84.3	45.4	85.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.1	83.8	83.7	84.2	84.2	81.8	78.5	78.1	79.6	83.9	87.1	87.2	85.6		
	DBStd	3.99	2.62	2.63	2.29	2.22	3.02	3.65	3.00	2.89	2.49	2.04	2.27	2.94		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	12094	1049	943	1059	1026	987	856	873	916	1016	1150	1116	1103		
	CDD65	6619	584	523	594	576	522	406	408	451	566	685	666	638		
	CDH74	77053	6352	5561	6616	6890	5826	3982	4116	5138	7251	9153	8538	7630		
	CDH80	36934	2602	2189	2811	3293	2624	1597	1767	2533	4054	5203	4617	3644		
(14) Wind	WSAvg	5.1	4.7	4.2	4.1	4.7	5.5	5.9	5.9	5.6	5.4	5.4	4.8	4.5		
(15) Precipitation	PrecAvg	61.8	14.4	14.8	10.4	3.4	0.9	0.1	0.1	0.0	0.6	1.6	5.2	10.1		
	PrecMax	92.8	27.1	34.9	30.7	13.8	4.3	1.9	1.3	0.9	8.5	11.3	8.5	18.3		
	PrecMin	42.2	5.5	5.9	5.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	1.5	2.3		
	PrecStd	13.7	6.1	6.1	5.4	3.6	1.1	0.4	0.3	0.2	1.6	2.5	1.8	3.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.6	96.0	96.5	96.9	94.9	92.8	93.1	96.0	99.8	102.2	102.1	100.2		
		MCWB	78.7	78.3	76.1	73.3	72.7	71.0	69.1	69.1	68.8	70.4	71.7	75.7		
	2%	DB	94.6	94.3	94.8	95.3	93.3	90.9	91.3	94.0	98.0	100.2	99.7	97.6		
		MCWB	79.1	78.7	76.1	73.4	72.3	70.3	68.2	67.9	68.5	70.8	73.6	77.1		
	5%	DB	92.9	92.7	93.4	94.0	91.9	89.5	89.9	92.4	96.7	98.7	98.0	95.7		
		MCWB	79.3	79.0	76.5	73.3	72.0	69.8	67.6	67.1	68.5	71.1	74.4	77.5		
	10%	DB	90.8	90.6	91.6	92.6	90.6	88.0	88.4	90.8	95.2	97.2	96.1	93.6		
		MCWB	79.2	78.9	77.4	73.4	71.6	68.9	66.8	66.3	68.6	71.6	75.3	77.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.4	82.0	81.6	79.8	78.0	75.2	73.9	73.8	76.5	78.5	80.4	81.0		
		MCDB	90.4	87.9	87.7	86.5	86.6	85.2	84.8	85.9	87.1	88.7	89.1	89.2		
	2%	WB	81.1	81.1	80.5	78.8	76.8	73.9	72.3	72.7	75.4	77.4	79.5	80.2		
		MCDB	89.0	87.7	87.1	85.8	85.5	84.3	84.5	84.7	86.6	87.5	88.7	88.6		
	5%	WB	80.4	80.5	79.9	78.1	75.9	72.7	71.0	71.7	74.5	76.8	78.8	79.7		
		MCDB	88.2	87.4	86.3	85.0	84.7	83.8	83.9	84.0	85.9	86.9	88.4	88.0		
	10%	WB	79.8	79.9	79.2	77.4	75.0	71.5	69.7	70.5	73.6	76.2	78.1	79.2		
		MCDB	87.1	86.3	85.5	84.2	84.0	83.7	82.8	83.3	85.2	86.6	87.6	87.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	13.5	14.6	17.5	18.3	19.3	21.3	23.5	24.4	22.5	19.8	16.0		
		MCDBR	16.8	16.9	17.8	19.4	19.2	19.8	22.3	24.7	25.8	24.1	21.9	19.1		
	5% WB	MCWBR	4.8	4.5	4.5	4.7	4.8	5.7	6.0	6.1	6.1	5.5	4.8	4.5		
		MCWBR	14.7	14.4	14.3	15.4	16.3	18.0	19.7	21.5	22.0	20.5	18.6	15.9		
(40) Clear-Sky Solar Irradiance	taub		0.413	0.404	0.399	0.375	0.360	0.346	0.339	0.351	0.412	0.441	0.447	0.421		
	taud		2.494	2.517	2.524	2.574	2.580	2.563	2.573	2.514	2.349	2.296	2.326	2.451		
	Ebn at Noon		295	296	292	289	283	282	287	292	283	282	283	292		
	Edh at Noon		37	36	35	31	29	29	29	33	41	44	43	38		
(44) All-Sky Solar Radiation	RadAvg		1720	1769	1783	1838	1714	1638	1724	1947	2133	2194	2075	1877		
	RadStd		183	246	206	167	99	64	52	68	99	110	76	155		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+0.72	N/A	N/A	N/A	N/A	-0.85	N/A	N/A	N/A	N/A
Regional (8 neighbors)		+0.72	N/A	N/A	N/A	N/A	-0.85	N/A	N/A	N/A	N/A

Nomenclature: See separate page