

JABIRU, Australia

WMO: 941370

Lat: 12.6594S

Lon: 132.8939E

Elev: 28

StdP: 100.99

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	18.3	0.8	4.0	29.1	3.2	4.8	27.2	7.4	29.5	6.8	29.3	1.2	120	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	12.5	37.8	22.2	37.0	22.4	36.2	22.6	27.3	31.4	27.0	31.2	26.7	30.7	3.7	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.6	22.2	28.3	26.1	21.6	28.1	25.8	21.2	27.9	87.0	31.6	85.3	31.3	83.9	30.8	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	6.0	5.4	13.9	39.5	1.6	0.9	12.7	40.2	11.8	40.7	10.9	41.2	9.8	41.9 (4)		
(5)			9.8	28.1	0.9	0.5	9.1	28.5	8.6	28.8	8.1	29.1	7.4	29.4 (5)		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	28.8	28.7	29.0	29.0	27.7	25.8	25.6	26.4	28.8	30.6	30.7	29.8
	DBStd	2.22	1.45	1.46	1.27	1.23	1.68	2.03	1.67	1.61	1.38	1.13	1.26	1.64
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6719	583	524	588	570	548	476	485	509	564	639	620	613
	CDD18.3	3677	324	291	330	320	290	226	227	251	314	381	370	354
	CDH23.3	42807	3529	3089	3676	3828	3237	2212	2287	2854	4028	5085	4743	4239
	CDH26.7	20519	1446	1216	1562	1829	1458	887	982	1407	2252	2891	2565	2024
Wind	WSAvg	2.3	2.1	1.9	1.8	2.1	2.4	2.6	2.6	2.5	2.4	2.4	2.1	2.0
Precipitation	PrecAvg	1569	365	376	265	87	23	3	2	1	14	40	133	257
	PrecMax	2358	688	887	780	350	109	49	33	22	216	287	217	466
	PrecMin	1072	139	150	132	0	2	0	0	0	0	0	39	58
	PrecStd	347	155	155	138	91	29	9	7	4	41	63	45	95
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	35.6	35.8	36.1	35.0	33.8	33.9	35.6	37.7	39.0	38.9	37.9
		MCWB	26.0	25.7	24.5	23.0	22.6	21.6	20.6	20.6	20.4	21.3	22.1	24.3
	2%	DB	34.8	34.6	34.9	35.2	34.1	32.7	32.9	34.5	36.7	37.9	37.6	36.5
		MCWB	26.1	25.9	24.5	23.0	22.4	21.3	20.1	20.0	20.3	21.6	23.1	25.1
	5%	DB	33.8	33.7	34.1	34.4	33.3	32.0	32.1	33.6	35.9	37.1	36.6	35.4
		MCWB	26.3	26.1	24.7	22.9	22.2	21.0	19.8	19.5	20.3	21.7	23.6	25.3
	10%	DB	32.7	32.6	33.1	33.7	32.5	31.1	31.3	32.7	35.1	36.2	35.6	34.2
		MCWB	26.2	26.1	25.2	23.0	22.0	20.5	19.3	19.0	20.3	22.0	24.1	25.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	27.8	27.6	26.6	25.6	24.0	23.3	23.2	24.7	25.8	26.9	27.2
		MCDB	32.5	31.1	30.9	30.3	30.3	29.6	29.3	29.9	30.6	31.5	31.7	31.8
	2%	WB	27.3	27.3	27.0	26.0	24.9	23.3	22.4	22.6	24.1	25.2	26.4	26.8
		MCDB	31.7	30.9	30.6	29.9	29.7	29.1	29.2	29.3	30.3	30.8	31.5	31.5
	5%	WB	26.9	27.0	26.6	25.6	24.4	22.6	21.7	22.0	23.6	24.9	26.0	26.5
		MCDB	31.2	30.8	30.2	29.4	29.3	28.8	28.9	28.9	30.0	30.5	31.3	31.1
	10%	WB	26.6	26.6	26.2	25.2	23.9	22.0	21.0	21.4	23.1	24.5	25.6	26.2
		MCDB	30.6	30.2	29.7	29.0	28.9	28.7	28.2	28.5	29.6	30.3	30.9	30.6
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.5	8.1	9.7	10.2	10.7	11.8	13.0	13.6	12.5	11.0	8.9
		MCDBR	9.3	9.4	9.9	10.8	10.7	11.0	12.4	13.7	14.3	13.4	12.2	10.6
		MCWBR	2.7	2.5	2.5	2.6	2.7	3.2	3.3	3.4	3.4	3.0	2.7	2.5
	5% WB	MCDBR	8.2	8.0	7.9	8.6	9.0	10.0	11.0	11.9	12.2	11.4	10.3	8.8
		MCWBR	2.8	2.8	2.5	2.3	2.4	2.9	3.2	3.1	2.8	2.6	2.7	2.6
Clear-Sky Solar Irradiance	taub	0.413	0.404	0.399	0.375	0.360	0.346	0.339	0.351	0.412	0.441	0.447	0.421	
	taud	2.494	2.517	2.524	2.574	2.580	2.563	2.573	2.514	2.349	2.296	2.326	2.451	
	Ebn at Noon	931	933	919	911	893	890	905	920	893	888	893	922	
	Edh at Noon	116	113	109	99	92	91	92	103	128	139	136	121	
All-Sky Solar Radiation	RadAvg	5.42	5.58	5.62	5.79	5.40	5.16	5.44	6.14	6.72	6.92	6.54	5.92	
	RadStd	0.58	0.78	0.65	0.53	0.31	0.20	0.17	0.21	0.31	0.35	0.24	0.49	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	N/A	N/A	N/A	-0.47	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.40	N/A	N/A	N/A	N/A	-0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page