

CENTRAL ARNHAM PLATEAU, Australia

WMO: 941410

Lat: 13.328S

Lon: 133.086E

Elev: 1366

StdP: 13.98

Time Zone: 9.50 (AUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	55.9	58.6	25.9	20.9	76.2	29.1	24.3	76.4	21.0	72.4	19.9	72.7	6.2	120	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	18.5	96.7	66.9	95.2	67.3	93.8	67.5	75.6	85.1	75.0	84.2	74.5	83.4	10.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.1	129.2	79.2	72.6	127.1	78.9	72.0	124.6	78.5	40.1	85.6	39.6	84.7	39.1	83.5	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	17.2	15.8	50.7	99.4	2.0	1.7	49.3	100.7	48.1	101.7	47.0	102.7	45.6	103.9		
(5)			43.0	77.4	1.8	1.0	41.7	78.2	40.6	78.8	39.6	79.4	38.3	80.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	78.8	80.8	80.9	81.2	80.0	76.7	72.2	72.1	73.6	79.1	83.1	83.9	82.6	(6)
(7)		DBStd	5.08	2.71	2.66	2.63	2.47	3.39	4.13	3.57	3.52	3.36	2.59	2.59	3.00	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	5	0	0	0	0	0	3	2	0	0	0	0	0	(9)
(10)		CDD50	10519	954	865	968	899	827	666	685	731	872	1025	1018	1009	(10)
(11)		CDD65	5050	489	445	503	449	362	219	222	267	422	560	568	544	(11)
(12)		CDH74	50835	4315	3974	4765	4384	3018	1553	1775	2716	4947	7025	6732	5631	(12)
(13)		CDH80	21085	1518	1462	1883	1770	956	333	409	935	2383	3680	3339	2417	(13)
(14)	Wind	WSAvg	8.1	8.1	7.6	7.2	8.3	9.3	9.5	9.3	8.2	7.8	7.7	7.0	6.8	(14)
(15)	Precipitation	PrecAvg	47.5	10.5	10.7	8.3	2.6	0.6	0.3	0.2	0.4	1.2	3.8	8.7		(15)
(16)		PrecMax	72.4	17.2	19.8	18.9	11.9	2.1	0.9	0.9	1.0	3.5	5.7	8.4	13.8	(16)
(17)		PrecMin	31.9	4.3	4.3	1.6	0.1	0.1	0.1	0.0	0.0	0.0	0.0	1.3	3.5	(17)
(18)		PrecStd	10.9	3.8	4.1	4.6	2.6	0.5	0.2	0.2	0.2	0.6	1.3	1.5	3.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.9	93.8	94.5	92.7	89.7	87.7	87.5	91.3	95.4	98.4	98.6	98.3	(19)
(20)			MCWB	71.7	69.2	69.5	68.2	68.0	65.3	64.9	63.9	63.7	65.9	66.6	69.0	(20)
(21)		2%	DB	91.8	91.8	92.6	91.2	88.0	85.4	85.6	88.8	93.5	96.5	96.5	95.0	(21)
(22)			MCWB	72.3	70.8	69.4	68.0	67.7	65.1	63.6	63.2	64.0	65.7	67.3	70.9	(22)
(23)		5%	DB	89.9	90.2	90.9	90.0	86.7	83.6	84.0	87.0	92.1	95.0	95.0	92.7	(23)
(24)			MCWB	72.9	71.8	69.8	68.1	67.2	64.6	62.8	62.1	63.7	66.0	67.8	71.3	(24)
(25)		10%	DB	87.7	88.2	89.1	88.4	85.2	81.9	82.5	85.3	90.6	93.5	93.3	90.6	(25)
(26)			MCWB	73.4	72.5	70.5	68.1	66.8	63.5	62.0	61.1	63.4	65.7	68.3	71.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.3	76.0	76.1	74.4	72.9	69.3	69.3	69.1	71.8	73.1	75.1	75.7	(27)
(28)			MADB	87.4	85.6	84.7	81.9	82.2	81.0	79.5	81.6	81.5	84.0	85.3	86.7	(28)
(29)		2%	WB	75.7	75.2	75.1	73.4	72.0	68.0	67.7	67.2	70.6	72.0	73.8	74.9	(29)
(30)			MADB	85.2	84.5	83.4	81.3	80.8	79.5	78.9	79.8	81.6	82.6	83.9	85.1	(30)
(31)		5%	WB	74.9	74.6	74.4	72.7	70.9	67.0	66.1	65.7	69.4	71.4	73.2	74.4	(31)
(32)			MADB	84.1	83.4	82.4	80.7	79.9	78.7	79.2	80.0	81.4	82.1	83.2	84.3	(32)
(33)		10%	WB	74.4	74.0	73.8	71.9	69.9	65.9	64.7	64.2	68.2	70.7	72.5	73.8	(33)
(34)			MADB	83.0	82.4	81.4	80.1	79.3	77.8	77.4	79.9	80.4	82.2	82.8	83.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.9	13.5	14.5	16.6	17.2	18.9	20.6	23.2	23.3	21.5	18.5	15.2	(35)
(36)			MCDBR	16.4	16.8	18.2	18.9	17.9	19.2	21.5	24.5	24.4	23.3	20.9	18.4	(36)
(37)			MCWBR	4.4	4.2	4.9	4.5	4.7	6.3	6.7	7.7	7.0	6.1	5.5	4.6	(37)
(38)		5% WB	MCDDBR	13.2	13.5	13.3	13.7	14.3	17.2	17.9	20.8	19.1	19.2	17.5	15.2	(38)
(39)			MCWBR	4.4	4.3	4.3	3.8	3.7	5.6	6.3	7.3	5.2	5.1	4.7	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.390	0.384	0.378	0.354	0.341	0.325	0.318	0.326	0.384	0.412	0.424	0.404	(40)	
(41)		taud	2.541	2.554	2.566	2.612	2.597	2.585	2.601	2.551	2.383	2.334	2.355	2.474	(41)	
(42)		Ebn at Noon	302	302	298	295	289	289	293	299	291	290	290	298	(42)	
(43)		Edh at Noon	35	35	33	30	29	28	28	31	39	43	42	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1802	1835	1836	1853	1708	1634	1729	1962	2151	2224	2114	1964	(44)	
(45)		RadStd	172	234	199	167	103	69	53	68	108	117	76	147	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.76	N/A	N/A	N/A	N/A	-0.76	N/A	N/A	N/A	N/A

Nomenclature: See separate page