

CENTRAL ARNHAM PLATEAU, Australia

WMO: 941410

Lat: 13.328S

Lon: 133.086E

Elev: 416

StdP: 96.42

Time Zone: 9.50 (AUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.3	14.8	-3.4	3.0	24.5	-1.6	3.5	24.6	9.4	22.5	8.9	22.6	2.8	120	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	10.3	35.9	19.4	35.1	19.6	34.3	19.7	24.2	29.5	23.9	29.0	23.6	28.6	4.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.8	18.5	26.2	22.6	18.2	26.0	22.2	17.8	25.8	75.5	29.8	74.1	29.3	73.0	28.6	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.4	7.7	7.1	DB	10.4	37.5	1.1	1.0	9.6	38.2	9.0	38.7	8.3	39.3	7.5	40.0
			WB	6.1	25.2	1.0	0.6	5.4	25.7	4.8	26.0	4.2	26.3	3.5	26.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	27.1	27.2	27.3	26.7	24.8	22.3	22.3	23.1	26.1	28.4	28.8	28.1	(6)
	DBStd	2.82	1.51	1.48	1.46	1.37	1.88	2.30	1.98	1.96	1.87	1.44	1.44	1.67	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	3	0	0	0	0	0	2	1	0	0	0	0	0	(9)
	CDD10.0	5844	530	481	538	499	459	370	381	406	484	569	566	561	(10)
	CDD18.3	2806	272	247	279	249	201	122	123	148	234	311	316	302	(11)
	CDH23.3	28242	2397	2208	2647	2436	1677	863	986	1509	2748	3903	3740	3128	(12)
	CDH26.7	11714	843	812	1046	983	531	185	227	519	1324	2044	1855	1343	(13)
(14) Wind	WSAvg	3.6	3.6	3.4	3.2	3.7	4.1	4.3	4.1	3.7	3.5	3.5	3.1	3.1	(14)
(15) Precipitation	PrecAvg	1207	266	273	211	67	15	7	5	5	9	30	96	222	(15)
	PrecMax	1839	436	504	481	301	53	23	23	25	89	146	213	350	(16)
	PrecMin	810	109	110	40	3	2	2	1	1	1	1	32	88	(17)
	PrecStd	278	96	104	118	66	13	5	4	4	16	33	39	80	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.4	34.3	34.7	33.7	32.0	30.9	30.8	32.9	35.2	36.9	37.0	36.8	(19)
		MCWB	22.0	20.6	20.9	20.1	20.0	18.5	18.3	17.7	17.6	18.8	19.2	20.6	(20)
	2%	DB	33.2	33.2	33.7	32.9	31.1	29.7	29.8	31.6	34.2	35.8	35.8	35.0	(21)
		MCWB	22.4	21.6	20.8	20.0	19.8	18.4	17.5	17.3	17.8	18.7	19.6	21.6	(22)
	5%	DB	32.2	32.3	32.7	32.2	30.4	28.7	28.9	30.6	33.4	35.0	35.0	33.7	(23)
		MCWB	22.7	22.1	21.0	20.1	19.5	18.1	17.1	16.7	17.6	18.9	19.9	21.8	(24)
	10%	DB	30.9	31.2	31.7	31.3	29.6	27.7	28.0	29.6	32.6	34.1	34.1	32.6	(25)
		MCWB	23.0	22.5	21.4	20.0	19.3	17.5	16.7	16.2	17.4	18.7	20.2	22.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.1	24.4	24.5	23.6	22.7	20.7	20.7	20.6	22.1	22.9	23.9	24.3	(27)
		MCDB	30.8	29.8	29.3	27.7	27.9	27.2	26.4	27.5	27.5	28.9	29.6	30.4	(28)
	2%	WB	24.3	24.0	23.9	23.0	22.2	20.0	19.8	19.6	21.4	22.2	23.2	23.9	(29)
		MCDB	29.6	29.2	28.5	27.4	27.1	26.4	26.0	26.6	27.5	28.1	28.8	29.5	(30)
	5%	WB	23.9	23.6	23.6	22.6	21.6	19.4	19.0	18.7	20.8	21.9	22.9	23.6	(31)
		MCDB	28.9	28.5	28.0	27.0	26.6	25.9	26.2	26.6	27.5	27.8	28.5	29.0	(32)
	10%	WB	23.6	23.3	23.2	22.2	21.1	18.9	18.2	17.9	20.1	21.5	22.5	23.2	(33)
		MCDB	28.3	28.0	27.5	26.7	26.3	25.4	25.2	26.6	26.9	27.9	28.2	28.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	7.5	8.0	9.2	9.5	10.5	11.4	12.9	12.9	12.0	10.3	8.4	(35)
		MCDBR	9.1	9.3	10.1	10.5	9.9	10.7	11.9	13.6	13.6	12.9	11.6	10.2	(36)
	5% WB	MCWBR	2.4	2.4	2.7	2.5	2.6	3.5	3.7	4.3	3.9	3.4	3.0	2.6	(37)
		MCWBR	7.4	7.5	7.4	7.6	7.9	9.5	9.9	11.6	10.6	10.7	9.7	8.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.390	0.384	0.378	0.354	0.341	0.325	0.318	0.326	0.384	0.412	0.424	0.404	(40)
		taud	2.541	2.554	2.566	2.612	2.597	2.585	2.601	2.551	2.383	2.334	2.355	2.474	(41)
	Ebn at Noon		953	951	938	930	910	910	925	944	918	914	914	938	(42)
		Edh at Noon	111	109	105	95	90	88	89	99	124	134	132	118	(43)
(44) All-Sky Solar Radiation	RadAvg		5.68	5.79	5.79	5.84	5.38	5.15	5.45	6.18	6.78	7.01	6.67	6.19	(44)
	RadStd		0.54	0.74	0.63	0.53	0.33	0.22	0.17	0.21	0.34	0.37	0.24	0.46	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.42	N/A	N/A	N/A	N/A	-0.42	N/A	N/A	N/A	N/A

Nomenclature: See separate page