

CAPE WESSEL, Australia

WMO: 941470

Lat: 11.004S

Lon: 136.759E

Elev: 63

StdP: 14.66

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	73.0	73.7	61.6	82.0	75.8	63.5	87.8	76.3	29.0	77.3	27.7	77.8	16.1	150	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.6	93.8	80.3	92.6	80.2	91.6	80.1	84.0	87.5	82.8	87.6	82.1	87.5	10.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.3	174.5	85.3	82.0	166.9	84.6	80.9	160.8	84.7	48.2	87.3	46.9	87.5	46.1	87.4	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.2	25.9	24.2	DB	71.2	95.9	1.4	1.5	70.2	97.0	69.4	97.9	68.6	98.8	67.6	99.9	(4)
(5)			WB	64.2	84.8	2.6	1.9	62.3	86.2	60.8	87.3	59.4	88.4	57.5	89.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.9	84.5	83.9	83.8	83.9	82.7	80.6	79.3	79.6	81.4	83.8	85.7	86.0
	DBStd	2.93	2.43	2.56	2.28	2.17	1.80	1.85	1.63	1.58	1.44	1.61	1.61	2.42
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12014	1069	948	1048	1016	1012	917	909	916	943	1049	1071	1116
	CDD65	6539	604	528	583	566	547	467	444	451	493	584	621	651
	CDH74	70539	7438	6342	6877	6597	5875	4135	3197	3228	4411	6407	7688	8344
	CDH80	25279	3087	2462	2564	2417	1649	749	505	710	1332	2410	3453	3941
Wind	WSAvg	14.2	13.7	13.9	12.0	14.0	17.5	19.0	18.5	15.7	13.7	12.3	9.9	10.3
Precipitation	PrecAvg	54.2	10.6	11.1	9.3	6.6	4.0	1.5	0.7	0.3	0.3	0.6	1.5	5.4
	PrecMax	83.8	26.1	26.2	21.1	38.0	21.7	9.7	3.3	0.9	2.2	5.2	14.1	17.0
	PrecMin	7.8	0.7	0.4	0.2	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	21.9	6.5	7.7	5.0	8.0	5.1	2.2	0.8	0.3	0.6	1.1	3.1	4.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.7	92.7	92.1	91.6	89.4	87.6	86.4	87.6	89.8	92.6	94.4	95.9
		MCWB	81.2	81.7	81.7	80.5	79.3	77.0	75.9	75.6	77.7	78.5	79.9	80.4
	2%	DB	91.9	91.4	90.8	90.2	88.2	86.1	85.2	86.3	88.4	91.2	93.0	94.5
		MCWB	80.9	81.3	81.2	79.9	78.7	76.4	75.5	75.3	77.0	78.4	79.9	80.3
	5%	DB	90.7	90.0	89.7	89.2	87.2	85.1	84.1	85.2	87.4	90.0	92.0	93.2
		MCWB	80.8	80.9	80.8	79.6	78.3	76.1	75.0	74.8	76.5	78.2	79.5	80.0
	10%	DB	89.2	88.5	88.4	88.0	86.1	84.0	83.0	84.0	86.4	89.0	91.0	91.7
		MCWB	80.5	80.5	80.5	79.2	77.9	75.6	74.5	74.2	76.1	77.9	79.2	79.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	84.6	84.5	85.3	84.3	81.0	79.6	78.6	78.3	79.9	82.2	82.7	84.9
		MCDB	87.4	87.7	87.3	85.8	86.4	83.6	83.3	83.9	86.8	88.0	90.6	87.9
	2%	WB	82.8	83.2	83.7	82.1	80.1	78.0	77.3	77.1	78.7	80.2	81.5	83.1
		MCDB	87.6	87.7	87.0	86.8	85.8	83.4	82.0	83.6	84.9	88.2	89.9	88.1
	5%	WB	81.9	82.3	82.5	81.1	79.4	77.1	76.5	76.2	77.9	79.2	80.6	81.9
		MCDB	87.4	87.5	86.7	86.3	84.9	82.9	81.5	82.9	84.8	87.5	89.3	88.2
	10%	WB	81.1	81.5	81.5	80.4	78.8	76.4	75.6	75.3	77.1	78.4	79.8	81.0
		MCDB	86.9	86.8	86.2	85.8	84.1	82.2	81.3	82.2	84.7	86.6	88.6	88.6
Mean Daily Temperature Range	5% DB	MDBR	8.7	8.2	8.4	8.2	7.2	7.3	8.1	9.9	11.2	11.5	11.5	10.6
		MCDBR	10.4	9.7	9.9	9.3	8.1	8.2	9.1	10.9	11.8	12.1	12.3	12.9
		MCWBR	4.7	4.7	5.0	5.1	4.3	4.3	4.6	4.9	4.8	4.9	4.7	4.7
	5% WB	MCDBR	9.2	9.1	8.8	8.7	7.4	7.3	8.5	10.4	11.2	11.8	11.6	11.1
		MCWBR	5.0	5.4	5.5	5.1	4.3	4.3	4.6	4.8	4.9	5.1	5.1	5.4
Clear-Sky Solar Irradiance	taub	0.414	0.405	0.392	0.388	0.396	0.390	0.378	0.376	0.400	0.409	0.410	0.401	
	taud	2.550	2.573	2.620	2.617	2.562	2.558	2.591	2.577	2.488	2.462	2.497	2.567	
	Ebn at Noon	295	295	294	286	273	270	277	285	287	291	294	298	
	Edh at Noon	35	34	31	30	30	30	29	31	36	37	36	34	
All-Sky Solar Radiation	RadAvg	1616	1632	1590	1595	1514	1421	1534	1810	2057	2191	2184	1886	
	RadStd	220	267	159	208	160	113	67	67	66	96	112	225	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+0.74	+0.32	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page