

BORROLOOLA, AustraliaWMO: **941520**Lat: **16.0773S**Lon: **136.3050E**Elev: **17**StdP: **101.13**Time Zone: **9.50 (AUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	9.8	-6.8	2.1	26.7	-3.9	2.7	25.8	7.7	23.2	7.2	24.3	0.6	210	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.2	38.7	22.3	37.5	22.8	36.5	23.0	27.4	32.2	27.0	31.7	26.6	31.2	4.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.7	29.2	25.9	21.2	28.9	25.5	20.8	28.6	87.3	32.4	85.2	31.8	83.4	31.2	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	7.0	6.4	DB	5.4	41.1	1.1	1.4	4.6	42.1	4.0	42.9	3.4	43.7	2.6	44.7	(4)
(5)			WB	3.7	28.2	1.3	0.6	2.7	28.6	1.9	29.0	1.2	29.3	0.2	29.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.4	29.2	29.0	28.4	26.9	23.9	21.3	21.2	22.5	25.9	28.6	30.2	30.5	(6)	
	DBStd	3.93	1.90	1.66	1.62	1.77	2.66	2.94	2.62	2.43	2.16	1.97	1.56	1.93	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	17	0	0	0	0	2	8	6	1	0	0	0	0	(9)	
	CDD10.0	5999	597	531	569	507	431	338	348	386	477	576	604	635	(10)	
	CDD18.3	2974	338	297	311	257	174	97	96	129	227	318	354	377	(11)	
	CDH23.3	35619	4039	3439	3433	2801	1913	1104	1166	1541	2624	3989	4640	4929	(12)	
	CDH26.7	17551	1898	1546	1565	1377	848	391	412	638	1378	2224	2598	2677	(13)	
(14) Wind	WSAvg	2.7	2.6	2.5	2.3	2.4	2.4	2.5	2.5	2.7	2.9	3.1	3.1	3.0	(14)	
(15) Precipitation	PrecAvg	940	211	212	193	51	11	7	1	1	4	17	67	166	(15)	
	PrecMax	1639	803	757	533	282	52	42	4	9	40	91	351	429	(16)	
	PrecMin	389	58	14	10	0	5	4	0	0	0	0	5	24	(17)	
	PrecStd	391	163	164	164	68	14	8	1	2	9	25	81	111	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.6	38.1	38.7	36.2	34.6	33.0	32.7	34.1	36.8	39.0	39.6	40.6	(19)	
		MCWB	24.7	24.0	22.7	22.6	21.5	21.1	19.2	19.2	20.4	21.0	20.9	21.8	(20)	
	2%	DB	36.6	35.9	35.7	35.1	33.5	31.7	31.5	32.6	35.4	37.5	38.3	38.5	(21)	
		MCWB	24.9	25.2	24.1	22.7	20.8	19.8	18.6	18.6	19.9	21.3	21.8	23.2	(22)	
	5%	DB	35.2	34.6	34.3	34.1	32.4	30.5	30.4	31.5	34.4	36.3	37.0	37.1	(23)	
		MCWB	25.3	25.6	24.5	22.7	20.4	19.0	17.9	18.0	19.8	21.6	22.5	23.9	(24)	
	10%	DB	33.9	33.4	33.2	33.1	31.3	29.1	29.2	30.4	33.2	35.1	35.9	35.7	(25)	
		MCWB	25.6	25.8	24.7	22.7	20.1	18.1	17.3	17.6	19.4	21.7	22.7	24.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.0	27.7	26.7	25.5	23.2	22.4	22.2	24.2	26.1	26.6	27.3	(27)	
		MCDB	33.8	32.8	32.0	31.2	30.7	30.2	29.6	29.1	30.8	32.4	31.6	31.3	(28)	
	2%	WB	27.2	27.5	27.0	25.9	23.8	21.9	21.2	21.5	23.4	25.3	26.0	26.7	(29)	
		MCDB	32.6	32.2	31.4	30.5	29.2	27.8	27.4	28.0	29.6	31.1	31.3	31.1	(30)	
	5%	WB	26.7	27.0	26.5	25.2	23.0	21.0	20.2	20.8	22.8	24.6	25.5	26.2	(31)	
		MCDB	31.7	31.7	30.8	29.7	28.6	27.0	26.1	26.9	28.8	30.5	30.9	30.9	(32)	
	10%	WB	26.3	26.6	26.1	24.7	22.1	20.1	19.3	19.9	22.2	24.0	25.0	25.9	(33)	
		MCDB	30.9	30.9	30.2	29.1	27.9	26.4	25.6	26.2	28.5	30.0	30.6	30.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	8.4	9.5	12.6	15.3	16.2	17.0	16.9	15.9	13.9	12.0	10.2	(35)	
		MCDBR	11.1	10.9	12.1	14.2	15.5	16.2	17.1	17.2	16.4	15.0	14.0	12.7	(36)	
	5% WB	MCWBR	3.0	3.3	3.7	4.9	5.6	6.4	6.4	5.9	4.8	4.3	3.6	3.2	(37)	
		MCWBR	9.0	8.7	8.8	11.0	13.3	14.6	14.7	14.3	13.9	12.4	10.9	9.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.410	0.405	0.393	0.376	0.352	0.332	0.330	0.335	0.388	0.415	0.432	0.423	(40)	
		taud	2.486	2.502	2.530	2.536	2.540	2.557	2.551	2.520	2.390	2.346	2.351	2.421	(41)	
	Ebn at Noon	Ebn at Noon	935	931	922	902	891	894	905	930	911	911	908	922	(42)	
		Edh at Noon	117	114	108	101	94	89	92	101	122	132	133	125	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	5.89	5.92	5.79	5.71	5.21	4.85	5.18	5.98	6.76	7.09	6.95	6.37	(44)	
	RadStd	RadStd	0.63	0.79	0.64	0.48	0.27	0.28	0.16	0.17	0.27	0.41	0.34	0.62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page