

GROOTE EYLANDT, Australia

WMO: 941530

Lat: 13.9747S

Lon: 136.4631E

Elev: 47

StdP: 14.67

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	52.3	55.4	46.2	46.4	67.4	48.8	51.2	68.7	16.6	82.3	15.5	82.1	1.6	90	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	14.8	96.4	76.1	94.7	76.7	93.2	76.9	82.1	89.3	81.3	88.5	80.7	88.0	9.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.0	86.8	79.2	151.7	85.4	78.8	149.7	84.9	46.1	89.5	45.1	89.0	44.4	88.5	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	14.9	13.5	48.3	99.8	2.4	2.1	46.6	101.3	45.3	102.5	43.9	103.7	42.2	105.2		
(5)			47.1	83.4	2.1	1.1	45.6	84.2	44.3	84.8	43.1	85.4	41.6	86.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.0	84.2	83.7	82.4	80.3	76.8	72.5	71.6	71.9	76.3	80.6	83.4	85.0
	DBStd	5.76	2.56	2.31	2.31	2.12	3.46	4.51	3.94	3.48	3.27	2.98	2.72	2.71
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	9	0	0	0	0	0	4	4	1	0	0	0	0
	CDD50	10596	1061	945	1004	908	832	676	669	678	788	948	1003	1084
	CDD65	5130	596	525	539	458	367	230	208	214	338	483	553	619
	CDH74	57035	7243	6174	5816	4611	3469	1833	1718	2208	3684	5723	6765	7791
CDH80	23898	3159	2605	2334	1896	1191	405	355	624	1535	2741	3279	3774	
Wind	WSAvg	5.7	6.3	6.1	4.8	4.7	5.0	5.6	5.5	5.7	5.8	6.2	6.2	6.3
Precipitation	PrecAvg	48.3	8.7	9.3	10.6	6.6	1.5	0.3	0.1	0.1	0.2	1.1	2.8	7.0
	PrecMax	76.2	20.4	17.4	23.9	21.9	7.5	1.6	0.8	0.5	2.8	3.5	9.1	16.6
	PrecMin	26.9	3.8	2.2	2.3	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.4
	PrecStd	14.2	4.3	4.0	6.1	5.7	1.7	0.4	0.2	0.1	0.6	1.0	2.6	3.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.7	96.4	95.3	93.3	90.4	87.6	86.5	88.9	92.9	96.4	98.1	98.7
		MCWB	76.7	77.8	78.5	76.5	75.3	73.7	70.9	69.3	69.7	72.9	75.4	75.6
	2%	DB	94.7	93.7	92.6	91.6	89.0	85.8	85.1	87.0	90.7	93.7	94.9	96.4
		MCWB	77.9	78.9	78.6	76.7	74.9	72.7	70.5	69.0	71.8	74.0	75.5	76.4
	5%	DB	92.5	91.8	90.9	90.0	87.6	84.2	83.9	85.5	89.3	91.9	93.2	94.2
		MCWB	78.7	79.1	78.5	76.6	74.9	72.0	70.0	68.7	71.6	74.3	75.9	77.2
	10%	DB	90.5	90.0	89.3	88.7	86.1	82.5	82.2	83.9	87.7	90.4	91.6	92.2
		MCWB	79.0	79.2	78.7	76.7	74.3	71.1	69.6	68.3	71.6	74.5	76.4	77.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.7	83.4	83.4	82.7	80.6	76.5	75.2	74.9	77.6	79.8	81.0	82.0
		MCDB	90.1	90.0	89.7	88.7	87.1	83.5	83.4	83.4	86.4	88.5	89.1	88.7
	2%	WB	81.7	81.7	81.7	80.3	78.3	75.1	73.6	73.4	76.2	78.6	80.0	81.0
		MCDB	89.2	89.1	88.6	87.4	84.8	82.8	81.4	81.8	85.5	87.7	88.3	88.4
	5%	WB	80.9	80.8	80.7	79.2	77.2	73.9	72.3	72.3	75.2	77.8	79.3	80.4
		MCDB	88.2	88.1	87.5	86.3	84.2	81.2	80.3	81.2	84.9	86.9	87.5	88.0
	10%	WB	80.2	80.0	79.9	78.2	76.1	72.7	71.0	71.0	74.2	76.9	78.7	79.8
		MCDB	87.2	87.1	86.4	85.2	83.0	79.8	79.1	80.1	83.8	86.1	86.8	87.5
Mean Daily Temperature Range	5% DB	MDBR	12.5	12.9	13.8	17.4	18.8	19.3	21.2	24.3	23.7	21.3	17.3	14.8
		MCDBR	15.6	15.9	17.0	19.9	20.1	19.5	22.0	25.7	24.8	22.5	19.2	17.8
		MCWBR	5.5	6.2	7.3	9.0	9.2	9.5	10.5	11.3	10.2	7.9	6.4	5.9
	5% WB	MCDBR	13.1	13.6	14.0	16.3	16.5	17.6	19.7	22.8	22.2	19.4	16.6	14.6
		MCWBR	5.8	6.0	6.9	8.4	8.6	8.9	10.2	11.6	10.5	7.9	6.4	5.6
Clear-Sky Solar Irradiance	taub	0.403	0.397	0.389	0.382	0.370	0.354	0.341	0.342	0.375	0.407	0.420	0.411	
	taud	2.564	2.582	2.601	2.597	2.598	2.605	2.638	2.610	2.498	2.425	2.434	2.511	
	Ebn at Noon	298	298	294	286	279	279	286	294	294	291	291	296	
	Edh at Noon	34	34	32	30	29	28	27	30	35	39	39	36	
All-Sky Solar Radiation	RadAvg	1846	1849	1745	1661	1556	1475	1598	1870	2116	2249	2209	2025	
	RadStd	181	228	180	201	115	107	56	61	82	103	91	178	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+0.74	+0.32	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page